



## Department of Energy

Bonneville Power Administration  
P.O. Box 3621  
Portland, Oregon 97208-3621

FREEDOM OF INFORMATION ACT/PRIVACY PROGRAM

September 28, 2018

In reply refer to: FOIA #BPA-2018-01550-F

Mike D. White  
Coos Forest Protective Association  
63612 Fifth Road  
Coos Bay, Oregon 97420  
[Mike.D.White@oregon.gov](mailto:Mike.D.White@oregon.gov)

Dear Mr. White:

This communication is the Bonneville Power Administration's (BPA) final response to your request for agency records made under the Freedom of Information Act, 5 U.S.C. § 552 (FOIA). Your records request was received on August 28, 2018 and was formally acknowledged on September 7, 2018.

### Request

"Line fault and/or outage report data for [...] BPA, Bandon-Fairview Transmission line, on July 25, 2018 between 8:00 a.m. - 5:00 p.m."

### Response

BPA conducted electronic searches for responsive records in the following agency offices:

Substation Operations North Bend

Responsive records were gathered. BPA is herein releasing 5 pages of agency records with no redactions applied.

### Fee

There are no FOIA fees applicable to the fulfillment of your request for BPA records.

### Certification

Pursuant to 10 C.F.R. § 1004.7(b)(2), I am the individual responsible for the records release and determinations described above. Your FOIA request BPA-2017-01550-F is now closed with all available agency records provided.

### Appeal

The adequacy of the search may be appealed within 90 calendar days from your receipt of this letter pursuant to 10 C.F.R. § 1004.8. Appeals should be addressed to:

Director, Office of Hearings and Appeals  
HG-1, L'Enfant Plaza  
U.S. Department of Energy  
1000 Independence Avenue, S.W.  
Washington, D.C. 20585-1615

The written appeal, including the envelope, must clearly indicate that a FOIA appeal is being made. You may also submit your appeal by e-mail to [OHA.filings@hq.doe.gov](mailto:OHA.filings@hq.doe.gov), including the phrase "Freedom of Information Appeal" in the subject line. (The Office of Hearings and Appeals prefers to receive appeals by email.) The appeal must contain all the elements required by 10 C.F.R. § 1004.8, including a copy of the determination letter. Thereafter, judicial review will be available to you in the Federal District Court either (1) in the district where you reside, (2) where you have your principal place of business, (3) where DOE's records are situated, or (4) in the District of Columbia.

You may contact BPA's FOIA Public Liaison, Jason Taylor, at the address on this letter header for any further assistance and to discuss any aspect of your request. Additionally, you may contact the Office of Government Information Services (OGIS) at the National Archives and Records Administration to inquire about the FOIA mediation services they offer. The contact information for OGIS is as follows:

Office of Government Information Services  
National Archives and Records Administration  
8601 Adelphi Road-OGIS  
College Park, Maryland 20740-6001  
E-mail: [ogis@nara.gov](mailto:ogis@nara.gov)  
Phone: 202-741-5770  
Toll-free: 1-877-684-6448  
Fax: 202-741-5769

Questions about this communication may be directed to Thanh Knudson, Flux Resources, LLC, at [etknudson@bpa.gov](mailto:etknudson@bpa.gov) or 503.230.5221

Sincerely,



Rachel L. Hull  
Freedom of Information/Privacy Act Officer

Responsive records attached

The information contained herein is transmission system information subject to Bonneville Power Administration's Standards of Conduct.

**SYSTEM-WIDE Daily Interruptions Report**

Jul 25 2018 05:00 through Jul 26 2018 04:59

**Customer Service Interruptions**

Out Datetime	In Datetime	Name	Duration (minutes)	Outage Type	Cause Dispatch	Responsible System Dispatch	MW Intrpt	OPS SPC Headquarter	O&M District	Control Center	Outage ID
07/24/2018 07:51		McMinnville: McMinnville W&L 115kV Feeder 1	still out	Plan	Maintenance	BPA	None	CHE	SAL	Munro	206960
07/24/2018 07:39		McMinnville: McMinnville W&L 115kV Feeder 2	still out	Plan	Maintenance	BPA	None	CHE	SAL	Munro	206958
07/24/2018 07:39		McMinnville: McMinnville W&L 115kV Feeder 3	still out	Plan	Maintenance	BPA	None	CHE	SAL	Munro	206959
07/23/2018 09:20		Ross: Clark Public Util 69kV Feeder 4	still out	Plan	Maintenance	Customer	None	ROS	LGV	Munro	206950
07/23/2018 09:00		Grand Coulee #2 Metering Point: Grant Co PUD 115kV Feeder 1	still out	Plan	Maintenance	BPA	Unknown	SIC	WEN	Munro	206947
07/23/2018 08:34		Fairview: PacifiCorp (PACW) 230kV Feeder 2	still out	Plan	Maintenance	Customer	None	NOR	EUG	Munro	206944
07/16/2018 10:35		Clatsop: PacifiCorp (PACW) 115kV Feeder 1	still out	Plan	Maintenance	Customer	Unknown	LGV	LGV	Munro	206830
07/16/2018 08:39		Port Angeles: Clallam Co PUD 115kV Feeder 1	still out	Plan	Maintenance	Customer	Unknown	OLY	OLY	Munro	206824
07/09/2018 13:15		Valhalla: Chelan Co PUD 115kV Feeder 1	still out	Plan	Oper Plan/RTCA Reqd Action	BPA	Unknown	SIC	WEN	Munro	206744
06/05/2018 04:56		Snohomish: Snohomish Co PUD 115kV Feeder 9	still out	Plan	Maintenance	Customer	None	SNO	SNO	Dittmer	206307
04/25/2018 10:31		Lynch Creek: Ohop Mutual Light 12.5kV Feeder 1 by Tacoma Power	still out	Plan	Maintenance	Customer	None	COV	COV	Dittmer	205788
04/13/2018 00:04		Fords Prairie CCL: Centralia City Lt 69kV Feeder 1	still out	Plan	Maintenance	Customer	Unknown	OLY	OLY	Munro	205677
03/20/2018 08:11		McCullough: Elmhurst Mutual 115kV Feeder 1 by Tacoma Power	still out	Plan	Maintenance	Customer	None	COV	COV	Dittmer	205415

**Transmission Line Interruptions**

Out Datetime	In Datetime	Name	Duration (minutes)	Outage Type	Cause Dispatch	Responsible System Dispatch	Length (miles)	OPS SPC Headquarter	O&M District	Transmission Owner NERC TADS	Control Center	Outage ID
07/25/2018 15:01	07/25/2018 15:01	Goshen-Drummond No 1 161kV line	0	Auto	Lightning	BPA	72.8	IDF	IDF	BPAT	Munro	206976
07/25/2018 10:56	07/25/2018 11:04	Big Eddy-Celilo No 2 500kV line	8	Auto	Equipment/Miscellaneous	BPA	0.6	CEL TDA	TDA	BPAT	Dittmer	206974
07/25/2018 10:56	07/25/2018 11:04	Celilo-Sylmar Pole No 4 1000kV line	8	Auto	Equipment/Miscellaneous	BPA	844.2	CEL	TDA RED	LDWP	Dittmer	206975
07/25/2018 08:33	07/25/2018 10:42	Priest River-Laclede section of Albeni Falls-Sand Creek No 1 115kV line	129	Plan	Maintenance	BPA	6.3	BEL	SPK	BPAT	Munro	206973
07/25/2018 08:08		River Road-Alcoa 115kV line	still out	Plan	Maintenance	BPA	0.2		LGV	CPUD	Munro	206972
07/24/2018 07:52		Lookout Point PH-Lookout Point No 1 115kV line	still out	Plan	Maintenance	BPA	0.2	ALV	EUG	BPAT	Munro	206963
07/24/2018 07:52	07/25/2018 14:19	McMinnville-PGE Dayton No 1 115kV line	1827	Plan	Maintenance	BPA	4.5	CHE	SAL	PGE	Munro	206964
07/24/2018 07:51	07/25/2018 14:12	Windishar-McMinnville section of Carlton-McMinnville No 1 115kV line	1821	Plan	Maintenance	BPA	1.5	CHE	SAL	BPAT	Munro	206961
07/24/2018 07:51	07/25/2018 14:12	Walnut City-McMinnville section of Forest Grove-McMinnville No 1 115kV line	1821	Plan	Maintenance	BPA	2.2	CHE	SAL	BPAT	Munro	206962
07/24/2018 07:03		Snohomish-Bothell No 1 230kV line	still out	Plan	Maintenance	BPA	7.6	SNO	SNO	BPAT	Dittmer	206957
07/23/2018 16:56		Bonneville PH 1-North Bonneville No 2 230kV line	still out	Plan	Maintenance	BPA	0.8	ROS	LGV	BPAT	Munro	206953
07/23/2018 12:05		Detroit PH-Detroit No 1 230kV line	still out	Plan	Maintenance	BPA	0.5	CHE	SAL	BPAT	Munro	206951
07/23/2018 08:56		Reston-Fairview No 2 230kV line	still out	Plan	Maintenance	BPA	29.5	ALV NOR	EUG	BPAT	Munro	206946
07/23/2018 08:55		Fairview-Rogue No 1 230kV line	still out	Plan	Maintenance	BPA	65.3	NOR	EUG	BPAT	Munro	206945
07/23/2018 08:29		Cardwell-Ariel section of Cardwell-PACW Merwin No 1 115kV line	still out	Plan	Maintenance	Foreign	15.5	LGV	LGV	PAC	Munro	206943
07/23/2018 08:24		Ariel-PACW Merwin section of Cardwell-PACW Merwin No 1 115kV line	still out	Plan	Construction	Foreign	0.8	LGV	LGV	PAC	Munro	206942
07/23/2018 08:14		North Bonneville-Troutdale No 1 230kV line	still out	Plan	Maintenance	BPA	27.7	ROS	LGV	BPAT	Munro	206940
07/23/2018 08:14		Grand Coulee-B212 section of Grand Coulee-Creston No 1 115kV line	still out	Plan	Maintenance	BPA	1.6	BEL SIC	WEN	BPAT	Munro	206941
07/23/2018 08:04	07/25/2018 14:43	Hawkins-Hideaway section of Hawkins-Alvey No 1 115kV line	3279	Plan	Maintenance	BPA	5.3	ALV	EUG	BPAT	Munro	206938
07/23/2018 07:52		Swan Valley-Teton No 2 115kV line	still out	Plan	Construction	BPA	35.4	IDF	IDF	BPAT	Munro	206935

Out Datetime	In Datetime	Name	Duration (minutes)	Outage Type	Cause Dispatch	Responsible System Dispatch	Length (miles)	OPS SPC Headquarter	O&M District	Transmission Owner NERC TADS	Control Center	Outage ID
07/23/2018 07:28		Elmo-Kerr section of Kalispell-Kerr No 1 115kV line	still out	Plan	Construction	BPA	12.8	KAL	KAL	BPAT	Munro	206931
07/23/2018 06:53	07/25/2018 16:38	Salem-Grand Ronde No 1 115kV line	3465	Plan	Maintenance	BPA	27.8	CHE	SAL	BPAT	Munro	206930
07/23/2018 06:13		Bonneville-Acton section of Bonneville PH 1-Hood River No 1 115kV line	still out	Plan	Maintenance	BPA	0.4	ROS TDA	LGV TDA	BPAT	Munro	206929
07/23/2018 05:53		Bonneville PH 2-North Bonneville No 4 230kV line	still out	Plan	Maintenance	BPA	1.3	ROS	LGV	BPAT	Munro	206927
07/20/2018 22:46	07/25/2018 19:33	Garrison-Taft No 2 500kV line	7007	Plan	Voltage Control	BPA	159.4	BEL GAR KAL	KAL SPK	BPAT	Dittmer	206919
07/16/2018 10:35		Driscoll-Clatsop section of Allston-Clatsop No 1 230kV line	still out	Plan	Maintenance	BPA	21.8	LGV	LGV	BPAT	Munro	206829
07/16/2018 08:59		Driscoll tap to Allston-Clatsop No 1 230kV line	still out	Plan	Maintenance	BPA	0.2	LGV	LGV	BPAT	Munro	206827
07/16/2018 04:07		Tacoma-TPWR Northeast No 3 230kV line	still out	Plan	Forced	BPA	0.1	COV	COV	TPWR	Dittmer	206812
07/14/2018 15:55		Driscoll-Cathlamet section of Driscoll-Naselle No 1 115kV line	still out	Plan	Load Control	BPA	6.5	LGV	LGV	BPAT	Munro	206791
07/09/2018 08:05		McNary-Morrow Flat No 2 230kV line	still out	Plan	Construction	BPA	16.3	FRA MCN	TRI	BPAT	Munro	206732
07/02/2018 09:33		Longview-Mint Farm No 1 115kV line	still out	Plan	Maintenance	Foreign	1.1		LGV	COWZ	Munro	206685
06/11/2018 09:28		Mint Farm-Olive Way 115kV line	still out	Plan	Maintenance	Foreign	0.4		LGV	COWZ	Munro	206389
04/02/2018 11:14		Maple Valley-Talbot No 1 230kV line	still out	Plan	Maintenance	Foreign	0.2	COV	COV	PSE	Dittmer	205567
02/12/2018 08:01		Big Eddy-Chenoweth No 1 115kV line	still out	Plan	Maintenance	BPA	6.5	TDA	TDA	BPAT	Munro	205148
10/03/2015 04:00		Big Eddy-Celilo No 3 230kV line	still out	Plan	Maintenance	BPA	1.1	CEL TDA	TDA	BPAT	Dittmer	194942
10/03/2015 04:00		Big Eddy-Celilo No 4 230kV line	still out	Plan	Maintenance	BPA	1.0	CEL TDA	TDA	BPAT	Dittmer	194943

**Transformer Interruptions (bulk electric system only)**

Out Datetime	In Datetime	Name	Voltage High (kV)	Voltage Low (kV)	Duration (minutes)	Outage Type	Cause Dispatch	Responsible System Dispatch	OPS SPC Headquarter	O&M District	Transmission Owner NERC TADS	Control Center	Outage ID
07/23/2018 09:11		Sno-King: 230/115kV Transformer 2	230.0	115.0	still out	Plan	Construction	BPA	SNO	SNO	BPAT	Dittmer	206948
07/23/2018 06:02		Alvey: 230/115kV Transformer 3	230.0	115.0	still out	Plan	Maintenance	BPA	ALV	EUG	BPAT	Munro	206928
07/16/2018 10:35		Clatsop: 230/115kV Transformer 1	230.0	115.0	still out	Plan	Forced	Foreign	LGV	LGV	BPAT	Munro	206831
06/18/2018 13:32		Pearl: 500/230kV Transformer 2	500.0	230.0	still out	Plan	Maintenance	BPA	CHE	SAL	BPAT	Dittmer	206458
07/17/2017 05:00		Grand Coulee: 287/230kV Transformer 1	287.0	230.0	still out	Plan	Maintenance	BPA	SIC	WEN	USBR	Munro	202882
07/17/2017 05:00		Olympia: 287/230kV Transformer 3	287.0	230.0	still out	Plan	Maintenance	BPA	OLY	OLY	BPAT	Munro	202883

**Additional Information**

07/26/2018 05:00	Thermal Generation		PNW/PSW Intertie
	Boardman <sup>1</sup>	943	AC Schedule <sup>2</sup> 2794
	Centralia 1 <sup>1</sup>	527	Actual <sup>1</sup> 2908
	Centralia 2 <sup>1</sup>	648	DC Schedule <sup>2</sup> 2338
	Columbia Generating Station <sup>1</sup>	1147	Actual <sup>1</sup> 2530

Notes: <sup>1</sup>SCADA, megawatts, instantaneous value; <sup>2</sup>Rotary Account, megawatts, integrated hourly value ending

**SUMMARY OF OUTAGES**

**Automatic**

	Equipment Back in Normal Service					Still	Total
	0 min	01-30	31-60	Hour+	Total	Out	Reported
Customer	0	0	0	0	0	0	0
Transmission 1	2	0	0	0	3	0	3
Transformer 0	0	0	0	0	0	0	0
<b>Total</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>

**Planned**

	Equipment Back in Normal Service				Total	Out	Total
	0 hrs	01-08	09-24	24+	Total	Reported	
Customer	0	0	0	0	0	13	13
Transmission 0	1	0	0	6	7	26	33
Transformer 0	0	0	0	0	0	6	6
<b>Total</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>6</b>	<b>7</b>	<b>45</b>	<b>52</b>