



Department of Energy

Bonneville Power Administration
P.O. Box 3621
Portland, Oregon 97208-3621

FREEDOM OF INFORMATION ACT/PRIVACY PROGRAM

December 7, 2021

In reply refer to: FOIA #BPA-2022-00100-F

Larry Johnson
Law Office of Larry G. Johnson
8505 129th Ave SE
Newcastle, WA 98056-1757
Email: larry.ede@gmail.com
Phone: 425-890-4404

Dear Mr. Johnson,

This communication concerns your agency records request submitted to the Bonneville Power Administration (BPA), made via the Freedom of Information Act, 5 U.S.C. § 552 (FOIA). Your request was received on November 1, 2021, and formally acknowledged on November 24, 2021.

Original Request

“[Preamble and Background Information] A consulting firm in Massachusetts, Synapse, conducted within the last two or three years load flow studies (also known as power studies) to analyze a Puget Sound Energy (PSE) proposed project within King County, Washington, known as Energize Eastside. In a report about its conclusions drawn from those studies, Synapse claims to have discovered a Bulk Electric System (BES) vulnerability caused by a transmission line deficiency in King County, Washington. According to Synapse, this problem apparently has existed now from an indeterminate time into the present. Specifically, Synapse states in its report: “...our analysis shows that the current summer electric peak demand in King County has already triggered an operational need for the proposed transmission expansion to address system contingency scenarios and ensure the security of the Bulk Electric System.

[Records requested are] ...any and all documents in [BPA’s] possession, or to which [BPA has] ready access, that references or relates to any known security or other vulnerability problem(s) in the BES within King County, Washington, due to a transmission line deficiency. The time frame for this records request is from January 1, 2020, to the present. This request is satisfied if limited to notification(s) to or from [BPA] about any claimed, identified, or known security or other vulnerability problem in the BES within King County, Washington, due to a transmission line deficiency, and [BPA’s] responses thereto. This request includes but is not limited to records [BPA has] ... or [has] ready access, to or from the following entities: 1. Puget Sound Energy. 2. RC West (the Reliability Coordinator for the WECC region). 3. The Bonneville Power Administration. 4. Seattle City Light. 5. Northern Grid (successor to Columbia Grid).”

Request Clarification

On November 10, 2021, the agency requested additional clarification on your original request, specifically in regards to a proposed definition of a transmission line deficiency as, “an unexpected failure or outage of a system component.” You replied: “The language in the Synapse report ... discusses a Bulk Electric System vulnerability in King County caused by a transmission line deficiency in King County. I believe that [language] means that unless some new transmission line is built in King County, then under summer peak load conditions under two contingencies (N-2) the grid would go unstable. [Specifically, is BPA] aware of such a problem Bulk Electric System ‘vulnerability’ as I have defined in this paragraph? [Additionally, i]n direct response to your thinking that a transmission line deficiency is defined as ‘an unexpected failure or outage of a system component’[,] [BPA’s] definition is a definition of what a *contingency* is[;] a transmissions line *deficiency* means more transmission lines need to be built in order to avoid instability in the grid under *contingency* conditions.”

Response

The agency’s Transmission Operations Planning office gathered twelve pages of responsive records. These records contain the applicable ALL LINES IN SERVICE study results during the 2021 summer operating season and the 2020-2021 winter operating season (most current study results over the past year). The records indicate that BPA is currently setting limits to the identified limiting element and limiting contingency pair. This applies to the request for information regarding “transmission line deficiency.” These records are being released in full with no redactions.

Fees

There are no fees associated with the processing of your FOIA request.

Certification

Pursuant to 10 C.F.R. § 1004.7(b)(2), I am the individual responsible for the information search and the release described above. Your FOIA request BPA-2022-00100-F is now closed with the responsive agency information provided.

Appeal

The adequacy of the search may be appealed within 90 calendar days from your receipt of this letter pursuant to 10 C.F.R. § 1004.8. Appeals should be addressed to:

Director, Office of Hearings and Appeals
HG-1, L’Enfant Plaza
U.S. Department of Energy
1000 Independence Avenue, S.W.
Washington, D.C. 20585-1615

The written appeal, including the envelope, must clearly indicate that a FOIA appeal is being made. You may also submit your appeal by e-mail to OHA.filings@hq.doe.gov, including the phrase "Freedom of Information Appeal" in the subject line. (The Office of Hearings and Appeals prefers to receive appeals by email.) The appeal must contain all the elements required by 10 C.F.R. § 1004.8, including a copy of the determination letter. Thereafter, judicial review will be available to you in the Federal District Court either (1) in the district where you reside, (2) where you have your principal place of business, (3) where DOE's records are situated, or (4) in the District of Columbia.

Questions about this communication may be directed to BPA FOIA Public Liaison Jason E. Taylor at 503-230-3537 or jetaylor@bpa.gov. Additionally, you may contact the Office of Government Information Services (OGIS) at the National Archives and Records Administration to inquire about the FOIA mediation services they offer. The contact information for OGIS is as follows:

Office of Government Information Services
National Archives and Records Administration
8601 Adelphi Road-OGIS
College Park, Maryland 20740-6001
E-mail: ogis@nara.gov
Phone: 202-741-5770
Toll-free: 1-877-684-6448
Fax: 202-741-5769

Thank you for your interest in the Bonneville Power Administration.

Sincerely,



Candice D. Palen
Freedom of Information/Privacy Act Officer

[Attachment: Responsive records](#)

None

Summer 2021

North of Echolake (NOEL) South-to-North (SN)

Heavy Loads


Outage: 21H

Temp: 32F

Average Puget Sound Net Area Load = 5149

G0
G1
G2
G3
G4
G5
G6
G7
G8
G9
G10
G11


| Gen Level | NOEL | | Worst Contingency | Limiting Facility |
|-----------|------|----------|---|---|
| | PSE | SCL/SNOH | | |
| G0 | 110 | 104 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G1 | 110 | 249 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G2 | 110 | 630 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G3 | 410 | 104 | BFR_Monroe PCB 4526 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 249 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 630 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G6 | 675 | 104 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 249 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G8 | 675 | 630 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G9 | 1030 | 104 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G10 | 1030 | 249 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G11 | 1030 | 630 | BFR_Monroe PCB 4522 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |



| Gen # | PSE Gen | SCL Gen | Transfer Limit | Worst Contingency | Limiting Facility |
|-------|---------|---------|----------------|--|---|
| G2 | 110 | 630 | 2826 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 630 | 2826 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 630 | 2828 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 630 | 2868 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G1 | 110 | 249 | 2779 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 249 | 2824 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 249 | 2834 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G10 | 1030 | 249 | 2868 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G3 | 410 | 104 | 2723 | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G6 | 675 | 104 | 2797 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G9 | 1030 | 104 | 2868 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |

None
 Summer 2021
 North of Echolake (NOEL) South-to-North (SN)
 Heavy Loads
 Outage: 21H
 Temp: 60F


| Average Puget Sound Net Area Load = 4381 | | | |
|--|------|----------|---|
| Gen Level | NOEL | | Limiting Facility |
| | PSE | SCL/SNOH | |
| G0 | 110 | 104 | 2610 BFR_Monroe PCB 4526 Monroe-Echo Lake-S Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G1 | 110 | 249 | 2610 BFR_Monroe PCB 4526 Monroe-Echo Lake-S Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G2 | 110 | 630 | 2610 BFR_Monroe PCB 4526 Monroe-Echo Lake-S Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G3 | 410 | 104 | 2591 BFR_Monroe PCB 4522 Monroe-Echo Lake-S Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 249 | 2567 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G5 | 410 | 630 | 2413 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G6 | 675 | 104 | 2619 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G7 | 675 | 249 | 2546 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 630 | 2396 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G9 | 1030 | 104 | 2501 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G10 | 1030 | 249 | 2501 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 630 | 2501 BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |



| Gen # | PSE Gen | SCL Gen | Transfer Limit | Worst Contingency | Limiting Facility |
|-------|---------|---------|----------------|--|---|
| G2 | 110 | 630 | 2610 | BFR_Monroe PCB 4526 Monroe-Echo Lake-S Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 630 | 2413 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 630 | 2396 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 630 | 2501 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G1 | 110 | 249 | 2610 | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 249 | 2567 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G7 | 675 | 249 | 2546 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G10 | 1030 | 249 | 2501 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G3 | 410 | 104 | 2591 | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G6 | 675 | 104 | 2619 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G9 | 1030 | 104 | 2501 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |

None
 Summer 2021
 North of Echolake (NOEL) South-to-North (SN)
 Heavy Loads
 Outage: 21H
 Temp: 86F

| Average Puget Sound Net Area Load = 4659 | | | | | |
|--|-----------|----------|-----------|---|---|
| Gen | Gen Level | | NOEL Path | Worst Contingency | Limiting Facility |
| | PSE | SCL/SNOH | | | |
| G0 | 110 | 104 | 2455 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G1 | 110 | 249 | 2455 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G2 | 110 | 630 | 2455 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G3 | 410 | 104 | 2426 | BFR_Monroe PCB 4526 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 249 | 2404 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G5 | 410 | 630 | 2285 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G6 | 675 | 104 | 2446 | BFR_Monroe PCB 4526 Monroe-Echo Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 249 | 2395 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 630 | 2258 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G9 | 1030 | 104 | 2342 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G10 | 1030 | 249 | 2342 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 630 | 2342 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |



| Gen # | PSE Gen | SCL Gen | Transfer Limit | Worst Contingency | Limiting Facility |
|-------|---------|---------|----------------|---|---|
| G2 | 110 | 630 | 2455 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G5 | 410 | 630 | 2285 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 630 | 2258 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 630 | 2342 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G1 | 110 | 249 | 2455 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G4 | 410 | 249 | 2404 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G7 | 675 | 249 | 2395 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G10 | 1030 | 249 | 2342 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G3 | 410 | 104 | 2426 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G3 | 410 | 104 | 2426 | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND Custer 500/230kV | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G6 | 675 | 104 | 2446 | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND Custer 500/230kV | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G9 | 1030 | 104 | 2342 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |

Interface Scenario IO

| | Trans Lim | Limiting Element | Limiting CTG | % OTDF | Pre-Trans Est | Limit Used | ATC Mon: MW flow Puget Sound Area Net Load (207) | Iteratively Found | ATC Mon: MW flow North of Echo Lake (3480) |
|------|-----------|---|---|--------|---------------|------------|--|-------------------|--|
| 32F | | | | | | | | | |
| _G1 | | 3231.15 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.21 | -497.67 | -496.6 | 5171.87 FULL | | 2778.91 |
| _G3 | | 3247.67 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.21 | -491.41 | -494.53 | 5127.21 FULL | | 2723.05 |
| _G4 | | 3578.86 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.21 | -498.36 | -496.13 | 5164.12 FULL | | 2823.68 |
| _G5 | | 3904.01 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.5 | -2500.7 | -2524.02 | 5105.47 FULL | | 2825.83 |
| _G6 | | 3655.54 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.19 | -497.31 | -496.32 | 5154.85 FULL | | 2796.99 |
| _G7 | | 3874.33 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.2 | -496.9 | -495.69 | 5175.52 FULL | | 2833.89 |
| _G8 | | 4168.53 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.56 | -2534.39 | -2524.53 | 5110.11 FULL | | 2828.07 |
| _G10 | | 4272.21 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.15 | -495.92 | -498.01 | 5181.04 FULL | | 2868.09 |
| 60F | | | | | | | | | |
| _G1 | | 3377.35 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.14 | -466.2 | -464.93 | 4434.68 FULL | | 2610.1 |
| _G3 | | 3465.52 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.13 | -463.78 | -465.82 | 4398.47 FULL | | 2590.55 |
| _G4 | | 3596.51 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.41 | -2315.04 | -2322.58 | 4395.81 FULL | | 2566.65 |
| _G5 | | 3594.34 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.41 | -2311.38 | -2323.56 | 4315.39 FULL | | 2413.41 |
| _G6 | | 3805.21 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.5 | -2326.49 | -2320.85 | 4400.79 FULL | | 2619.12 |
| _G7 | | 3792.3 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.5 | -2318.88 | -2328.62 | 4395.81 FULL | | 2545.7 |
| _G8 | | 3811.04 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.5 | -2324.25 | -2330.84 | 4312.16 FULL | | 2395.53 |
| _G10 | | 4026.1 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.54 | -2337.18 | -2332.14 | 4393.7 FULL | | 2501.2 |
| 86F | | | | | | | | | |
| _G1 | | 2916.56 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.32 | -2070.52 | -2082.17 | 4708.88 FULL | | 2454.63 |
| _G3 | | 2992.3 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.14 | -427.37 | -425.8 | 4673.36 FULL | | 2426.28 |
| _G4 | | 3088.23 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.35 | -2124.98 | -2128.98 | 4674.74 FULL | | 2403.57 |
| _G5 | | 3162.13 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.35 | -2168.51 | -2157.25 | 4595.47 FULL | | 2285.14 |
| _G6 | | 3285.74 Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -9.14 | -427.92 | -426.11 | 4681.81 FULL | | 2445.86 |
| _G7 | | 3316.84 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.37 | -2154.14 | -2144.2 | 4676.99 FULL | | 2395.22 |
| _G8 | | 3356.61 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.37 | -2168.58 | -2159.05 | 4592.69 FULL | | 2257.87 |
| _G10 | | 3532.68 Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.37 | -2108.72 | -2099.83 | 4671.39 FULL | | 2341.91 |

| North of Echolake (NOEL) South-to-North (SN) | | Heavy Loads | | | | | | 21H None | | | | | |
|--|------|-------------|------|------|------|------|------|----------|------|------|------|------|------|
| PSE Gen | | 110 | 110 | 110 | 410 | 410 | 410 | 675 | 675 | 675 | 1030 | 1030 | 1030 |
| SCL + SNPD Gen | LOAD | 104 | 249 | 630 | 104 | 249 | 630 | 104 | 249 | 630 | 104 | 249 | 630 |
| 32F | 5149 | 2779 | 2779 | 2779 | 2723 | 2824 | 2826 | 2797 | 2834 | 2828 | 2868 | 2868 | 2868 |
| 60F | 4381 | 2610 | 2610 | 2610 | 2591 | 2567 | 2413 | 2619 | 2546 | 2396 | 2501 | 2501 | 2501 |
| 86F | 4659 | 2455 | 2455 | 2455 | 2426 | 2404 | 2285 | 2446 | 2395 | 2258 | 2342 | 2342 | 2342 |
| | | G0 | G1 | G2 | G3 | G4 | G5 | G6 | G7 | G8 | G9 | G10 | G11 |

Limiting Element

Limiting CTG

| | |
|--|---|
| Line CUSTER (40323) TO MONROE (40749) CKT 2 500.00 - 5 | BFR Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Bank 1 |
| Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 | BFR Monroe PCB 4522 Monroe-Echo Lake-SnoKing 1 500kV AND Monroe 500kV Capacitor Group 3 |
| Limiting Element | Limiting CTG |
| #N/A | #N/A |
| #N/A | #N/A |
| #N/A | #N/A |
| #N/A | #N/A |
| #N/A | #N/A |

| | 32F | 60F | 86F |
|------|---------|---------|---------|
| _G1 | 2778.91 | 2610.10 | 2454.63 |
| _G3 | 2723.05 | 2590.55 | 2426.28 |
| _G4 | 2823.68 | 2566.65 | 2403.57 |
| _G5 | 2825.83 | 2413.41 | 2285.14 |
| _G6 | 2796.99 | 2619.12 | 2445.86 |
| _G7 | 2833.89 | 2545.70 | 2395.22 |
| _G8 | 2828.07 | 2395.53 | 2257.87 |
| _G10 | 2868.09 | 2501.20 | 2341.91 |

| | |
|----------------------|--|
| Description: | None |
| Season/Year: | Summer 2021 |
| Direction: | North of Echolake (NOEL) South-to-North (SN) |
| Case Loads: | Heavy Loads |
| Outage: | 21H |
| Power World: | 21 |
| Study Person: | Dan Pool, David Chis, Daniel Kuraspediani |
| Source: | 21HS_SNH_NOEL |

*Note: The presence of a "red" box indicates a further examination in Powerworld is required

ALIS

WINTER 2021

North of Echolake (NOEL) South-to-North (SN)


Heavy Loads

Outage: 21H

Temp: 25F

Average Puget Sound Net Area Load = 6813

| | Gen Level | | NOEL Path | Worst Contingency | Limiting Facility |
|-----|-----------|----------|-----------|--|---|
| | PSE | SCL/SNOH | | | |
| G0 | 110 | 119 | 3190 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G1 | 110 | 301 | 3190 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G2 | 110 | 670 | 3190 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G3 | 410 | 119 | 3185 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 301 | 3245 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 670 | 3280 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G6 | 675 | 119 | 3222 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 301 | 3228 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G8 | 675 | 670 | 3293 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G9 | 1030 | 119 | 3292 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G10 | 1030 | 301 | 3292 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G11 | 1030 | 670 | 3292 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |



| Gen # | PSE Gen | SCL Gen | Transfer Limit | Worst Contingency | Limiting Facility |
|-------|---------|---------|----------------|--|---|
| G2 | 110 | 670 | 3190 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 670 | 3280 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G8 | 675 | 670 | 3293 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G11 | 1030 | 670 | 3292 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G1 | 110 | 301 | 3190 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 301 | 3245 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 301 | 3228 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G10 | 1030 | 301 | 3292 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G3 | 410 | 119 | 3185 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G6 | 675 | 119 | 3222 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G9 | 1030 | 119 | 3292 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing 1 500kV AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |

ALIS

WINTER 2021

North of Echolake (NOEL) South-to-North (SN)


Heavy Loads

Outage: 21H

Temp: 45F

Average Puget Sound Net Area Load = 5753

| | Gen Level | | NOEL Path | Worst Contingency | Limiting Facility |
|-----|-----------|----------|-----------|---|---|
| | PSE | SCL/SNOH | | | |
| G0 | 110 | 119 | 3032 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G1 | 110 | 301 | 3032 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G2 | 110 | 670 | 3032 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G3 | 410 | 119 | 3049 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 301 | 3028 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 670 | 2992 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G6 | 675 | 119 | 3087 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 301 | 3067 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-S | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G8 | 675 | 670 | 2962 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G9 | 1030 | 119 | 3072 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G10 | 1030 | 301 | 3072 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 670 | 3072 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |



| Gen # | PSE Gen | SCL Gen | Transfer Limit | Worst Contingency | Limiting Facility |
|-------|---------|---------|----------------|--|---|
| G2 | 110 | 670 | 3032 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing_1_500kV_AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G5 | 410 | 670 | 2992 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV_AND_Custer_500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 670 | 2962 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV_AND_Custer_500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 670 | 3072 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV_AND_Custer_500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G1 | 110 | 301 | 3032 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing_1_500kV_AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G4 | 410 | 301 | 3028 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing_1_500kV_AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G7 | 675 | 301 | 3067 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing_1_500kV_AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G10 | 1030 | 301 | 3072 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV_AND_Custer_500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G3 | 410 | 119 | 3049 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing_1_500kV_AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G6 | 675 | 119 | 3087 | BFR_Monroe_PCB_4526_Monroe-Echo_Lake-SnoKing_1_500kV_AND | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] |
| G9 | 1030 | 119 | 3072 | BFR_Custer_PCB_4268_Monroe-Custer_1_500kV_AND_Custer_500/230kV | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |

ALIS

WINTER 2021

North of Echolake (NOEL) South-to-North (SN)


Heavy Loads

Outage: 21H

Temp: 70F

Average Puget Sound Net Area Load = 4450

| | Gen Level | | NOEL Path | Worst Contingency | Limiting Facility |
|-----|-----------|----------|-----------|--|-------------------|
| | PSE | SCL/SNOH | | | |
| G0 | 110 | 119 | 2714 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G1 | 110 | 301 | 2714 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G2 | 110 | 670 | 2714 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G3 | 410 | 119 | 2711 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G4 | 410 | 301 | 2641 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G5 | 410 | 670 | 2493 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G6 | 675 | 119 | 2664 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G7 | 675 | 301 | 2616 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G8 | 675 | 670 | 2456 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G9 | 1030 | 119 | 2545 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G10 | 1030 | 301 | 2545 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |
| G11 | 1030 | 670 | 2545 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | |



| Gen # | PSE Gen | SCL Gen | Transfer Limit | Worst Contingency | Limiting Facility |
|-------|---------|---------|----------------|---|--|
| G2 | 110 | 670 | 2714 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G5 | 410 | 670 | 2493 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G8 | 675 | 670 | 2456 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G11 | 1030 | 670 | 2545 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G1 | 110 | 301 | 2714 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G4 | 410 | 301 | 2641 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G7 | 675 | 301 | 2616 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G10 | 1030 | 301 | 2545 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G3 | 410 | 119 | 2711 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G6 | 675 | 119 | 2664 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |
| G9 | 1030 | 119 | 2545 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] |

Interface Scenario IO

| | Trans Lim | Limiting Element | Limiting CTG | % OTDF | Pre-Trans Est | Limit Used | ATC Mon: MW flow Puget Sound Area Net Load (207) | Iteratively Found | ATC Mon: MW flow North of Echo Lake (3480) |
|------|-----------|---|---|--------|---------------|------------|--|-------------------|--|
| 25F | | | | | | | | | |
| _G1 | 2708.48 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.33 | -505.8 | -505.68 | 6836.31 FULL | | 3190.23 |
| _G3 | 2865.09 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.33 | -506.48 | -505.47 | 6810.02 FULL | | 3184.69 |
| _G4 | 3128.93 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.33 | -507.43 | -506.56 | 6820.55 FULL | | 3244.92 |
| _G5 | 3577.49 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.27 | -525.7 | -525.72 | 6778.77 FULL | | 3280.37 |
| _G6 | 3219.93 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.33 | -507.06 | -507.15 | 6816.53 FULL | | 3222.16 |
| _G7 | 3380.98 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.33 | -503.68 | -505.1 | 6818.72 FULL | | 3228.11 |
| _G8 | 3886.92 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.27 | -524.66 | -524.72 | 6784.6 FULL | | 3293.3 |
| _G10 | 3884.26 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.32 | -507.29 | -506.12 | 6835.32 FULL | | 3292.12 |
| 45F | | | | | | | | | |
| _G1 | 3121.49 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.36 | -481.06 | -482.64 | 5788.47 FULL | | 3032.4 |
| _G3 | 3320.61 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.35 | -484.74 | -483.21 | 5765.3 FULL | | 3049.16 |
| _G4 | 3428.5 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.35 | -478.92 | -480.2 | 5763.53 FULL | | 3028.34 |
| _G5 | 3722.01 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -50.21 | -2362.19 | -2354.7 | 5697.35 FULL | | 2991.61 |
| _G6 | 3670.79 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.35 | -485.2 | -483.68 | 5772.61 FULL | | 3086.84 |
| _G7 | 3788.17 | Line SNOKING_S3 (41008) TO MAP_SK3_CIO2 (410081) CKT 1 [230.00 - 230.00 kV] | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND | -8.34 | -483.47 | -481.53 | 5774.98 FULL | | 3067.07 |
| _G8 | 3932.98 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.91 | -2356 | -2366.35 | 5691.45 FULL | | 2961.58 |
| _G10 | 4148.33 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.89 | -2369.04 | -2376.09 | 5772.37 FULL | | 3071.51 |
| 70F | | | | | | | | | |
| _G1 | 3325.05 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.98 | -2194.06 | -2201.78 | 4511.78 FULL | | 2713.82 |
| _G3 | 3465.43 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.96 | -2188.54 | -2194.23 | 4486.01 FULL | | 2711.25 |
| _G4 | 3458.04 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.96 | -2185.43 | -2193.55 | 4467.78 FULL | | 2641.49 |
| _G5 | 3502.2 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.96 | -2195.79 | -2204.8 | 4375.12 FULL | | 2492.78 |
| _G6 | 3643.51 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.96 | -2182.42 | -2187.75 | 4477.23 FULL | | 2664.29 |
| _G7 | 3691.47 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.96 | -2200.6 | -2204.35 | 4462.39 FULL | | 2616.18 |
| _G8 | 3693.06 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.96 | -2198.38 | -2204.17 | 4367.58 FULL | | 2455.71 |
| _G10 | 3895.84 | Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 500.00 kV] | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/23 | -49.92 | -2201.99 | -2190.54 | 4449.25 FULL | | 2544.91 |

21HW_SNH_NOEL

| North of Echolake (NOEL) South-to-North (SN) | | | Heavy Loads | | | | 21H | ALIS | | | | | |
|--|------|------|-------------|------|------|------|------|------|------|------|------|------|------|
| PSE Gen | | 110 | 110 | 110 | 410 | 410 | 410 | 675 | 675 | 675 | 1030 | 1030 | 1030 |
| SCL + SNPD Gen | LOAD | 119 | 301 | 670 | 119 | 301 | 670 | 119 | 301 | 670 | 119 | 301 | 670 |
| 25F | 6813 | 3190 | 3190 | 3190 | 3185 | 3245 | 3280 | 3222 | 3228 | 3293 | 3292 | 3292 | 3292 |
| 45F | 5753 | 3032 | 3032 | 3032 | 3049 | 3028 | 2992 | 3087 | 3067 | 2962 | 3072 | 3072 | 3072 |
| 70F | 4450 | 2714 | 2714 | 2714 | 2711 | 2641 | 2493 | 2664 | 2616 | 2456 | 2545 | 2545 | 2545 |
| | | G0 | G1 | G2 | G3 | G4 | G5 | G6 | G7 | G8 | G9 | G10 | G11 |

Limiting Element

Limiting CTG

| | |
|---|---|
| Line CUSTER (40323) TO MONROE (40749) CKT 2 [500.00 - 5 | BFR_Custer PCB 4268 Monroe-Custer 1 500kV AND Custer 500/230kV Bank 1 |
| Line SNOKING S3 (41008) TO MAP_SK3_CIO2 (410081) CKT | BFR_Monroe PCB 4526 Monroe-Echo Lake-SnoKing 1 500kV AND Monroe 500kV Capacitor Group 2 |
| Limiting Element | Limiting CTG |
| #N/A | #N/A |
| #N/A | #N/A |
| #N/A | #N/A |
| #N/A | #N/A |
| #N/A | #N/A |

| | 25F | 45F | 70F |
|-------------|---------|---------|---------|
| _G1 | 3190.23 | 3032.40 | 2713.82 |
| _G3 | 3184.69 | 3049.16 | 2711.25 |
| _G4 | 3244.92 | 3028.34 | 2641.49 |
| _G5 | 3280.37 | 2991.61 | 2492.78 |
| _G6 | 3222.16 | 3086.84 | 2664.29 |
| _G7 | 3228.11 | 3067.07 | 2616.18 |
| _G8 | 3293.30 | 2961.58 | 2455.71 |
| _G10 | 3292.12 | 3071.51 | 2544.91 |

| | |
|----------------------|--|
| Description: | ALIS |
| Season/Year: | WINTER 2021 |
| Direction: | North of Echolake (NOEL) South-to-North (SN) |
| Case Loads: | Heavy Loads |
| Outage: | 21H |
| Power World: | 21 |
| Study Person: | Dan Pool, Daniel Kuraspediani, David Chis |
| Source: | 21HW_SNH_NOEL |

*Note: The presence of a "red" box indicates a further examination in Powerworld is required