



Redispatch Events on the Federal System

This document provides information about BPAT Redispatch as outlined in the 2018-2019 Rate Case Settlement, Attachment M.

March FY 2018 Events

Date	Start Time	End Time	Flowgate or Path	MWh Requested	Redispatch Type	INC Source	INC MW	INC Cost \$/mwh	DEC Source	DEC MW	DEC Cost \$/mwh	Reason for Redispatch/Trans Purchase	Monthly Average Net Cost by Flowgate
3/1/2018 - 3/31/2018	1:00	2400	Northwestern Montana	26,038	Transmission Purchase							Transmission Outage	\$ 112,745.00
3/13/2018	1:00	4:00	Northern Intertie	600	Discretionary	Chief Joseph	600	32	The Dalles McNary Bonneville	600	10	SOL Exceeded	\$ 13,200.00

March Total: \$ 125,945.00
 FY 2018 Year to Date: \$ 491,956.00

March FY18 Events by Flowgate or Path

Flowgate	Max Cost, \$/mwh	Min Cost, \$/mwh	Average Cost, \$/mwh
Flowgate			
North of Hanford			
North of John Day			
North of Echo Lake			
West of John Day			
West of McNary			
Northern Intertie	\$32.00	\$10.00	\$22.00
Path/Area Transmission Purchase			
RATS			
LaGrande			
Northwest Montana	\$4.33	\$4.33	\$4.33

Maximum and minimum costs are calculated as follows:

1. For each event (I*J - L*M)/total MWH of INC
2. Determine highest event value (maximum cost)
3. Determine lowest event value (minimum cost)

Average cost per month for each flow gate is calculated as follows:

1. For each flowgate, sum of events for each column I, J, L, M
2. For each flowgate, use sums from step 1 (I*J - L*M) and divide by the total MWH of INC