

**Bonneville Power Administration**  
**Expanded Standard Offer for Commercial**  
**and Industrial Lighting**

**Frequently Asked Questions**

- Q: The Rebate Verification Report includes high performance fluorescent luminaires with input wattages ranging from 85 watts to 600 watts. The Specifications for the same item require 114 to 750 input watts. Which is correct?**
- A:** The input wattages on the Lighting Rebate Verification Report are correct and should be used. The input wattages listed in some early versions of the specifications are in error.
- Q: Are common areas in multi-family housing eligible to participate in the ESO rebates?**
- A:** Yes. The ESO is intended for most non-residential occupancies, including office space, lobby areas, indoor/outdoor swimming pools, handball courts, exercise rooms, outdoor lighting, etc.