

*in the news*[home](#) [site search](#) [org chart](#) [contact us](#) [web comments](#)

Power outage in Klickitat County

[Click here for other BPA news releases](#)

Bonneville Power Administration

FOR IMMEDIATE RELEASE: THURSDAY, June 1, 2000

PR 60 00

CONTACTS: [Aretha Hyman](#), BPA (503) 230-5131

GOLDENDALE, Wash. – A power outage occurred at 6:52 a.m. Thursday, June 1, on the Bonneville Power Administration high-voltage transmission system north of Dallesport. The BPA maintenance crews tested the transformer at the Goldendale Substation and found it to be operable. They then inspected power lines by helicopter and determined that a connector on the line had failed due to wear and tear. The equipment was repaired and service restored at 2:30 p.m. The outage affected half of Klickitat PUD's customers.

###
