

Ductless Heat Pump Qualified Applications List

This list is to assist utilities in determining whether a specific application is allowed under BPA's residential or commercial Ductless Heat Pump (DHP) measures.

Please contact your Contracting Officer Technical Representative if you have questions on applications not clearly stated in the IM or in this document.

Updated Oct. 01, 2025

Not-Approved DHP Applications for Residential Measures:

- At this time Variable Refrigerant Flow (VRF) technologies do not qualify for the residential ductless heat pump measure. BPA understands that the cost and energy savings for VRFs differ significantly from a standard residential DHP configuration.

