

BP-26 Rate Proceeding

Final Proposal

Power Loads and Resources Study

BP-26-FS-BPA-03

July 2025



POWER LOADS AND RESOURCES STUDY

Table of Contents

	Page
COMMONLY USED ACRONYMS AND SHORT FORMS.....	iii
1. INTRODUCTION AND OVERVIEW.....	1
1.1 Introduction	1
1.2 Overview of Methodology.....	1
2. FEDERAL SYSTEM LOAD OBLIGATION FORECAST	5
2.1 Overview.....	5
2.2 Public Agencies' Total Retail Load and Firm Requirements Power Sales Contract (PSC) Obligation Forecasts	5
2.2.1 Load Following PSC Obligation Forecasts	7
2.2.2 Block PSC Obligation Forecasts	8
2.2.3 Slice/Block PSC Obligation Forecasts.....	9
2.2.4 Tier 2 Load Service PSC Obligation Forecasts.....	10
2.2.5 Sum of Load Following, Slice/Block, Block and Tier 2 PSC Obligation Forecasts	11
2.3 Investor-Owned Utilities Sales Forecast and Other Load Served at NR Rate	11
2.4 Direct Service Industry Sales Forecast	12
2.5 Reclamation Reserve Power Obligations.....	13
2.6 Other Federal System Contract Obligations	14
3. RESOURCE FORECAST	15
3.1 Federal System Resource Forecast	15
3.1.1 Overview.....	15
3.1.2 Hydro Generation.....	15
3.1.2.1 Regulated Hydro Generation Forecast.....	16
3.1.2.2 Independent Hydro Generation Forecast.....	25
3.1.2.3 Small Hydro Generation Forecast.....	26
3.1.3 Non-Hydro Renewable Generation Forecasts	26
3.1.4 Thermal Generation Forecasts.....	26
3.1.5 Contract Purchases.....	27
3.1.6 Uncommitted Purchases	28
3.1.7 Federal System Transmission Losses.....	28
3.2 Regional Hydro Resources	30
3.2.1 Overview.....	30
3.2.2 PNW Regional Hydro Generation	30
3.3 4(h)(10)(C) Credits	30
3.3.1 Overview.....	30
3.3.2 Forecast of Power Purchases Eligible for 4(h)(10)(C) Credits	32
3.4 Use of Tier 1 System Firm Critical Output Calculation	33

4.	FEDERAL SYSTEM LOAD-RESOURCE BALANCE.....	37
4.1	Overview.....	37
4.2	Firm Load-Resource Balance.....	37
4.3	Firm Federal System Energy Load-Resource Balance	38
4.4	Federal System 30-Water-Year Load-Resource Balance	38
	SUMMARY TABLES	41
Table 1	Priority Firm Power Load Obligations—Forecast By Product Annual Energy in aMW	43
Table 2	Loads and Resources—Federal System Summary Annual Energy in aMW <i>(Sums may not be exact due to rounding)</i>	43
Table 3	Loads and Resources—Federal System Components Annual Energy in aMW.....	44

COMMONLY USED ACRONYMS AND SHORT FORMS

AAC	Anticipated Accumulation of Cash
ACNR	Accumulated Calibrated Net Revenue
ACS	Ancillary and Control Area Services
AF	Advance Funding
AFUDC	Allowance for Funds Used During Construction
AGC	automatic generation control
aMW	average megawatt(s)
ANR	Accumulated Net Revenues
AOP	Assured Operating Plan
ASC	Average System Cost
BAA	Balancing Authority Area
BiOp	Biological Opinion
BPA	Bonneville Power Administration
BPAP	Bonneville Power Administration Power
BPAT	Bonneville Power Administration Transmission
Bps	basis points
Btu	British thermal unit
CAISO	California Independent System Operator
CIP	Capital Improvement Plan
CIR	Capital Investment Review
CDQ	Contract Demand Quantity
CGS	Columbia Generating Station
CHWM	Contract High Water Mark
CNR	Calibrated Net Revenue
COB	California-Oregon border
COI	California-Oregon Intertie
Commission	Federal Energy Regulatory Commission (see also “FERC”)
Corps	U.S. Army Corps of Engineers
COSA	Cost of Service Analysis
COU	consumer-owned utility
Council	Northwest Power and Conservation Council (see also “NPCC”)
COVID-19	coronavirus disease 2019
CP	Coincidental Peak
CRAC	Cost Recovery Adjustment Clause
CRFM	Columbia River Fish Mitigation
CSP	Customer System Peak
CT	combustion turbine
CWIP	Construction Work in Progress
CY	calendar year (January through December)
DD	Dividend Distribution
DDC	Dividend Distribution Clause
dec	decrease, decrement, or decremental
DERBS	Dispatchable Energy Resource Balancing Service

DFS	Diurnal Flattening Service
DNR	Designated Network Resource
DOE	Department of Energy
DOI	Department of Interior
DOP	Detailed Operating Plan
DSI	direct-service industrial customer or direct-service industry
DSO	Dispatcher Standing Order
EE	Energy Efficiency
EESC	EIM Entity Scheduling Coordinator
EIM	Energy imbalance market
EIS	environmental impact statement
EN	Energy Northwest, Inc.
ESA	Endangered Species Act
ESS	Energy Shaping Service
e-Tag	electronic interchange transaction information
FBS	Federal base system
FCRPS	Federal Columbia River Power System
FCRTS	Federal Columbia River Transmission System
FELCC	firm energy load carrying capability
FERC	Federal Energy Regulatory Commission
FMM-IIE	Fifteen Minute Market – Instructed Imbalance Energy
FOIA	Freedom of Information Act
FORS	Forced Outage Reserve Service
FPS	Firm Power and Surplus Products and Services
FPT	Formula Power Transmission
FRP	Financial Reserves Policy
F&W	Fish & Wildlife
FY	fiscal year (October through September)
G&A	general and administrative (costs)
GARD	Generation and Reserves Dispatch (computer model)
GDP	Gross Domestic Product
GI	generation imbalance
GMS	Grandfathered Generation Management Service
GSP	Generation System Peak
GSR	Generation Supplied Reactive
GRSPs	General Rate Schedule Provisions
GTA	General Transfer Agreement
GWh	gigawatthour
HLH	Heavy Load Hour(s)
HYDSIM	Hydrosystem Simulator (computer model)
IE	Eastern Intertie
IIE	Instructed Imbalance Energy
IM	Montana Intertie
inc	increase, increment, or incremental
IOU	investor-owned utility

IP	Industrial Firm Power
IPR	Integrated Program Review
IR	Integration of Resources
IRD	Irrigation Rate Discount
IRM	Irrigation Rate Mitigation
IRPL	Incremental Rate Pressure Limiter
IS	Southern Intertie
kcfs	thousand cubic feet per second
kW	kilowatt
kWh	kilowatthour
LAP	Load Aggregation Point
LDD	Low Density Discount
LGIA	Large Generator Interconnection Agreement
LLH	Light Load Hour(s)
LMP	Locational Marginal Price
LPP	Large Project Program
LT	long term
LTF	Long-term Firm
Maf	million acre-feet
Mid-C	Mid-Columbia
MMBtu	million British thermal units
MNR	Modified Net Revenue
MO	market operator
MRNR	Minimum Required Net Revenue
MW	megawatt
MWh	megawatthour
NCP	Non-Coincidental Peak
NEPA	National Environmental Policy Act
NERC	North American Electric Reliability Corporation
NFB	National Marine Fisheries Service (NMFS) Federal Columbia River Power System (FCRPS) Biological Opinion (BiOp)
NLSL	New Large Single Load
NMFS	National Marine Fisheries Service
NOAA Fisheries	National Oceanographic and Atmospheric Administration Fisheries
NOB	Nevada-Oregon border
NORM	Non-Operating Risk Model (computer model)
NWPA	Northwest Power Act/Pacific Northwest Electric Power Planning and Conservation Act
NWPP	Northwest Power Pool
NP-15	North of Path 15
NPCC	Northwest Power and Conservation Council (see also “Council”)
NPV	net present value
NR	New Resource Firm Power
NRFS	NR Resource Flattening Service

NRU	Northwest Requirements Utilities
NT	Network Integration
NTSA	Non-Treaty Storage Agreement
NUG	non-utility generation
OATT	Open Access Transmission Tariff
O&M	operations and maintenance
OATI	Open Access Technology International, Inc.
ODE	Over Delivery Event
OS	oversupply
OY	operating year (August through July)
P10	tenth percentile of a given dataset
PDCI	Pacific DC Intertie
PF	Priority Firm Power
PFp	Priority Firm Public
PFx	Priority Firm Exchange
PNCA	Pacific Northwest Coordination Agreement
PNRR	Planned Net Revenues for Risk
PNW	Pacific Northwest
POD	Point of Delivery
POI	Point of Integration or Point of Interconnection
POR	point of receipt
PPC	Public Power Council
PRSC	Participating Resource Scheduling Coordinator
PS	Power Services
PSC	power sales contract
PSW	Pacific Southwest
PTP	Point-to-Point
PUD	public or people's utility district
RAM	Rate Analysis Model (computer model)
RAS	Remedial Action Scheme
RCD	Regional Cooperation Debt
RD	Regional Dialogue
RDC	Reserves Distribution Clause
REC	Renewable Energy Certificate
Reclamation	U.S. Bureau of Reclamation
REP	Residential Exchange Program
REPSIA	REP Settlement Implementation Agreement
RevSim	Revenue Simulation Model
RFA	Revenue Forecast Application (database)
RHWM	Rate Period High Water Mark
ROD	Record of Decision
RPSA	Residential Purchase and Sale Agreement
RR	Resource Replacement
RRHL	Regional Residual Hydro Load
RRS	Resource Remarketing Service

RSC	Resource Shaping Charge
RSS	Resource Support Services
RT1SC	RHWM Tier 1 System Capability
RTD-IIE	Real-Time Dispatch – Instructed Imbalance Energy
RTIEO	Real-Time Imbalance Energy Offset
SCD	Scheduling, System Control, and Dispatch Service
SCADA	Supervisory Control and Data Acquisition
SCS	Secondary Crediting Service
SDD	Short Distance Discount
SILS	Southeast Idaho Load Service
Slice	Slice of the System (product)
SMCR	Settlements, Metering, and Client Relations
SP-15	South of Path 15
T1SFCO	Tier 1 System Firm Critical Output
TC	Tariff Terms and Conditions
TCMS	Transmission Curtailment Management Service
TDG	Total Dissolved Gas
TGT	Townsend-Garrison Transmission
TOCA	Tier 1 Cost Allocator
TPP	Treasury Payment Probability
TRAM	Transmission Risk Analysis Model
Transmission System Act	Federal Columbia River Transmission System Act
Treaty	Columbia River Treaty
TRL	Total Retail Load
TRM	Tiered Rate Methodology
TS	Transmission Services
TSS	Transmission Scheduling Service
UAI	Unauthorized Increase
UDE	Under Delivery Event
UFE	unaccounted for energy
UFT	Use of Facilities Transmission
UIC	Unauthorized Increase Charge
UIE	Uninstructed Imbalance Energy
ULS	Unanticipated Load Service
USFWS	U.S. Fish & Wildlife Service
VER	Variable Energy Resource
VERBS	Variable Energy Resource Balancing Service
VOR	Value of Reserves
VR1-2014	First Vintage Rate of the BP-14 rate period (PF Tier 2 rate)
VR1-2016	First Vintage Rate of the BP-16 rate period (PF Tier 2 rate)
WECC	Western Electricity Coordinating Council
WPP	Western Power Pool
WRAP	Western Resource Adequacy Program
WSPP	Western Systems Power Pool

This page intentionally left blank.

1. INTRODUCTION AND OVERVIEW

1.1 Introduction

The Power Loads and Resources Study (Study) contains the load and resource data used to develop Bonneville Power Administration's (BPA's) wholesale power rates. This Study illustrates how each component of the loads and resources analysis is completed, how the components relate to each other, and how they fit into the rate development process. The Power Loads and Resources Study Documentation (Documentation), BP-26-FS-BPA-03A, contains details and results supporting this Study.

This Study focuses on fiscal years (FYs) 2026-2028 and has two primary purposes: 1) to determine BPA's monthly and annual energy load and resource balance (load-resource balance); and 2) to provide specific results that are used as inputs in other rate case study processes and calculations. To ensure that BPA has sufficient firm generation to meet its firm load obligations, BPA bases its resource planning on hydro generation estimates under P10 (10th percentile) firm monthly generation from the recent 30 year historical stream flow record. *See* § 3.1.2.1.3 below.

This Study provides inputs for various other studies, processes, and calculations in the ratemaking process. The results of this Study provide data to 1) the Power Rates Study, 2) the Power Revenue Requirement Study, 3) the Power and Transmission Risk Study, and 4) the Power Market Price Study and Documentation.

1.2 Overview of Methodology

This Study includes three main components: 1) load data, including a forecast of the federal system loads and contract obligations; 2) resource data, including federal system generating resource and contract purchase estimates, total Pacific Northwest (PNW)

1 regional hydro resource estimates, and the estimated power purchases that are eligible for
2 Section 4(h)(10)(C) credits under the Pacific Northwest Electric Power Planning and
3 Conservation Act (Northwest Power Act), 16 U.S.C. §§ 839–839h; and 3) the federal system
4 load-resource balance, which compares federal system loads, contract obligations, and
5 sales to the federal system generating resources and contract purchases.

6
7 The first component of the Power Loads and Resources Study is load data, which is the
8 federal system load obligation forecast, or the firm energy that BPA expects to serve during
9 FY 2026-2028 under firm requirements contract obligations and other BPA contract
10 obligations. The load estimates are discussed in Section 2 of this Study and are detailed in
11 the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A.

12
13 The second component of this study is resource data, which includes the forecast of
14 1) federal system resources, 2) PNW regional hydro resources, and 3) power purchases
15 eligible for 4(h)(10)(C) credits. The federal system resource forecast includes hydro and
16 non-hydro generation estimates plus power deliveries from BPA contract purchases. The
17 federal system resource estimates are discussed in Section 3.1 below and are detailed
18 in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A. The PNW
19 regional hydro resources include all hydro resources in the PNW, whether federally or
20 non-federally owned. The regional hydro estimates are discussed in Section 3.2 below and
21 are detailed in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A.
22 The resource estimates used to calculate the 4(h)(10)(C) credits are discussed in
23 Section 3.3 below, and the estimated power purchases eligible for 4(h)(10)(C) credits are
24 detailed in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A.

1 The third component of this Study is BPA's load-resource balance, which is calculated on an
2 annual average energy basis for each year of the rate period, FY 2026, FY 2027 and
3 FY 2028. BPA's firm energy load-resource balance is calculated by subtracting BPA's load
4 and contract obligations from the federal system resources. The load-resource balance is
5 discussed in Section 4 below and is detailed in the Power Loads and Resources Study
6 Documentation, BP-26-FS-BPA-03A.

7
8 Throughout this Study and its documentation, load and resource forecasts are shown using
9 three different measurements. The first, energy in average megawatts (aMW), is the
10 average amount of energy produced or consumed over a given time period, in most cases a
11 month. The second measurement, heavy load hour (HLH) energy in megawatthours
12 (MWh), is the total megawatthours generated or consumed over the heavy load hours of a
13 given time period. HLH can vary by contract but generally are clock hours 06:00 to 22:00
14 Monday through Saturday, excluding North American Electric Reliability Corporation
15 (NERC) holidays. The third measurement, light load hour (LLH) energy in megawatthours,
16 is the total megawatthours generated or consumed over the LLH of a given timeframe. LLH
17 can also vary by contract but generally are clock hours 22:00 to 06:00 Monday through
18 Saturday, all day Sunday, and all day on NERC holidays. Resource forecasts are shown
19 using an additional measurement, one-hour capacity. One-hour capacity in megawatts
20 (MW) is the single highest one hour of forecast generation capability per month and
21 represents the peak forecasted capability that a resource has the ability to meet; this
22 includes forecasted generation, reserves held, and capacity not used in that hour based on
23 optimizing water across that month. These measurements are used to ensure that BPA will
24 have adequate resources to meet the variability of loads.

This page intentionally left blank.

2. FEDERAL SYSTEM LOAD OBLIGATION FORECAST

2.1 Overview

The Federal System Load Obligation forecasts include: 1) BPA's projected firm requirements power sales contract (PSC) obligations to consumer-owned utilities (COUs) and federal agencies (together, for purposes of this Study, called public agencies or public agency customers); 2) PSC obligations to investor-owned utilities (IOUs); 3) PSC obligations to direct-service industries (DSIs); 4) reserve power delivery obligations to the U.S. Bureau of Reclamation (Reclamation); and 5) other BPA contract obligations, including contract obligations outside the PNW region (exports) and contract obligations within the PNW region (intra-regional transfers (out)). This section summarizes BPA's forecasts of these obligations.

2.2 Public Agencies' Total Retail Load and Firm Requirements Power Sales Contract (PSC) Obligation Forecasts

In December 2008, BPA executed PSCs with public agencies under which BPA is obligated to provide power deliveries from October 1, 2011, through September 30, 2028. These contracts are referred to as Contract High Water Mark (CHWM) contracts. Three types of CHWM contracts were offered to customers: Load Following, Slice/Block, and Block (with or without Shaping Capacity). Of the 135 BPA public agency CHWM customers, 125 have Load Following contracts, seven have Slice/Block contracts, and three have Block contracts. These numbers include the product change elections from Slice to Load Following that three customers (Clark County, Snohomish PUD, and Emerald PUD) made in June 2024 that will be effective October 1, 2025.

BPA's obligation to serve public agency customers under their CHWM contracts incorporates the following: Tier 1 System Capability; updated forecasts of each customer's

1 total load obligation; individual customer dedicated resource amounts; and individual
2 customers elections for Above-Rate Period High Water Mark (Above-RHWM) load service.
3 The Tier 1 System Capability is determined for each rate period in the RHWM Process.
4 Above-RHWM load is determined for each rate period in the RHWM Process; any
5 Above-RHWM load service placed on BPA is Tier 2 Load Service. *See* Power Rates Study,
6 BP-26-FS-BPA-01, § 1.4.2.

7
8 Under the CHWM contracts, BPA's load obligation to each customer can consist of RHWM
9 load and Above-RHWM load. The RHWM Process sets the maximum amount of power that
10 a customer may purchase each year of the rate period at the Priority Firm Power (PF)
11 Tier 1 rate, subject to that customer's calculated Net Requirement net of its New Large
12 Single Loads (NLSLs). *See* Tiered Rate Methodology (TRM), BP-12-A-03, § 4.2.
13 Above-RHWM load for each year of the rate period is calculated by subtracting the
14 customer's RHWM from the difference between its forecast Total Retail Load (TRL) (less
15 NLSLs) and its existing resources.

16
17 Each customer elects how to serve Above-RHWM load by 1) adding new non-federal
18 dedicated resources; 2) buying power from sources other than BPA; and/or 3) requesting
19 BPA to supply all or a part of this power. *See* TRM, BP-12-A-03, § 4.3. Under the terms of
20 the CHWM contract and the TRM, the first two options are identified as self-supply and
21 result in a change in the dedicated resource amounts for that customer. If a customer
22 elects for BPA to serve all or part of its Above-RHWM load, BPA will first serve this load
23 from federal surplus generation, then, if needed, purchase power or acquire the output
24 from non-federal generating resources in order meet the customer's Above-RHWM load at
25 a PF Tier 2 rate. Non-federal power purchased or acquired to serve Tier 2 load is separate
26 and distinct from BPA's Tier 1 System Capability. For the purposes of this Study, BPA

1 assumed the following elections for Above-RHWM load for the three customers changing
2 from the Slice product to Load Following product: Clark PUD – self-supply; Snohomish
3 PUD – self-supply (which has no Above-RHWM load); and Emerald PUD – self-supply.
4 Above-RHWM load served by BPA is identified as Tier 2 Load Service, and non-federal
5 power purchases and acquisitions needed above firm federal surplus generation to serve
6 Tier 2 load are identified as Tier 2 Augmentation.

7 8 **2.2.1 Load Following PSC Obligation Forecasts**

9 The Load Following product provides firm power to meet the customer’s total retail load,
10 less the dedicated power from the customer’s non-federal resource generation and
11 purchases from other suppliers. The total monthly firm obligation forecast for public
12 agency customers that purchase the Load Following product is based on the sum of the
13 utility-specific firm requirements PSC load obligation forecasts, which are customarily
14 produced by BPA analysts. The method used for preparing the load obligation forecasts is
15 as follows.

16
17 First, using BPA’s Agency Load Forecast (ALF) model, BPA analysts produce utility-specific
18 forecasts of total retail load by applying least-squares regression on historical monthly
19 energy loads, and for a growing number of customers, a statistically adjusted end-use (SAE)
20 model. The least-squares regression-based models may include several independent
21 variables, such as a time trend, heating degree days, cooling degree days, and monthly
22 indicator variables. The SAE models replace typical independent variables used in load
23 forecasting with calculated indexes for structural measures associated with heating
24 equipment, cooling equipment, and other energy-consuming technologies. Heating and
25 cooling degree days are measures of temperature effects to account for changes in
26 electricity usage related to temperature changes. Heating degree days are calculated when

1 the temperature is below a base temperature, such as 65 degrees Fahrenheit; similarly,
2 cooling degree days are calculated when the temperature is above a base temperature. The
3 results from these computations are utility-specific monthly forecasts of total retail energy
4 load. The energy value for total retail load is split into HLH and LLH time periods using
5 recent historical relationships.

6
7 Second, estimates of customer-owned and consumer-owned dedicated resource generation
8 and contract purchases dedicated to serve retail loads (including those to serve Above-
9 RHWL load) are subtracted from the utility-specific total retail load forecasts to produce
10 BPA's total firm load obligation forecast for each utility. These load obligation forecasts
11 provide the basis for the Load Following product sales projections incorporated in BPA
12 ratemaking.

13
14 A list of the 125 public and federal agency customers that will be purchasing the Load
15 Following product during the BP-26 rate period appears in Power Loads and Resources
16 Study Documentation, BP-26-FS-BPA-03A, Table 1.1.1. BPA's total PSC load obligation
17 forecast including federal agencies is summarized in *id.*, Tables 1.2.1 for energy, 1.2.2 for
18 HLH, and 1.2.3 for LLH, on Line 3 (Load Following). The components of this forecast are
19 also included in the calculation of the load-resource balance, *id.*, Tables 9.1.1 for energy,
20 9.1.2 for HLH, and 9.1.3 for LLH, on Line 1 (Load Following).

21 22 **2.2.2 Block PSC Obligation Forecasts**

23 The Block product provides a planned amount of firm requirements power to serve the
24 customer's retail load up to its planned net requirement. The Block product provides a
25 planned amount of firm requirements power in a fixed monthly shape. The customer is

1 responsible for using its own non-federal resources or unspecified resources to meet any
2 load in excess of its planned monthly BPA purchase.

3
4 The three public agency customers that have selected the Block product are identified in
5 *id.*, Table 1.1.2. BPA's forecast of the total Block Obligation is summarized in *id.*,
6 Tables 1.2.1 for energy, 1.2.2 for HLH, and 1.2.3 for LLH, on Line 14 (Tier 1 Block). This
7 forecast is also included in the calculation of the load-resource balance, *id.*, Tables 9.1.1 for
8 energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 6 (Tier 1 Block).

9 10 **2.2.3 Slice/Block PSC Obligation Forecasts**

11 The Slice/Block product provides firm requirements power to serve the customer's retail
12 load up to its planned net requirement. For each fiscal year, the planned annual
13 Slice/Block amounts are adjusted based on BPA's calculation of the customer's planned net
14 requirement under the contract. The Block portion of the Slice/Block product provides a
15 planned amount of firm requirements power in a fixed monthly shape, while the Slice
16 Output from the Tier 1 System portion provides planned amounts of firm requirements
17 power in the shape of BPA's generation from the Tier 1 System.

18
19 The annual Slice/Block forecast and the monthly shape of the Slice/Block product for
20 FY 2026-2028 are calculated by multiplying the Tier 1 Block Monthly Shaping Factors in
21 the customer's CHWM contract by the customer's planned annual net requirement
22 in average megawatts less its annual forecast Critical Slice Amounts, as defined in the
23 CHWM contract. Critical Slice Amounts are forecast to equal the customer's Slice
24 Percentage, adjusted as described in the TRM, BP-12-A-03, § 3.6, multiplied by the
25 applicable annual RHWMTier 1 System Capability.

1 BPA's Slice Output obligation for the Slice/Block customers is forecast by multiplying the
2 monthly forecast of Tier 1 System output by the sum of the individual customers' Slice
3 Percentages as listed in the Slice/Block CHWM contracts. The Tier 1 System output is
4 comprised of specific federal system resources and contracts identified in the TRM. *See*
5 Section 3.2 below.

6
7 A list of the seven Slice/Block customers appears in Power Loads and Resources Study
8 Documentation, BP-26-FS-BPA-03A, Table 1.1.3. BPA's forecast of the total Slice/Block PSC
9 Obligation is summarized in *id.*, Tables 1.2.1 for energy, 1.2.2 for HLH, and 1.2.3 for LLH, on
10 Line 8 (Slice Block) and Line 11 (Slice Output from T1 System). This forecast is also
11 included in the calculation of the load-resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2
12 for HLH, and 9.1.3 for LLH, on Line 8 (Slice).

13 14 **2.2.4 Tier 2 Load Service PSC Obligation Forecasts**

15 The Tier 2 product provides the portion of Above-RHWM load for which customers have
16 elected BPA to serve. Under the CHWM contracts, each customer's load is separated into
17 load that is eligible to be served at Tier 1 rates, and Above-RHWM load, which can be
18 served by BPA at Tier 2 rates or self-supplied by the customer. The RHWM Process sets the
19 maximum amount of power that a customer may purchase each year of the rate period
20 under Tier 1 rates, subject to that customer's calculated Net Requirement exclusive of its
21 New Large Single Loads (NLSLs). *See* TRM, BP-12-A-03, § 4.2. Above-RHWM load for each
22 year of the rate period is calculated by subtracting the customer's RHWM from the
23 difference between its forecast Total Retail Load (TRL) (less NLSLs) and its existing
24 resources, if positive. Each customer elects how to serve Above-RHWM load. If the
25 customer elects to purchase all or part of its Above RHWM load from BPA, it is called
26 Tier 2 load.

1 BPA's forecast of the total Tier 2 Load Service Obligation is summarized in Power Loads
2 and Resources Study Documentation, BP-22-FS-BPA-03A, Tables 1.2.1 for energy, 1.2.2 for
3 HLH, and 1.2.3 for LLH, on Line 17 (Tier 2 - Load Growth) and Line 22 (Tier 2 – Short
4 Term). This forecast is also included in the calculation of the load-resource balance, *id.*,
5 Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 16 (Tier 2 Load Service).
6

7 **2.2.5 Sum of Load Following, Slice/Block, Block and Tier 2 PSC Obligation** 8 **Forecasts**

9 The sum of the projected firm requirements PSC obligations, for customers with CHWM
10 contracts, comprises the public agencies preference customers' portion of the Priority Firm
11 Public (PFp) load obligation forecast. Each customer's load obligation forecast accounts for
12 the reported amount of conservation the customer plans to achieve during the FY 2024-
13 2025 rate period. These forecasts do not include additional BPA-funded conservation
14 beyond what the customers have reported they plan to achieve. As individual customers
15 achieve conservation measures in addition to what they already committed to, the
16 customers will receive credits on their power bills reflecting lower loads due to the
17 additional conservation measures. The annual average energy PF load obligations for
18 FY 2024-2025 are presented, by product, in Table 1 of this Study.
19

20 **2.3 Investor-Owned Utilities Sales Forecast and Other Load Served at NR Rate**

21 The six IOUs in the PNW region are Avista Corporation, Idaho Power Company,
22 NorthWestern Energy Division of NorthWestern Corporation, PacifiCorp, Portland General
23 Electric Company, and Puget Sound Energy, Inc. Most of the IOUs have signed BPA power
24 sales contracts for net requirement service for FY 2011 through 2028; however, no IOUs
25 have chosen to take service under these contracts. If requested, and eligible by contract,
26 BPA would serve any net requirements of an IOU at the New Resource Firm Power (NR)

1 rate. No net requirements power sales to regional IOUs are forecast for FY 2026-2028
2 based on BPA's current contracts with the regional IOUs.

3
4 In addition, BPA makes power available at the NR rate to any public body, cooperative, or
5 federal agency to the extent such power is used to serve any NLSL as defined by the
6 Northwest Power Act, 16 U.S.C. §§ 839–839h. BPA also offers products at the NR rate for
7 public agency customers electing to serve their NLSLs with their own dedicated resources.
8 One customer, Harney Electric Cooperative, has requested NR service for the FY 2026-2028
9 rate period. Harney Electric Cooperative's election is to serve its planned NLSL, Thacker
10 Pass lithium mine, with NR service in the amount of the mine load net of consumer-owned
11 onsite generation from waste-heat from the mining. In this study, BPA assumes that it will
12 serve the NR amount forecasted as 0.7 aMW in FY 2026, 20 aMW in FY 2027 and 25 aMW
13 in FY 2028, with a peak load of 35 MW in the rate period; the planned NLSL load is included
14 in Power Loads and Resource Study documentation, BP-26-FS-BPA-03A , Tables 9.1.1 for
15 energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 22 (NR Obligations).

17 **2.4 Direct Service Industry Sales Forecast**

18 BPA will make power sales deliveries to one direct service industry customer, Port
19 Townsend Paper Corporation (Port Townsend), during the FY 2026-2028 rate period.

20
21 Port Townsend's current contract with BPA provides for the sale of power through
22 September 30, 2028. BPA deliveries under this contract will provide Port Townsend with a
23 maximum contract demand of 15.75 MW through September 30, 2028. Jefferson County
24 PUD serves Port Townsend's wheel-turning load (load not integral to the industrial
25 process) and Port Townsend's Old Corrugated Containers (OCC) recycling plant load,
26 totaling 8.5 aMW. Jefferson County PUD's load forecast reflects this service arrangement.

1 In this study, BPA assumes that it will continue to serve the remainder of Port Townsend's
2 load during the entire FY 2026-2028 rate period, approximately 11 aMW.

3
4 BPA's DSI contract obligation is included in the federal system load-resource balance in the
5 Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Tables 9.1.1 for
6 energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 11 (Direct Service Industries).

7 8 **2.5 Reclamation Reserve Power Obligations**

9 BPA provides power from the federal system for Reclamation project loads and to serve
10 several irrigation districts and on-site load associated with Reclamation projects.

11 Irrigation districts have been authorized by Congress to receive reserved power from
12 specified Federal Columbia River Power System (FCRPS) projects as part of the
13 Reclamation project authorization. Reclamation also may purchase power from the FCRPS
14 if reserve power is not sufficient to serve irrigation loads. BPA does not contract directly
15 with these irrigation districts; instead, there are several agreements between BPA and
16 Reclamation that provide details on the power deliveries.

17
18 A list of Reclamation obligations appears in the Power Loads and Resources Study
19 Documentation, BP-26-FS-BPA-03A, Table 1.1.4. BPA's forecast of the total Reclamation
20 load is summarized in *id.*, Tables 1.2.1 for energy, 1.2.2 for HLH, and 1.2.3 for LLH, on
21 Line 29 (USBR Obligation). This forecast is also included in the calculation of the
22 load-resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on
23 Line 4 (USBR).

2.6 Other Federal System Contract Obligations

BPA provides federal power to customers under a variety of contract arrangements not included in the public agencies, IOU, DSI, or Reclamation forecasts. These contract obligations are categorized as 1) power sales, 2) power or energy exchanges, 3) capacity sales or capacity-for-energy exchanges, 4) power payments for services, and 5) power commitments under the Columbia River Treaty. These arrangements, collectively called “Other Contract Obligations,” are specified by individual contract provisions and can have various delivery arrangements and rate structures. BPA’s Other Contract Obligations are considered to be firm and are assumed to be served by the federal system resources regardless of weather, water, or economic conditions. These contracts include obligations delivered to entities outside the PNW region (exports) and obligations delivered to entities within the PNW region (intra-regional transfers (out)). These contract obligations are modeled individually and are specified for monthly energy in average megawatts, HLH, and LLH.

BPA’s export contract obligations are detailed in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Tables 2.1.1 for energy, 2.1.2 for HLH, and 2.1.3 for LLH. BPA’s intra-regional transfers (out) contract obligations are detailed in *id.*, Tables 2.3.1 for energy, 2.3.2 for HLH, and 2.3.3 for LLH. These forecasts are also included in the calculation of the load-resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 14 (exports) and Line 15 (intra-regional transfers (out)).

BPA’s load-resource balance in this Study is used to help set the Priority Firm Tier 1 rates. Trading floor sales are included in BPA’s load-resource balance, the revenue impacts of trading floor contracts are reflected as presales of secondary energy and are included as secondary revenues credited to non-Slice customer rates.

3. RESOURCE FORECAST

3.1 Federal System Resource Forecast

3.1.1 Overview

BPA markets power and provides transmission services to serve the firm electric load needs of its customers. BPA does not own generating resources; rather, BPA markets power from federal and specific non-federal generating resources to meet BPA's federal load obligations. In addition, BPA purchases power to serve firm requirements load through contracts that add to the federal system resource capability. These resources and contract purchases are collectively called "federal system resources." Federal system resources are classified as hydro resources (regulated, independent, and small hydro projects); other resources (large thermal and renewable resources); contract purchases; and uncommitted purchases. Federal system resource forecasts are adjusted to take into account reserves and transmission loss estimates, which reduce the federal system resource capability.

3.1.2 Hydro Generation

The federal system hydro resources are comprised of the generation from regulated, independent, and small hydro projects. Regulated hydro projects and the process used for estimating the generation of regulated hydro projects are detailed in Section 3.1.2.1 below. Independent hydro projects and the methodology used for forecasting the generation of independent hydro projects are described in Section 3.1.2.2 below. BPA also purchases the output from two small hydro projects. The generation estimates for these small hydro projects were provided by the individual project owners and are assumed not to vary by water year; they are included in Section 3.1.2.3 below.

3.1.2.1 Regulated Hydro Generation Forecast

BPA markets the generation from the federal system hydro projects. These projects are owned and operated by either the U.S. Army Corps of Engineers (Corps) or Reclamation.

This Study uses the recent 30 years of historical streamflows from BPA's hydrosystem simulator model (HYDSIM) to estimate the energy production that can be expected from specific hydroelectric power projects in the Columbia River Basin when operating in a coordinated fashion and meeting power and non-power requirements. The hydro projects modeled in HYDSIM are called regulated hydro projects.

The hydro regulation study, which is comprised of two steps, uses individual project operating characteristics and conditions to determine the energy production expected from each individual project. Physical characteristics of each project come from the final Pacific Northwest Coordination Agreement (PNCA) data submittals from regional utilities and government agencies involved in the coordination and operation of regional hydro projects. The PNCA expired in large part on September 15, 2024, and BPA has entered into agreements with federal project owners to continue receiving plant characteristic data and physical characteristic updates. The HYDSIM model provides project-by-project monthly energy generation estimates for the regulated hydro projects for each water year modeled. HYDSIM incorporates and produces data for 14 periods per year: 10 calendar months and two periods each for April and August. April and August are modeled differently because the hydro system generation can differ significantly between the beginning and end of these months due to changes in streamflows and operating constraints. This 14-period data set is referred to as monthly data for simplicity.

1 There are two main steps of the hydro regulation studies that estimate regulated hydro
2 generation. First, the Canadian operation is determined based on the best available
3 information from the Columbia River Treaty (Treaty) planning and coordination process.
4 The Treaty calls for an Assured Operating Plan (AOP) to be completed six years prior to
5 each operating year and a Detailed Operating Plan (DOP) to be completed, if necessary, the
6 year prior to the operating year. The DOP reflects modifications to the AOP if agreed to by
7 the U.S. and Canada and is usually completed a few months prior to the beginning of the
8 operating year. These official DOP studies from the Treaty process are not available in time
9 for use in BPA's ratemaking process. Therefore, "surrogate DOP" studies described below
10 are used to represent the best available estimate for Canadian Treaty operations. The
11 surrogate DOP studies include the official AOP study assumptions plus the most recent
12 plant data and constraints available from project owners through the PNCA planning and
13 coordination process. In this study the surrogate DOP reflects the modeling assumptions
14 from the Treaty Agreement in Principle from summer 2024. Previously an AER step was
15 performed between the Canadian Treaty operation and the operational study (OPER step)
16 explained below, but this step has been modified because of the expiration of the PNCA.

17
18 Second, the OPER step is run in HYDSIM with the estimated regional firm loads developed
19 for each year of the study and with any expected operations during the rate period. In the
20 OPER step, the non-federal projects are fixed to their operations from either the final
21 Actual Energy Regulation study (AER) produced under the PNCA or fixed to the average
22 monthly elevation from the most recent seven years of actual elevation data, and the
23 federal projects operate based on expected operations as coordinated with project owners.

24
25 In summary, a surrogate DOP is used to determine the Canadian operations; non-federal
26 projects operate to fixed operations; and an OPER step is run to determine the operation of

1 the federal projects based on additional assumptions needed to reflect expected
2 operations. The end result of these steps is generally referred to as the hydro regulation
3 study. *See* Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, § 8.

4
5 For this Study, separate hydro regulation studies are performed for each year of the rate
6 period. Completing hydro regulation studies for each year allows the hydro generation
7 estimates to capture changes in the variables that characterize yearly variations in hydro
8 operations due to firm loads, firm resources, markets for hydro energy products in
9 better-than-critical water conditions, and project operating limitations and requirements.
10 These variables affect the amount and timing of energy available from the hydro system
11 and are updated annually to reflect current expectations. Sections 3.1.2.1.1-4 below
12 contain additional details on the process of producing the regulated hydro generation
13 estimates used in this Study.

14
15 Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Tables 3.1.1 for
16 energy, 3.1.2 for HLH, 3.1.3 for LLH, and 3.1.4 for one-hour capacity, Lines 1-14, list the
17 federal hydro projects included in BPA's Regulated Hydro Generation forecast. The
18 regulated hydro HLH/LLH split and one-hour capacity is based on the federal system
19 regulated hydro generation estimates produced by BPA's RiverWare-based hourly model
20 analyses, which utilize the HYDSIM hydro regulation studies as their base input. *See*
21 Section 3.1.2.1.4 below.

22
23 The net regulated hydro energy generation provides inputs for the Power and
24 Transmission Risk Study, BP-26-FS-BPA-05, and the Power Market Price Study and
25 Documentation, BP-26-FS-BPA-04. The HLH and LLH federal system regulated hydro

generation estimates are later combined with the federal system independent hydro HLH and LLH estimates, in the Power and Transmission Risk Study, BP-26-FS-BPA-05.

3.1.2.1.1 Assumptions in the HYDSIM Hydro Regulation Study

The HYDSIM studies encompass the power and non-power operating requirements expected to be in effect during the rate period, including those described in the *Biological Assessment of Effects of the Operations and Maintenance of the Federal Columbia River System on ESA-Listed Species* (2020 BA) and any modifications that arose during the development of the associated biological opinions issued by the National Oceanic and Atmospheric Administration (NOAA) Fisheries and the U.S. Fish and Wildlife Service (USFWS) and modifications that resulted from adaptive management and incorporated in annual operating documents (i.e., 2025 Water Management Plan and 2025 Fish Passage Plan and its appendices).

The aforementioned assessments are summarized in the Columbia River System Operations (CRSO) Environmental Impact Statement (EIS) Record of Decision (ROD) released in September 2020 as well as associated NEPA documents developed following the ROD. The hydropower regulation studies in this rate proposal reflect the selected alternative operational measures in this ROD and associated NEPA documents, as well as in the Litigation Stay. Operational measures include seasonal flow objectives, minimum flow levels for fish, spill for juvenile fish passage, reservoir target elevations, ramp rate restrictions, and turbine operation requirements. Measures that are physical structural modifications (*e.g.*, upgrading spill weirs) were typically excluded from the rate period based on estimated project implementation and completion timelines. Specific assumptions for the HYDSIM hydro regulation studies are detailed in the Documentation, BP-26-FS-BPA-03A, § 8.

HYDSIM uses hydro plant operating characteristics in combination with power and non-power requirements to simulate the coordinated operation of the hydro system. These operating requirements include but are not limited to: 1) storage content limits determined by rule curves; maximum project draft rates determined by each project owner as provided by the final PNCA data submittals, and 2) flow and spill objectives described in applicable NOAA Fisheries and USFWS biological opinions or other long-term agreements. Some limited deviations from the 2023 PNCA data submittals for Operating Year 2024 were necessary to accurately model anticipated operations for the rate period, such as fine-tuning the study to reflect typical in-season management decisions that are not reflected in the 2023 PNCA data submittals.

The following is an overview of the HYDSIM input updates and modeling changes that have been made since the BP-24 Power Loads and Resources Final Study (see Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, § 8, for more detail).

The Canadian project operations are based on the “surrogate 2025 DOP” with updates from the Treaty Agreement in Principle, including:

- Pre-planned Flood Risk Management (FRM) space is limited to Arrow compared to previous “surrogate DOPs” in which FRM space was included at Arrow, Mica, and Duncan projects.
- The Arrow Project Operating Criteria (APOC) no longer includes an FRM constrain to determine the Arrow outflows and end contents.
- APOC is now based on the Arrow January-July and April-July runoff volume forecast rather than the forecast for The Dalles for those periods.

- Libby operation in this step changed such that it is fixed to operations from a Corps RiverWare model representing project operations consistent with the CRSO EIS.
- Libby FRM changed in this step to be reflective of the actual operations at Libby (VarQ SRD), which led to less draft at Libby during this step.
- The OPER is based on PNCA data submittal updates for Operating Year 2024 and additional data updates as follows: Juvenile passage spill was updated to be consistent with the operations incorporated in annual operating documents (i.e., 2025 Water Management Plan and Fish Passage Plan and its appendices).
- 2020 CRSO EIS selected alternative flood controls were updated from the Corps (prior to the Treaty Agreement in Principle and do not reflect FRM changes at U.S. projects related to the Treaty Agreement in Principle).
- Irrigation withdrawals into Banks Lake were updated with data provided by Reclamation.
- In the OPER study, the regional residual hydro loads (RRHL) used in HYDSIM were updated to include current forecasts of loads, contract sales and purchases, and non-hydro generation. The RRHL are calculated by subtracting the regional firm non-hydro resources from the total regional firm load. The RRHL in the BP-26 HYDSIM study are about 1,424 aMW higher than in the BP-24 HYDSIM study when averaged over the rate period.
- The lack of market spill has been updated based on estimates from the Aurora® production cost model.

1 The assumptions used in the hydro regulation studies were the same for all three years of
2 the rate period—FY 2026, FY 2027, and FY 2028—except for the following:

- 3 • The hydro availability factors used to model anticipated unit outages
4 apply specifically to each year of the studies.
- 5 • Arrow trout spawning operation was modeled as every other year and
6 was included in FY 2026 and FY2028.
- 7 • The RRHL forecasts were calculated specifically for each study year. The
8 loads incorporated in the FY 2027 hydro regulation study are about
9 547 aMW higher than the loads projected for the FY 2026 hydro
10 regulation study and 481 aMW higher in FY 2028 than FY 2027 on an
11 annual average basis.
- 12 • The amounts of spill due to lack of market were different in the three
13 hydro regulation studies. These differences come from the Aurora model,
14 which simulates the different anticipated market conditions in FY 2026,
15 FY 2027, and FY 2028.

16 17 **3.1.2.1.2 2020 Level Modified Flows**

18 The HYDSIM model uses streamflows from historical years as the basis for estimating
19 power production of the hydroelectric system. The HYDSIM studies are developed using
20 the 2020 Level Modified Flows data set, and the presented results reflect the generation
21 from the recent 30 years of historical stream flows (1989-2018). Historical streamflows
22 are modified to reflect the changes over time due to the effects of irrigation and
23 consumptive diversion demand, return flow, and changes in contents of upstream
24 reservoirs and lakes. In HYDSIM, the unregulated flow data include updated estimates of
25 Grand Coulee irrigation pumping using data provided by Reclamation for Operating Year
26 2025.

1 The recent 30 years of streamflow data capture observed and recent hydrologic conditions
2 in the Columbia River Basin and thus provides the best available basis for forecasting near-
3 term future generation. Approximately 80 percent of BPA's federal system resource stack
4 is comprised of hydro generation, which can vary annually by about 4,000 aMW depending
5 on water conditions. HYDSIM estimates regulated hydro project generation for varying
6 water conditions and takes into account specific flows, volumes of water, elevations at
7 dams, biological opinions, and many other aspects of the hydro system.

8 9 **3.1.2.1.3 Firm Power Planning**

10 To ensure that the agency has sufficient generation to meet load, BPA bases its resource
11 planning on firm generation conditions. Firm generation is defined as the monthly
12 10th percentile (P10) generation of the federal system. The monthly P10 is a consistent
13 statistical definition of firm power across the year derived from the full distribution of
14 generation outcomes that result from the regulation of a wide range of run-off volumes and
15 shapes under current operational assumptions. The annual firm hydro generation estimate
16 is calculated from the weighted average of the monthly P10 (of the recent 30-year
17 historical generation record) of and independent hydro projects.

18 19 **3.1.2.1.4 Regulated Hydro HLH/LLH Split and One-Hour Capacity Calculations** 20 **using RiverWare**

21 The monthly energy produced by HYDSIM for each regulated hydro project is split between
22 HLH and LLH and provide inputs for RevSim in the Power and Transmission Risk Study,
23 BP-26-FS-BPA-05, Section 4.1.1.1.2. To calculate the HLH/LLH regulated hydro splits, BPA
24 completes an hourly simulation of the regulated hydro projects' operation using the
25 RiverWare computer model.

1 To simulate hourly federal “Big 10” regulated hydro generation, the RiverWare model uses
2 HYDSIM monthly project flows, monthly reservoir content, and other power and
3 non-power constraints discussed in Section 3.1.2.1 above. RiverWare studies also
4 incorporate current forecasts of monthly Regulating Reserve, Operating Reserve, Load
5 Following Reserve, Dispatchable Energy Resource Balancing Service (DERBS) Reserve, and
6 Variable Energy Resource Balancing Service (VERBS) Reserve.

7
8 The resulting RiverWare studies shape the monthly energy from HYDSIM into HLH and
9 LLH federal hydro generation for each of the recent 30-water-year conditions of the study.
10 These projections are the basis for the federal system hydro energy relationships that
11 provide the monthly HLH and LLH energy splits that are shown in the Power Loads and
12 Resources Study Documentation, BP-26-FS-BPA-03A, Tables 3.1.2 and 3.1.3, and are inputs
13 to the Power and Transmission Risk Study, BP 26-FS-BPA-05, Section 4.1.1.1.5.1. These
14 forecasts are also included in the calculation of the load-resource balance, which is
15 included in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A,
16 Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 26 (Regulated
17 Hydro - Net).

18
19 The same RiverWare studies provide the hourly peak federal hydro generation values for
20 each month of the 30-water-year conditions. Peak generation values are calculated by
21 taking the highest hour of the forecast generation shape along with the capacity being held
22 in reserve. This capacity held in reserve provides a maximum possible hourly capability,
23 by providing the maximum potential capacity available after meeting the energy shape, this
24 capacity held in reserve accounts for all uses of the hydro generations facilities capability
25 including all types of reserves. Any change of the monthly energy shape to use some or all
26 of this capacity held in reserve, on a specific hour, has a direct impact to the energy

1 available and shape of that energy for the remaining hours of the month. The monthly
2 one-hour capacity values are shown in the Power Loads and Resources Study
3 Documentation, BP-26-FS-BPA-03A, Table 3.1.4.

4 5 **3.1.2.2 Independent Hydro Generation Forecast**

6 Federal independent hydro includes hydro projects whose generation output typically
7 varies by water condition; however, the generation forecasts for these projects are not
8 modeled or regulated in the HYDSIM study. BPA markets the power from independent
9 hydro projects that are owned and operated by Reclamation, the Corps, and other project
10 owners. Federal independent hydro generation and one-hour capacity estimates are
11 provided by Reclamation and the Corps. Independent hydro generation is evaluated over
12 the same recent 30-year study period as regulated hydro projects (1989-2018). These
13 estimates also include power purchased from the Cowlitz Falls hydro project owned by
14 Lewis County Public Utility District. Power Loads and Resources Study Documentation,
15 BP-26-FS-BPA-03A, Tables 3.2.1, 3.2.2, 3.2.3, and 3.2.4, Lines 1-18, list the hydro projects
16 included in BPA's Independent Hydro Generation forecast.

17
18 The energy estimates for federal independent hydro generation used in this Study are
19 summarized in *id.*, Tables 3.2.1 for energy, 3.2.2 for HLH, 3.2.3 for LLH, and 3.2.4 for
20 one-hour capacity, Line 20. This forecast is also included in the calculation of the load-
21 resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on
22 Line 27 (Independent Hydro - Net).

23
24 The HLH/LLH splits and the one-hour capacity for the independent hydro generation
25 estimates are developed based on historical generation data. This Study provides the

1 monthly HLH and LLH generation for the federal system independent hydro resources used
2 in the Power and Transmission Risk Study, BP-26-FS-BPA-05.

3 4 **3.1.2.3 Small Hydro Generation Forecast**

5 BPA's small hydro resource purchases are from the Dworshak/Clearwater Small Hydro
6 project and Rocky Brook hydro project. Generation estimates for these small hydro
7 projects are provided by each individual project owner and are assumed not to vary by
8 water year. Small hydro resources are detailed in the Power Loads and Resources Study
9 Documentation, BP-26-FS-BPA-03A, Tables 3.3.1 for energy, 3.3.2 for HLH, 3.3.3 for LLH,
10 and 3.3.4 for one-hour capacity. This forecast is also included in the calculation of the load-
11 resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 28
12 (Small Hydro – Net).

13 14 **3.1.3 Non-Hydro Renewable Generation Forecasts**

15 Non-hydro renewable generation includes the purchased output from non-federally owned
16 wind resource (the federally purchased share of the Stateline Wind project, which expires
17 in December of 2026). The generation and capacity forecasts for these resources take into
18 account historical generation values. These projects are detailed in *id.*, Tables 4.2.1 for
19 energy, 4.2.2 for HLH, 4.2.3 for LLH, and 4.2.4 for one-hour capacity. This forecast is also
20 included in the calculation of the load-resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2
21 for HLH, and 9.1.3 for LLH, on Line 29 (Non-Hydro Renewable).

22 23 **3.1.4 Thermal Generation Forecasts**

24 Thermal generation forecasts include the purchased output from non-federally owned
25 projects and project generation that is directly assigned to BPA. The only thermal resource
26 is the Columbia Generation Station project. Forecasts for this project include a two-year

1 refueling cycle. The generation forecast for Columbia Generating Station is shown in the
2 Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Tables 4.1.1 for
3 energy, 4.1.2 for HLH, 4.1.3 for LLH, and 4.1.4 for one-hour capacity. This forecast is also
4 included in the calculation of the load-resource balance, *id.*, Tables 9.1.1 for energy, 9.1.2
5 for HLH, and 9.1.3 for LLH, on Line 32 (Thermal).

6 7 **3.1.5 Contract Purchases**

8 BPA purchases or receives power under a variety of contractual arrangements to help meet
9 federal load obligations. The contracts are categorized as 1) power purchases, 2) power or
10 energy exchange purchases, 3) capacity-for-energy exchange contracts, 4) power
11 purchased or assigned to BPA under the Columbia River Treaty, and 5) transmission loss
12 returns under Slice/Block contracts. These arrangements are collectively called “contract
13 purchases.” The transmission loss returns category captures the return of Slice
14 transmission losses to the federal system by Slice customers under Slice/Block contracts.
15 BPA’s contract purchases are considered firm federal system resources that are delivered
16 to the federal system regardless of weather, water, or economic conditions.

17
18 BPA’s expected contract purchases are detailed in the documentation as follows. Power
19 purchases from delivery points outside the PNW region are termed imports, which are
20 found in *id.*, Tables 2.2.1 for energy, 2.2.2 for HLH, and 2.2.3 for LLH. Non-federal Canadian
21 Entitlement Return (CER) deliveries are found in *id.*, Tables 2.4.1 for energy, 2.4.2 for HLH,
22 and 2.4.3 for LLH. Power purchases from delivery points within the PNW region are called
23 intra-regional transfers (in) and are found in *id.*, Tables 2.3.1 for energy, 2.3.2 for HLH, and
24 2.3.3 for LLH. Slice transmission loss returns to BPA do not have their own detailed table
25 but are included in the federal system load-resource balance in the forecasts of “Contract
26 Purchases.” *See id.*, Tables 9.1.1 for energy, 9.1.2 for HLH, and 9.1.3 for LLH, on Line 35

(imports), Line 36 (intra-regional transfers (in)), Line 37 (non-federal CER), and Line 38 (Slice transmission loss return).

3.1.6 Uncommitted Purchases

Uncommitted purchases include estimates of any Tier 1 system augmentation purchases required to meet any annual deficits of the federal system to meet Tier 1 load service, Tier 2 augmentation to meet Tier 2 load service that is greater than the forecasted available federal system, and other augmentation to meet other load service obligations, including DSI and NLSL, in order for the federal system to be in load-resource balance. Calculation of augmentation purchases are discussed in Section 4.2 below.

3.1.7 Federal System Transmission Losses

Federal system transmission loss estimates are treated as generation reductions in this Study. These losses are calculated monthly and vary by water conditions. The loss factors used have several components that combine to give the estimate of losses typically associated with federal system generation: 1) step-up transformers from generation to the high-voltage transmission network, 2) high-voltage network transmission, 3) transfers to federal loads over non-federal transmission systems, and 4) step-down transformers from high-voltage transmission to low-voltage delivery. The federal system transmission loss factors used in this Study are as follows:

- Energy is 2.83 percent, October thru May; 3.04 percent, June thru August; and 2.83 percent in September.
- Capacity is 2.88 percent, October thru May; 3.09 percent, June thru August; and 2.88 percent in September.

The estimated magnitude of each loss factor component for energy and capacity is as follows:

- Step-up transformers between the federal generation and the transmission network: average losses of 0.31 percent for energy and 0.36 percent for capacity.
- High-voltage network: uses a monthly factor set by season, as shown in the table below.

October	November	December		January	February	March	April	May	June	July	August	September
76%	1.76 %	1.76 %		1.76%	1.76%	1.76%	1.76%	1.76%	1.97%	1.97%	1.97%	1.76 %

- Transfer service to federal system loads over non-federal transmission systems: average losses of 0.49 percent for energy and 0.43 percent for capacity.
- Step-down transformers: average losses of 0.27 percent for energy and 0.33 percent for capacity.

These transmission loss factor components were developed in 1992 and reaffirmed by Transmission Services in 1994, 2000, and 2011. In 2014, BPA updated the transmission loss factor for the third component—transfer service to federal loads over non-federal transmission systems. This update was first included in studies for the BP-16 rate case. In addition, BPA continues to revise high-voltage network losses, with the latest update being included in this BP-26 Final Proposal. *See* TC-26 Settlement Agreement, TC-26-A-BPA-02-AP01, Appendix 2 at 160 (Bonneville’s Open Access Transmission Tariff, Schedule 11 (Real Power Loss Calculation)). The Power and Transmission Risk Study and the Power Rates Study also use these transmission loss factors.

3.2 Regional Hydro Resources

3.2.1 Overview

This Study produces total PNW regional hydro resource estimates for FY 2026 through FY 2028. Additionally, it provides the hydro resource inputs for the Aurora model, which provides forecasts used in the Power Market Price Study and Documentation, BP-26-FS-BPA-04.

3.2.2 PNW Regional Hydro Generation

PNW regional hydro resource estimates are one of the inputs to the Aurora model and are comprised of all PNW regulated, independent, and small hydro resources for FY 2026 through FY 2028. Regulated hydro generation estimates for this study are developed for each of the water years from 1989 through 2018 using the HYDSIM study described in Section 3.1.2.1, above. Independent hydro generation estimates are provided by the project owners for the same water years. See Section 3.1.2.2, above. Small hydro generation estimates are provided by the project owners and are assumed not to vary by water year. Small hydro projects are described in Section 3.1.2.3, above.

The total regional regulated, independent, and small hydro energy is summarized for each of the 30 water years for FY 2026-2028 in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Section 5.

3.3 4(h)(10)(C) Credits

3.3.1 Overview

The Northwest Power Act directs BPA to mitigate impacts on, and protect and enhance fish and wildlife affected by the development and operation of federal hydroelectric projects in the Columbia River Basin and its tributaries in a manner consistent with the Fish and

1 Wildlife Program, the Power Plan developed by the NPCC, and with other purposes of the
2 Northwest Power Act. 16 U.S.C. § 839b(h)(10)(A).

3
4 BPA's expenditures to protect and enhance fish and wildlife and mitigate impacts must be
5 properly accounted for and allocated among the various purposes of the hydroelectric
6 projects. This is necessary for compliance with Section 4(h)(10)(C) of the Northwest
7 Power Act, 16 U.S.C. § 839b(h)(10)(C), which requires BPA to recoup the portion of its fish
8 and wildlife mitigation expenditures that address impacts of non-power purposes by taking
9 "4(h)(10)(C) credits" against BPA's annual payments to the U.S. Treasury. These credits
10 ensure that when BPA funds mitigation addressing impacts caused by both power and non-
11 power project purposes, BPA's ratepayers ultimately bear the costs associated with
12 mitigating the power impact only and not the non-power purposes. *See* 16 U.S.C.
13 § 839b(h)(8)(B).

14
15 The non-power purposes of the hydroelectric projects include flood control, irrigation,
16 recreation, and navigation. The percentage of costs attributable to non-power purposes is
17 22.3 percent. This percentage is the systemwide average of cost allocations for non-power
18 purposes of the FCRPS provided by the Reclamation and the Corps for their hydropower
19 projects.

20
21 One type of expenditure that factors into 4(h)(10)(C) credits is BPA's purchase of
22 replacement power at times when the hydro system is operated to benefit fish and wildlife,
23 preventing BPA from generating enough hydroelectric power to meet its obligations.
24 These power purchases are part of the calculation of 4(h)(10)(C) credits in the Power and
25 Transmission Risk Study, BP-26-FS-BPA-05, § 4.1.1.1.5.6. The operations to benefit fish
26 and wildlife are described in this Study in Section 3.1.2.1.1.

3.3.2 Forecast of Power Purchases Eligible for 4(h)(10)(C) Credits

The power purchases eligible for 4(h)(10)(C) credits are estimated by comparing power purchase estimates between two HYDSIM hydro regulation studies. The first hydro regulation study, termed the “with-fish” study, models hydro system operations using current requirements for fish mitigation and wildlife enhancement under 30 historical water year conditions (October, 1988, through September, 2018). The second hydro regulation study, called the “no-fish” study, models the hydro system operation assuming no operational changes were made to benefit fish and wildlife using the same 30 historical water year conditions.

BPA estimates and compares the power purchases required to meet a specific firm load (described below) under the with-fish study and the power purchases required to meet the same firm load under the no-fish study. The 4(h)(10)(C) credits do not pertain to the entire generation difference between the with-fish study and the no-fish study; instead, the credits pertain to only a portion of the additional power purchases in the with-fish study. BPA receives 4(h)(10)(C) credits for the non-power portion (22.3 percent) of the additional power purchases it must make in the with-fish study relative to the no-fish study.

The specific firm load, called the Firm Energy Load Carrying Capability (FELCC), used in the calculation of 4(h)(10)(C) credits was part of the original negotiated arrangement between the Department of Energy and the U.S. Treasury specifying how BPA would claim the credits. A fundamental principle of this arrangement for claiming 4(h)(10)(C) credits is that the calculation must not be affected by BPA’s marketing decisions. To separate the credit calculation from BPA marketing decisions, 4(h)(10)(C) credits are calculated using the load that could have been served with certainty while drafting the system from full to

empty without fish operations under the worst energy-producing water conditions. This FELCC is the amount of firm energy that BPA would have been entitled to sell without fish operations and is used as the firm load in the 4(h)(10)(C) power purchases analysis.

The differences between the federal FELCC and federal generation in the with-fish study determine the power purchases under the with-fish study. Similarly, the differences between the federal FELCC and federal generation in the no-fish study determine the power purchases under the no-fish study. The instances where power purchases are greater in the with-fish study compared to the no-fish study result in power purchases eligible for 4(h)(10)(C) credits. Alternatively, when power purchases are less in the with-fish study than in the no-fish study, the difference constitutes a negative 4(h)(10)(C) credit.

The differences in energy purchase amounts between the with-fish and no-fish hydro studies are calculated for each period and water condition used for planning. The differences are shown for the rate period in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Tables 6.1.1, 6.1.2, and 6.1.3. These power purchases are used as inputs to the Power and Transmission Risk Study where, combined with Aurora market price estimates, they are used to calculate the 4(h)(10)(C) credits for power purchases. The non-power portion (22.3 percent) of the average expense for these purchases is used as the forecast of 4(h)(10)(C) credits for federal hydro system fish operations.

3.4 Use of Tier 1 System Firm Critical Output Calculation

The forecast Tier 1 System Firm Critical Output (T1SFCO) used in the ratemaking process was calculated for the FY 2026–2028 rate period in the BP-26 RHW process. Power

1 Rates Study, BP-26-FS-BPA-01, § 1.4.2. The T1SFCO adds forecasts of hydro generation,
2 thermal generation, and contract purchases together, and subtracts specified system
3 obligations as shown in Tables 3.1-3.4 in the TRM, BP-12-A-03. RHWM Tier 1 System
4 Capability is the sum of the T1SFCO and RHWM Augmentation. TRM, BP-12-A-03, § 3.1.
5 The BP-26 RHWM process rescaled the CHWMs to this RHWM Tier 1 system capability to
6 arrive at individual customers' RHWM values for the FY 2026–2028 rate period.

7
8 Supporting tables for the T1SFCO used in this Study for the calculation of the Tier 1 System
9 output are provided in the Power Loads and Resources Study Documentation, BP-26-FS-
10 BPA-03A, Section 7. T1SFCO is 7,033.278 aMW when averaged over the three-year rate
11 period, FY 2026–2028. *Id.*, Table 7.1.1. RHWM Augmentation is 76.275 aMW, and RHWM
12 Tier 1 system capability is 7,109.552 aMW over the three-year rate period, FY 2026-2028.
13 The BP-26 RHWM process calculated an adjusted Slice Output of 11.745 percent of the
14 RHWM Tier 1 system capability.

4. FEDERAL SYSTEM LOAD-RESOURCE BALANCE

4.1 Overview

For BPA to plan operations and set power rates, the federal system must be in load and resource balance; that is, BPA must produce an annual forecast showing that it has enough resources available to meet its forecast firm loads under firm generation conditions characterized by the monthly P10. The load-resource balance is composed of the monthly energy amounts of BPA's resources, which include hydro, non-hydro, and contract purchases, less BPA's load obligations, which are comprised of BPA's power sales contract obligations and other contract obligations.

4.2 Firm Load-Resource Balance

To determine whether the federal system is in load-resource balance, the forecast amount of BPA's annual firm energy resources under the monthly P10 conditions is estimated and compared to BPA's total firm energy loads. If BPA's expected firm energy resources are equal to BPA's total expected load obligations on an annual basis, then BPA is considered to be in load-resource balance. If the load-resource balance is not zero, BPA calculates adjustments to its loads or resources to maintain BPA in load-resource balance.

If BPA's annual firm energy resources are estimated to be greater than BPA's forecasted firm load obligations, BPA is considered to be annual firm energy surplus. If surplus, BPA would calculate the amount of surplus sales needed to increase load obligations to keep the federal system in load-resource balance: first by serving Tier 2 loads, then by serving any other obligations, and finally identifying firm surplus sales if still surplus after serving all of BPA's load obligations. Conversely, if BPA's annual firm energy resources are estimated to be lower than BPA's forecasted load obligations, BPA is considered to be in annual firm energy deficit. If deficit, BPA would calculate the amount of system augmentation

purchases (or additional resources) needed to return the federal system to load-resource balance. If deficit, BPA calculates the amount of system augmentation needed to first meet Tier 1 loads (defined as Tier 1 system augmentation), then to meet Tier 2 loads (defined as Tier 2 system augmentation), and finally to meet other loads (defined as other augmentation), in order to return the federal system to load-resource balance. BPA calculates each augmentation type separately so that it can allocate augmentation costs to the appropriate rates.

Annual firm surplus sales and system augmentation purchases may not fully balance monthly federal system HLH or LLH energy surpluses or deficits. Purchases made to meet individual monthly HLH or LLH energy deficits are called balancing purchases and are presented in the Power and Transmission Risk Study Documentation, BP-26-FS-BPA-05A.

4.3 Firm Federal System Energy Load-Resource Balance

Table 2 in this Study shows a summary of the federal system annual energy load-resource balance for FY 2026-2028. Under monthly weighted P10 firm conditions, the federal system is expected to be in firm energy load-resource balance for each year of the rate period, with no forecasted firm surplus sales. Table 2, Line 7. The individual components that make up the federal system annual energy load-resource balance for FY 2026-2028 are shown in Table 3 of this Study and presented monthly in the Power Loads and Resources Study Documentation, BP-26-FS-BPA-03A, Tables 9.1.1 (energy), 9.1.2 (HLH), and 9.1.3 (LLH).

4.4 Federal System 30-Water-Year Load-Resource Balance

To determine the load-resource balance for the federal system under each of the 30 historical water years 1989 through 2018, the forecast amount of resources for each year is

1 estimated and compared to loads. The 30 water year monthly federal system
2 surpluses/deficits for FY 2026 through FY 2028 are found in the Power Loads and
3 Resources Study Documentation, BP-26-FS-BPA-03A, Tables 10.1.1 for energy, 10.1.2 for
4 HLH, and 10.1.3 for LLH. These are used by RevSim in the calculation of secondary energy
5 revenues. *See* Power and Transmission Risk Study, BP-26-FS-BPA-05, § 3.1.2.1.

This page intentionally left blank.

SUMMARY TABLES

This page intentionally left blank.

Table 1
Priority Firm Power Load Obligations—Forecast By Product
Annual Energy in aMW

(Sums may not be exact due to rounding)

	A	B	C
	FY 2026	FY 2027	FY 2028
Preference Customer Load Obligations			
1. Load-Following Customers <i>(Includes federal agencies and does not include AHWM loads not served by BPA)</i>	4,937	4,956	4,972
2. Block	561	575	589
3. Slice/Block	1,444	1,441	1,438
4. Tier 2 Load <i>(AHWM loads placed on BPA)</i>	534	579	619
5. Total Preference Load Obligations <i>(sum of Lines 1 through 4)</i>	7,476	7,551	7,618

Table 2
Loads and Resources—Federal System Summary
Annual Energy in aMW *(Sums may not be exact due to rounding)*

	A	B	C
	FY 2026	FY 2027	FY 2028
Firm Obligations			
1. Load Following	4,937	4,956	4,972
2. Tier 1 Block	561	575	589
3. Slice	1,444	1,441	1,438
4. Direct Service Industries	11	11	11
5. Contract Deliveries <i>(not including Firm Surplus Sale)</i>	328	328	328
6. Tier 2 Load Service <i>(AHWM loads served by BPA, includes Resource Remarketing)</i>	534	579	619
7. Firm Surplus Sale	0	0	0
8. NR Obligation	7	19	26
9. Total Net Obligations <i>(sum of Lines 1 through 7)</i>	7,822	7,909	7,983
Net Resources			
10. Net Hydro Resources	6,603	6,618	6,622
11. Non-Hydro Renewables	33	17	0
12. Thermal	1,116	994	1,116
13. Contract Purchases <i>(not incl Augmentation)</i>	165	165	165
14. Tier 1 Augmentation Purchases	0	0	0
15. Tier 2 Augmentation Purchases	140	342	301
16. Other Augmentation Purchases	18	31	38
17. Federal System Transmission Losses	-254	-257	-259
18. Net Total Resources <i>(sum of lines 9 through 15)</i>	7,822	7,909	7,983
Surplus/Deficit			
19. Firm Surplus/Deficit <i>(Line 16 – Line 8)</i>	0	0	0

1
2
3

Table 3
Loads and Resources—Federal System Components
Annual Energy in aMW

(Sums may not be exact due to rounding)

	A	B	C
	FY 2026	FY 2027	FY 2028
Firm Obligations			
1. Load Following Total	4,937	4,956	4,972
2. Preference Customers	4,611	4,627	4,638
3. Federal Agencies	135	137	138
4. Reclamation Obligation	192	192	196
5. Federal Diversity	0	0	0
6. Tier 1 Block Total	561	575	589
7. Tier 1 Block Obligation	561	575	589
8. Slice Total	1,444	1,444	1,438
9. Slice Block	604	615	599
10. Slice Output from Tier 1 System	840	826	839
11. Direct Service Industries Total	11	11	11
12. DSI Obligation	11	11	11
13. Contract Deliveries Total	328	328	328
14. Exports	317	318	318
15. Intra-Regional Transfers (Out)	11	11	11
16. Tier 2 Load Service Total	534	579	619
17. Preference Customers	518	562	600
18. Federal Agencies	21	22	23
19. Resource Remarketing	-5	-4	-4
20. Uncommitted Sales Total	0	0	0
21. Firm Surplus	0	0	0
22. NR Obligation	0.7	20	25
23. NR Rate Load	0.7	20	25
24. Total Firm Obligations <i>(sum of Lines 1+6+8+11+13+16+20+22)</i>	7,816	7,910	7,983

Table 3 (continued)
Loads and Resources—Federal System Components
Annual Energy in aMW
(Sums may not be exact due to rounding)

	A	B	
	FY 2026	FY 2027	FY2028
Net Resources			
25. Hydro Resources Total	6,603	6,618	6,622
26. Regulated Hydro – Net	6,336	6,345	6,354
27. Independent Hydro – Net	264	270	265
28. Small Hydro – Net	3	3	3
29. Non-Hydro Renewables Total	33	17	0
30. Wind	33	17	0
31. Other	0	0	0
32. Thermal Total	1,116	994	1,116
33. Nuclear	1,116	994	1,116
34. Contract Purchases Total	165	165	165
35. Imports	1	1	1
36. Intra-Regional Transfers (In)	63	63	63
37. Non-Federal CER	84	84	84
38. Slice Transmission Loss Return	17	17	17
39. Uncommitted Purchases Total	132	353	318
40. Tier 1 Augmentation	0	0	0
41. Tier 2 Augmentation	120	322	281
42. Other Augmentation	12	31	38
43. Reserves & Losses Total	-234	-237	-239
44. Operating Reserves	0	0	0
45. Balancing Reserves	0	0	0
46. Transmission Losses	-234	-237	-239
47. Total Net Resources <i>(sum of Lines 25+29+32+34+39+43)</i>	7,816	7,910	7,983
48. Total Firm Surplus/Deficit <i>(Line 47 – Line 24)</i>	0	0	0

This page intentionally left blank.

