

B O N N E V I L L E
P O W E R A D M I N I S T R A T I O N



**Available Transfer Capability
Implementation Document
(MOD-001-1a)**

**Bonneville Power Administration
Transmission Services**

Effective Date: May 03, 2022

Contents

I. Purpose	1
II. Definitions	1
III. Overview	2
Methodologies Selected	2
MOD-029-2a	2
MOD-008-1	2
Methodologies Not Applicable to BPA	2
ATC Calculations	2
ATC Calculation Periods	2
Frequency of ATC Recalculation.....	2
Limiting Assumptions.....	3
IV. Allocation Processes	3
V. Outages	4
Outage Planning	4
Outage Criteria for TTC Calculations	4
VI. Priorities Used to Set TTC	4
VII. Rated System Path Methodology for BPA’s Paths.....	5
BPA’s Paths	6
Calculating TTC	10
Data and Assumptions.....	10
Process to Determine TTC.....	11
Calculating Firm Transmission Service for Paths	13
Calculating Firm Existing Transmission Commitments (ETC _F)	13
Determining base ETC for Flow-Based Paths.....	15
Calculating Interim ETC _F for Flow-based Paths.....	19
Calculating Firm Available Transfer Capability (ATC _F)	21
Calculating Non-Firm Transmission Service for BPA’s Paths	24
Calculating Non-Firm Existing Transmission Commitments (ETC _{NF})	24
Calculating Non-Firm Available Transfer Capability (ATC _{NF})	25
Adjustments to Flow-based Path ATC Values	31
VIII. Data Sources and Recipients.....	31
IX. Responding to Data Requests.....	32
X. ATCID Revisions.....	33

3 I. Purpose

4 This Available Transfer Capability Implementation Document (ATCID) addresses all of the
5 requirements of North American Electric Reliability Corporation (NERC) Reliability Standard
6 MOD-001-1a (Available Transmission System Capability). This ATCID is specifically required by
7 MOD-001-1a, R3 and its sub-requirements. This ATCID also outlines BPA's Postback
8 Methodology as required by North American Energy Standards Board (NAESB) Wholesale
9 Electric Quadrant business practice standards.

10 This ATCID only applies to ATC calculations through month 13.

11 II. Definitions

12 All capitalized terms used in this ATCID are either contained in NERC's Glossary of Terms,
13 NAESB WEQ-000, or are defined in this ATCID.

14 Defined terms specific to BPA include:

- 15 • **Federal Columbia River Power System (FCRPS):** The Transmission System
16 constructed and operated by BPA and the 31 federally-constructed hydroelectric dams¹
17 on the Columbia and Snake Rivers, and the Columbia Generating Station nuclear plant.
18 Each entity is separately managed and financed, but the facilities are operated as an
19 integrated power System.
- 20 • **Federal Columbia River Transmission System (FCRTS):** The FCRTS is comprised of
21 BPA's main grid network Facilities (Network), Interconnections with other
22 Transmission Systems (External Interconnections²), Interties,³ delivery Facilities,
23 subgrid Facilities, and generation Interconnection Facilities within the Pacific
24 Northwest region and with western Canada and California.
- 25 • **Long-Term Reservation:** a confirmed reservation that has duration greater than or
26 equal to 365 days
- 27 • **Short-Term Reservation:** a confirmed reservation that has duration less than 365
28 days

¹ Albeni Falls, Anderson Ranch, Big Cliff, Black Canyon, Boise River Diversion, Bonneville, Chandler, Chief Joseph, Cougar, Detroit, Dexter, Dworshak, Foster, Grand Coulee, Green Peter, Green Springs, Hills Creek, Hungry Horse, Ice Harbor, John Day, Libby, Little Goose, Lookout Point, Lost Creek, Lower Granite, Lower Monumental, McNary, Minidoka, Palisades, Roza and The Dalles

² Northern Intertie, Reno-Alturas Transmission System, West of Hatwai, West of Garrison and LaGrande paths.

³ California-Oregon AC Intertie, Pacific DC Intertie, and Montana Intertie.

29 III. Overview

30 BPA owns and provides Transmission Service over the FCRTS. BPA is registered with NERC as a
31 Transmission Operator (TOP) and Transmission Service Provider (TSP), among other
32 registrations.

33 Methodologies Selected

34 MOD-029-2a

35 BPA has elected to use the Rated System Path Methodology (MOD-029-2a) to calculate
36 Available Transfer Capability (ATC) for its paths. The description of how BPA implements
37 this methodology for these paths is included in this ATCID. (MOD-001 R1)

38 MOD-008-1

39 BPA maintains Transmission Reliability Margin (TRM) as described in NERC Standard MOD-
40 008-1 for its Northern Intertie, West of Garrison E>W and Satsop Injection paths. The
41 description of how BPA implements TRM can be found in BPA's TRM Implementation
42 Document (TRMID), found on BPA's website. BPA does not maintain TRM for any other
43 paths.

44 Methodologies Not Applicable to BPA

45 BPA does not use the Area Interchange Methodology (MOD-028-2), the Flowgate
46 Methodology (MOD-030-2), or a Capacity Benefit Margin (MOD-004-1). Therefore, these
47 standards are not applicable to BPA.

48 ATC Calculations

49 ATC Calculation Periods

50 BPA calculates ATC values using the Rated System Path Methodology for the following time
51 periods: (MOD-001 R2)

- 52 • Hourly values for up to 168 hours. The next hour may be calculated in subhourly
53 intervals, with the most limiting subhourly ATC value being the hourly value. (MOD-001
54 R2.1)
- 55 • Daily values for day 3 through day 90. For days 3 to 7 (up to hour 168), the daily ATC
56 value is the most limiting hourly ATC value for that day. (MOD-001 R2.2)
- 57 • Monthly values for month 2 through month 13. For months 2 and 3 (up to day 90), the
58 monthly ATC value is the most limiting daily ATC value for that month. (MOD-001 R2.3)

59 Frequency of ATC Recalculation

60 BPA recalculates ATC on the following frequency, even if the calculated values
61 identified in the ATC equation are unchanged: (MOD-001 R8)

- 62 • Hourly, at least once per hour. (MOD-001 R8.1)
- 63 • Daily, at least once per day. (MOD-001 R8.2)

64 • Monthly, at least once per day. (MOD-001 R8.3)

65 BPA may recalculate ATC values more frequently due to changes in Total Transfer
66 Capability (TTC), Power Transfer Distribution Factors (PTDFs), system issues or as deemed
67 necessary.

68 **Limiting Assumptions**

69 BPA studies assumptions of various System conditions to develop TTCs for its paths for the
70 planning of operations time frame. The governing TTCs for each time frame are
71 established from these planning of operations studies, based on the time period being
72 calculated and the reason for the change in TTC. BPA uses these TTCs in its ATC
73 calculations. There are no additional TTC studies conducted to establish the path TTCs
74 used BPA's ATC calculations. Therefore when determining the TTC, BPA studies
75 assumptions that are no more limiting than those used in its planning of operations for the
76 corresponding time period, when such planning of operations has been performed for that
77 time period. (MOD-001 R6)

78 When calculating ATC, BPA uses the TTCs determined in its planning of operations TTC
79 studies. There are no additional TTC studies conducted to establish the path TTCs used in
80 BPA's ATC calculations. For flow-based paths, BPA calculates Existing Transmission
81 Commitments (ETC) by summing base ETC from power flow studies with interim ETC from
82 PTDFs. BPA uses the most recent System condition information to re-calculate its hourly,
83 daily and monthly PTDFs in the planning of operations time frame. The ETCs used in
84 BPA's ATC calculations are re-calculated with these updated PTDFs in each time frame.
85 There are no additional ETC studies, beyond the base ETC studies and the PTDF
86 calculations, performed during the planning of operations time frame. Therefore, BPA
87 does not use more limiting assumptions when calculating ATC in its planning of operations
88 time frame. (MOD-001 R7)

89 **IV. Allocation Processes**

90 BPA allocates transfer capability among multiple owners or users of its 1:1 and flow-based
91 paths.

92 **Allocating TTC:**

93 For paths where allocation agreements exist, BPA allocates TTC according to the
94 contractual rights of the various owners as defined in the agreements.

95 Allocation agreements do not exist for three of BPA's flow-based paths that have multiple
96 owners: South of Allston S>N, Columbia Injection N>S and Wanapum Injection N>S. BPA
97 uses the allocations found in the South of Allston N>S agreement to allocate TTC across
98 South of Allston S>N. For Columbia Injection N>S and Wanapum Injection N>S, BPA
99 determines its share of TTC based on BPA-owned transmission lines that make up these
100 paths when all lines are in service. During outage conditions, individual allocations exist
101 for the loss of each transmission line in the line definitions for these paths.

102

103 **Allocating base ETC:**

104 BPA also allocates its base ETC among some of its shared flow-based paths. To allocate
105 base ETC for South of Allston N>S and S>N, BPA uses the contractual rights defined in the
106 South of Allston allocation agreement. To allocate base ETC for the Columbia Injection
107 N>S and Wanapum Injection N>S paths, BPA only models BPA's lines in the base ETC cases
108 for these paths. BPA does not allocate base ETC across any other shared flow-based
109 paths.

110 BPA calculates Power Transfer Distribution Factors based on the entire path definition of all
111 paths.

112 At this time BPA does not allocate transfer capabilities among multiple lines or sub-paths
113 within a larger path or between TSPs to address forward-looking congestion management and
114 seams coordination. (MOD-001 R3.5)

115 **V. Outages**

116 Outages from all TSPs that are internal or adjacent to BPA's Balancing Authority Area (BAA)
117 can be mapped to the WECC base cases. (MOD-001 R3.6.3)

118 **Outage Planning**

119 Outage plans and the policy are posted to the Outage Plans website at: [Outage Coordination -
120 Bonneville Power Administration \(bpa.gov\)](http://www.bpa.gov/OutageCoordination)

121 **Outage Criteria for TTC Calculations**

122 BPA incorporates outages into the TTC calculations after they have been studied by BPA or
123 provided to BPA by another TOP. Generally, BPA studies outages 10 to 16 days prior to the
124 outage start date.

125 The duration of an outage is not a criteria by which BPA determines which outages to
126 incorporate in its daily and monthly TTC calculations. The most conservative hourly TTC
127 calculated for a given outage or combination of outages becomes the governing TTC for the
128 daily calculation period. Likewise, the most conservative daily TTC for a given outage or
129 combination of outages becomes the governing TTC for the monthly calculation period.
130 (MOD-001 R3.6.1) (MOD-001 R.3.6.2)

131 **VI. Priorities Used to Set TTC**

132 BPA may update assumptions and calculate new TTCs when changes to System conditions will
133 significantly impact those limits and may use those updated assumptions to determine new
134 TTC values. The following hierarchy of priorities categorizes the TTC values based on the
135 time period being calculated and the reason for the change. This prioritization may then be
136 used to revise the path TTC for a given time period if BPA determines that more recent
137 assumptions to calculate TTC values better reflect updated System information:

- 138 • **Real-time limit (highest priority):** The “Real-time limit” priority governs when BPA
139 updates the assumptions of System conditions to calculate TTCs during the Real-time
140 horizon. A change to the TTC calculation with the Real-time priority governs all other
141 priorities. For example, if BPA receives an update that a scheduled outage will be
142 extended by two hours early in the Real-time day, BPA may update the assumptions
143 for the TTC calculation accordingly for the additional two hours and may use those
144 same updated assumptions to update the TTC. If there are multiple real-time updates
145 to assumptions for TTC calculations, the most recent TTC calculated governs.
- 146 • **Scheduling limit:** The “scheduling limit” priority may be used occasionally when the
147 assumptions for the TTC are not governing or an actual scheduling limit has been
148 imposed. If there is more than one scheduling limit, the lowest scheduling limit
149 governs until a Real-time limit TTC is submitted.
- 150 • **Pre-schedule forecast:** The “pre-schedule forecast” TTC priority may be used for a
151 path if the assumptions for the TTC calculations are updated for the pre-schedule
152 period. For example, for TTCs calculated for flow-based paths that are derived using
153 nomograms, if the assumptions are re-evaluated just prior to the pre-schedule day to
154 incorporate updated data inputs, the TTC may be updated. The pre-schedule forecast
155 TTC governs over the ‘studied’ priority.
- 156 • **Studied:** The “studied” priority is used when there are outages where a study report
157 has been issued, including those provided by other TOPs. For example, if a study
158 report is issued evaluating assumptions for line outage system conditions, the TTCs in
159 that report govern over any lower-priority TTCs for the duration of the line outage
160 conditions.
- 161 • **Estimated known limit:** The “estimated known limit” priority is used to establish
162 unstudied TTCs or to define seasonal path TTCs that govern over “short-term
163 seasonal” or “Path Rating” priorities.
- 164 • **Short-term seasonal:** The “short-term seasonal” priority is used for TTCs issued for
165 seasonal Path Ratings. As these Ratings may be higher at certain times during the
166 year, the short-term seasonal priority governs over the Path Rating priority. For
167 example, if the longer-term Path Rating for a path is 7800 MW, but seasonally this
168 Rating increases to 8000 MW, the short-term seasonal Rating of 8000 MW governs and
169 is used to set the TTC during the season to which it applies.
- 170 • **Path Rating:** The “Path Rating” priority is used to set base TTCs using either the
171 Rating of the paths, TTCs studied using normal conditions, TTCs calculated for the
172 planning horizon, or all of the above. The lowest value resulting from the above
173 calculations governs for the given time period and is used to set the TTC. For
174 example, if under normal conditions the TTC for a path is 4410 MW, but the TTC
175 calculated for the planning horizon is 4100 MW, the lower TTC of 4100 MW governs and
176 is used to set the TTC for the path.
- 177 • **Informational limit (lowest priority):** The “informational limit” is used while
178 establishing the initial setup of paths within the scheduling and reservation system.
179 The informational limit is equal to the initial Path Rating of the path.

180 VII. Rated System Path Methodology for BPA’s Paths

181 This section describes how BPA implements the Rated System Path methodology for its paths.
182 It addresses all of the requirements in MOD-029-2a.

183 **BPA's Paths**

184 The following tables list BPA's paths. BPA has a combination of 1:1 and flow-based paths, and
 185 uses MOD-029-2a to calculate ATC for both.

186 **Table 1, BPA's 1:1 Paths**

1:1 Path Name	Direction
Northern Intertie Total On Oasis: NI_TOTL_N>S	(N>S)
Northern Intertie Total On OASIS: NI_TOTL_S>N	(S>N)
Montana-Northwest West of Garrison On OASIS: WOGARR_E>W	(E>W)
Montana-Northwest West of Garrison On OASIS: WOGARR_W>E	(W>E)
La Grande On OASIS: LAGR_W>E	(W>E)
La Grande On OASIS: LAGR_E>W	(E>W)
Montana Intertie On OASIS: MI_E>W	(E>W)
Reno-Alturas NW Sierra On OASIS: RATS_N>S	(N>S)
Reno-Alturas NW Sierra On OASIS: RATS_S>N	(S>N)
California-Oregon AC Intertie (COI) On OASIS: AC_N>S	(N>S)
California-Oregon AC Intertie (COI) On OASIS: AC_S>N	(S>N)
Pacific DC Intertie On OASIS: DC_S>N	(S>N)
Pacific DC Intertie On OASIS: DC_N>S	(N>S)
Rock Creek On OASIS: ROCKCK_GEN	Gen
John Day Wind On OASIS: JDWIND_GEN	Gen
Satsop Injection On OASIS: SATSOP_GEN	Gen

Table 2, BPA's Flow-Based Paths

Flow-based Path Name	Direction	Transmission Line Components	Case used for base ETC calculation
North of Hanford On OASIS: NOHANF	(N>S)	Vantage-Hanford #1 500-kV; Grand Coulee-Hanford #1 500-kV; and Shultz-Wautoma #1 500-kV	Heavy load case
North of Hanford On OASIS: NOHANF	(S>N)	Hanford-Vantage #1 500-kV; Hanford-Grand Coulee #1 500-kV; and Wautoma-Shultz #1 500-kV	Heavy load case
South of Allston On OASIS: SOALSN	(N>S)	BPA-Owned Transmission Lines: Allston-Keeler 500-kV; Lexington-Ross 230-kV; and Allston-St. Helens 115-kV; Portland General Electric -Owned Transmission Lines: Trojan-St. Marys 230-kV; and Trojan-Harborton 230-kV; PacifiCorp-Owned Transmission Lines: Merwin-St. Johns 115-kV; Astoria-Seaside 115-kV; and Clatsop 230/115-kV	Heavy load case
South of Allston On OASIS: SOALSN	(S>N)	BPA-Owned Transmission Lines: Keeler-Allston 500-kV; Ross-Lexington 230-kV; and St. Helens-Allston 115-kV; Portland General Electric -Owned Transmission Lines: St. Marys-Trojan 230-kV; and Harborton-Trojan 230-kV; PacifiCorp-Owned Transmission Lines: St. Johns-Merwin 115-kV; Seaside-Astoria 115-kV; and Clatsop 230/115-kV	Heavy load case
Raver-Paul On OASIS: RAVR_PAUL	(N>S)	Raver-Paul #1 500-kV When Raver-Paul #1 500-kV is out of service, the following lines are monitored: Raver-Paul #1 500-kV; St. Clair-South Tacoma #1 230-kV; Chehalis-Covington #1 230-kV; Frederickson-St. Clair 115-kV; and Electron Heights-Blumaer 115-kV	Heavy load case

Flow-based Path Name	Direction	Transmission Line Components	Case used for base ETC calculation
Cross Cascades North On OASIS: C-CASC_N	(E>W)	BPA-Owned Transmission Lines: Schultz-Raver #1, #3, & #4 500-kV; Schultz-Echo Lake #1 500-kV; Chief Joseph-Monroe #1 500-kV; Chief Joseph-Snohomish #3 & #4 345-kV; Rocky Reach-Maple Valley #1 345-kV; Grand Coulee-Olympia #1 287-kV; and Bettas Road-Covington #1 230-kV; Puget Sound Energy-Owned Transmission Line: Rocky Reach-Cascade 230-kV	Heavy load case
Cross Cascades South On OASIS: C-CACS_S	(E>W)	BPA-Owned Transmission Lines: Big-Eddy-Ostrander #1 500-kV; Ashe-Marion #2 500-kV; Buckley-Marion #1 500-kV; Knight-Ostrander #1 500-kV; John Day-Marion #1 500-kV; McNary-Ross #1 345-kV; Big Eddy-Chemawa #1 230-kV; Big Eddy-McLoughlin #1 & #2 230-kV; Midway-North Bonneville #1 230-kV; Jones Canyon-Santiam #1 230-kV; and Big Eddy-Troutdale #1 230-kV PGE-Owned Transmission Line: Round Butte-Bethel 230-kV	Heavy load case
West of McNary On OASIS: WOMCNY	(E>W)	Coyote Springs-Slatt #1 500-kV; McNary-Ross #1 345-kV; Harvalum-Big Eddy #1 230-kV; Jones Canyon-Santiam #1 230-kV; and McNary-John Day #2 500-kV	Heavy load case
West of Slatt On OASIS: WOSLATT	(E>W)	Slatt-Buckley #1 500-kV; and Slatt-John Day #1 500-kV	Heavy load case
West of John Day On OASIS: WOJD	(E>W)	John Day-Big Eddy #1 500-kV; John Day-Big Eddy #2 500-kV; and John Day-Marion #1 500-kV	Heavy load case
South of Boundary On OASIS: SBNDRY	(N>S)	Boundary-Bell #1 230-kV; Boundary-Bell #3 230-kV; Boundary-Usk #1 230-kV; and Boundary 230/115-kV Transformer #1	Heavy load case

Flow-based Path Name	Direction	Transmission Line Components	Case used for base ETC calculation
Columbia Injection On OASIS: CLMBIA	(N>S)	BPA-Owned Transmission Lines: Columbia-Grand Coulee #1 230-kV; Columbia-Grand Coulee #3 230-kV; Columbia-Rocky Reach #2 230-kV; Columbia-Valhalla #1 115-kV; and Columbia-Valhalla #2 115-kV; Chelan PUD-Owned Transmission Line: Columbia-Rocky Reach #1 230-kV	Heavy load case
Wanapum Injection On OASIS: WANAPM	(N>S)	BPA-Owned Transmission Line: Vantage-Midway #1 230-kV; Grant PUD-Owned Transmission Line: Priest Rapids-Midway #3 230-kV	Heavy load case
West of Lower Monumental On OASIS: W_LOMO	(E>W)	Lower Monumental-Ashe 500-kV; Lower Monumental-Hanford 500-kV; and Lower Monumental-McNary 500-kV	Heavy load case
North of Echo Lake On OASIS: N_ECOL	(S>N)	Echo Lake-Monroe-SnoKing Tap #1 500-kV; Echo Lake-Maple Valley #1 500-kV; Echo Lake-Maple Valley #2 500-kV; and Covington-Maple Valley #2 230-kV	Heavy load case
South of Custer On OASIS: SCSTER	(N>S)	Custer-Monroe #1 500-kV; Custer-Monroe #2 500-kV; Custer-Bellingham #1 230-kV; and Custer-Murray #1 230-kV	Heavy load case
West of Hatwai On OASIS: WOH_E>W	(E>W)	Hatwai-Lower Granite #1 500-kV; Bell-Grand Coulee #6 500-kV; Bell-Grand Coulee #3 230-kV; Bell-Grand Coulee #5 230-kV; Westside-Grand Coulee #1 230-kV; Dry Creek-Talbot 230-kV; North Lewiston-Tucannon River #1 115-kV; Devils Gap-Stratford 115-kV; Lind-Warden 115-kV; Creston-Bell #1 115-kV; and Dry Gulch-Pomeroy 69-kV	Light load case

188
189

BPA will select the Rated System Path Methodology if new paths are implemented, and update the appropriate table above. (MOD-001 R1)

190 Calculating TTC

191 Data and Assumptions

192 When calculating TTC for its paths, BPA uses WECC base cases that utilize data and
193 assumptions consistent with the time period being studied. (MOD-029, R1.1) In addition to
194 BPA's TOP area, these WECC base cases model the entire Western Interconnection.
195 Hence, the WECC base cases include all TOP areas regardless if they are either contiguous
196 to BPA's TOP area or are linked to BPA's TOP area by a joint operating Agreement. (MOD-
197 029 R1.1.1.2, R1.1.1.3)

198 TOP areas contiguous with BPA's TOP area include (MOD-029 R1.1.1.2):

- 199 • Avista Corporation (AVA)
- 200 • BC Hydro (BCH)
- 201 • California Independent System Operator (CAISO)
- 202 • City of Tacoma, Department of Public Utilities, Light Division
- 203 • Eugene Water and Electric Board (EWEB)
- 204 • Idaho Power Company (IPCO)
- 205 • Los Angeles Department of Water and Power (LADWP)
- 206 • NorthWestern Energy (NWMT)
- 207 • NV Energy
- 208 • PacifiCorp (PAC)
- 209 • Pend Oreille County Public Utility District No. 1
- 210 • Portland General Electric (PGE)
- 211 • Public Utility District No. 1 of Chelan County
- 212 • Public Utility District No. 1 of Clark County
- 213 • Public Utility District No. 1 of Snohomish County
- 214 • Public Utility District No. 2 of Grant County, Washington
- 215 • PUD No. 1 of Douglas County
- 216 • Puget Sound Energy, Inc. (PSEI)
- 217 • Seattle City Light (SCL)

218 BPA uses the following data and assumptions in the WECC base cases when calculating
219 TTCs for its paths:

220 BPA models all existing System Elements in their normal operating condition for the
221 assumed initial conditions, up to the time horizon in which BPA begins modeling
222 outages. (MOD-029 R1.1.2)

223 The WECC base cases include generators and phase shifters that meet the guidelines
224 set out in the WECC Data Preparation Manual. (MOD-029 R1.1.3) (MOD-029 R1.1.4)

225 BPA uses the seasonal Load forecasts contained in the WECC base cases for each BA.
226 (MOD-029 R1.1.5)

227 Generation and Transmission Facility additions and retirements within the WECC
228 footprint are included in the WECC seasonal operating base cases for the season in
229 which they are energized/de-energized, respectively. BPA engineers modify the WECC
230 base cases to reflect the actual dates of energization/de-energization. (MOD-029
231 R1.1.6, R1.1.7)

232 The WECC base cases include Facility Ratings as provided to WECC by the Transmission
233 Owners and Generator Owners. (MOD-029 R1.2)

234 If Facility changes are made by BPA or another entity, then the base cases will be
235 updated to reflect these changes with a Mid-Season update. (MOD-029 R1.1, R1.2)

236 The approved seasonal operating base cases that include the Facility changes will not
237 be used until 0 to 16 days prior to the energization or implementation of the Facility
238 change. (MOD-029 R1.1, R1.2)

239 For periods beyond two weeks, the WECC base cases will be updated as necessary to
240 perform seasonal studies for the current or upcoming season in accordance with the
241 current BPA study processes. (MOD-029 R1.1, R1.2, R2.1)

242 For all paths, except West of Garrison and Northern Intertie South to North, BPA uses
243 the all lines in service TTC from the relevant seasonal studies when there are no
244 studied outages to set the TTC of the path for the corresponding seasonal time
245 periods.

246 For West of Garrison, for the seasons or time periods in which the seasonal studies
247 have not been completed, the most recent year's seasonal study results will be used
248 for setting the TTC for the path.

249 For Northern Intertie South to North, for the seasons or time periods in which the
250 seasonal studies have not been completed, the most recent year's seasonal study
251 results will be used for setting the TTC. BPA uses the minimum TTC from the relevant
252 seasonal studies to set the TTC of the path for periods from the next day and
253 beyond. For the Real-time horizon, when there are no studied outages, BPA uses the
254 maximum TTC from the relevant seasonal studies to set the TTC of the path.

255 BPA models Special Protection Systems (BPA uses the term Remedial Action Schemes
256 or RAS) that currently exist or are projected for implementation within the studied
257 time horizon. (MOD-029 R1.1.8)

258 The WECC base cases include all series compensation for each line at the expected
259 operating level. (MOD-029 R1.1.9)

260 BPA uses no other modeling requirements for calculating TTC in addition to those
261 specified in this document. (MOD-029 R1.1.10)

262 **Process to Determine TTC**

263 BPA adjusts generation and Load levels within the WECC power-flow base cases to
264 determine the TTC that can be simulated for each of its paths, while at the same time
265 satisfying all operations planning criteria contingencies, as follows:

266 BPA studies single and multiple contingencies that are relevant to the path being studied.
267 (MOD-029 R2.1)

268 When modeling normal conditions, BPA models all Transmission Elements in BPA’s BAA and
269 adjacent BAAs at or below 100 percent of their continuous Rating. (MOD-029 R2.1.1)

270 BPA models contingencies as per the current version of “RC West System Operating Limits
271 Methodology for the Operations Horizon” (RC West SOL Methodology) posted on RC West’s
272 website. (MOD-029 R2.1.2)

273 When modeling contingencies, BPA determines TTCs by stressing the system until flows
274 exceed emergency Facility Ratings or voltages fall outside emergency system voltage
275 limits (i.e., the post-Contingency state). If a facility does not have an emergency Facility
276 Rating, the normal Facility Rating is used. If there is no emergency system voltage limit,
277 the normal system voltage limit is used. (MOD-029 R2.1.2) By meeting the criteria in the
278 RC West SOL Methodology, uncontrolled separation should not occur. (MOD-029 R2.1.3)

279 BPA’s paths listed below are bi-directional and have studied TTCs in both the prevailing
280 and non-prevailing direction of flow. (MOD-029 R2.2)

- 281 • Northern Intertie Total
- 282 • Montana-Northwest/West of Garrison
- 283 • La Grande
- 284 • Reno-Alturas NW Sierra
- 285 • California-Oregon AC Intertie
- 286 • Pacific DC Intertie
- 287 • North of Hanford
- 288 • South of Allston

289 All of BPA’s other paths are one directional, in the prevailing direction of flow, and have
290 studied TTCs that are established for the prevailing direction of flow. If TTC values for
291 the non-prevailing direction of flow were needed for these paths, BPA would determine
292 these TTC values in accordance with the sub-requirements listed in MOD-029 R2, including
293 MOD-029 R2.2.

294 For paths where TTC varies due to simultaneous interaction with one or more other paths,
295 BPA develops a nomogram, represented either by an equation or its graphical
296 representation, describing the interaction of the paths and the resulting TTC under
297 specified conditions. BPA then calculates a value, based on that nomogram and
298 forecasted System conditions for the time period studied, to develop its TTC values for
299 the affected paths. (MOD-029 R2.4)

300 BPA or the adjacent path TOP identifies when the new or increased TTC for a path being
301 studied by BPA or the adjacent path TOP has an adverse impact on the TTC value of
302 another existing path by modeling the flow on the path being studied at its proposed new
303 TTC level, while simultaneously modeling the flow on the existing path at its TTC level. In
304 doing so, BPA or the adjacent path TOP honors the reliability criteria described above.
305 BPA or the adjacent path TOP includes the resolution of this adverse impact in its study
306 report for the path. (MOD-029 R2.5)

307 BPA has Transmission Ownership Agreements where multiple ownerships of Transmission
308 rights exist on a path. TTC for the affected paths is allocated according to contractual
309 ownership rights. (MOD-029 R2.6)

310 The ratings for BPA's paths whose ratings were established, known, and used in operation
311 since January 1, 1994, have been re-established using updated methods. BPA studies its
312 paths, with the exception of LaGrande, on a periodic basis and reconfirms the rating of
313 each path based on these studies. These ratings are then used to establish the TTC for
314 the path.

315 For the LaGrande path, BPA uses the Accepted Rating of the path as defined in the WECC
316 Path Rating Catalog. BPA's LaGrande path is part of the NW-Idaho path (WECC Path
317 14). The rating of Path 14 was reconfirmed through an updated study in 2010 when the
318 path definition had to be modified due to the addition of the Hemingway Substation by
319 PAC and Idaho Power.

320 BPA creates a study report that describes the TTC applicable to the outages during the
321 studied time period and includes the limiting Contingencies and the limiting cause for the
322 calculated TTC. The RC West SOL Methodology document defines the steps taken and
323 assumptions BPA used to determine TTC for each path. BPA creates a study report for
324 each study it performs. The study report relies on the basic assumptions included in RC
325 West SOL methodology and identifies any changes to those basic assumptions. (MOD-029
326 R2.8)

327 Information regarding TTCs is shared electronically between the appropriate BPA
328 organizations within seven calendar days of the finalization of the study report for the TTCs.
329 BPA sends a notice to all TSPs for the paths listed in Table 1 where there are multiple TSPs
330 *prior* to limitations in TTCs. (MOD-029 R4)

331 These notices are called Notices of Planned Path Limitation. Where BPA has performed a
332 study, the notice states that the TTC study report is available to TSPs for the specific path
333 within seven calendar days upon request to nercatcstandards@bpa.gov with **TTC Study**
334 **Report Request** in the subject line. Use the **TTC Study Report Request Form** found on BPA's
335 ATC Methodology website to submit the request.

336 A path for which BPA does not perform studies to determine the most current value of TTC is
337 Reno - Alturas NW Sierra (RATS). For RATS, NV Energy determines TTC. The TTC is provided
338 to BPA and BPA then sends a Notice of Planned Path Limitation. (MOD-029 R3)

339 **Calculating Firm Transmission Service for Paths**

340 **Calculating Firm Existing Transmission Commitments (ETC_F)**

341 When calculating ETC_F for all time periods for its paths, BPA uses the following algorithm as
342 specified in MOD-029 R5:

$$343 \text{ETC}_F = \text{NL}_F + \text{NITS}_F + \text{GF}_F + \text{PTP}_F + \text{ROR}_F + \text{OS}_F$$

344

345 **Where:**

346 NL_F is the firm capacity set aside to serve peak Native Load forecast commitments for the
347 time period being calculated, to include losses, and Native Load growth, not otherwise
348 included in Transmission Reliability Margin or Capacity Benefit Margin.

349 BPA does not have any NL_F , and thus sets NL_F at zero for all of its paths for all time
350 periods. All of BPA's firm Transmission obligations are captured in the $NITS_F$, PTP_F , GF_F
351 and ROR_F components of the ETC_F algorithm.

352 $NITS_F$ is the firm capacity reserved for Network Integration Transmission Service serving Load,
353 to include losses, and Load growth, not otherwise included in Transmission Reliability Margin
354 or Capacity Benefit Margin.

355 For BPA's 1:1 paths where $NITS_F$ commitments exist to serve Network Load outside BPA's
356 BAA, the firm capacity set aside for $NITS_F$ is equal to the Load forecast, which includes
357 losses and Load growth, minus generation outside BPA's BAA that is designated to serve
358 that Load. For BPA's 1:1 paths where $NITS_F$ commitments exist to serve Network Load
359 inside BPA's BAA from a forecasted or designated network resource that impacts the path,
360 the firm capacity set aside for $NITS_F$ is equal to the amount the resource is
361 forecasted/designated for.

362 For BPA's flow-based paths, BPA accounts for $NITS_F$ obligations with a combination of base
363 ETC and interim ETC calculations, as described further in this document.

364 GF_F is the firm capacity set aside for grandfathered Transmission Service and contracts for
365 energy and/or Transmission Service, where executed prior to the effective date of a
366 Transmission Service Provider's Open Access Transmission Tariff or "safe harbor tariff."

367 The amount of GF_F BPA sets aside across its 1:1 paths is based on the terms of each
368 individual contract.

369 For BPA's flow-based paths, BPA accounts for GF_F obligations with base ETC calculations,
370 as described further in this document.

371 PTP_F is the firm capacity reserved for confirmed Point-to-Point Transmission Service.

372 In BPA's calculations for 1:1 paths, PTP_F is equal to the sum of the MW Demands of PTP_F
373 reservations or schedules.

374 For BPA's flow-based paths, BPA accounts for PTP_F obligations with a combination of base
375 ETC and interim ETC calculations, as described further in this document.

376 For Redirects from conditional short-term firm parent reservations, BPA's ETC accounts
377 for the parent reservation until the Redirect is confirmed on OASIS. Once the Redirect is
378 confirmed, BPA's ETC only accounts for the Redirect.

379 For Redirects from long-term firm parent reservations or unconditional short-term firm
380 parent reservations, BPA's ETC accounts for both the parent reservation and the Redirect
381 reservation until the Redirect itself is unconditional. Once the Redirect is unconditional,
382 BPA's ETC only accounts for the Redirect.

383 In some cases, BPA has PTP_F contracts that give customers the right to schedule between
384 multiple Points of Receipt (PORs) and Points of Delivery (PODs). However, the customer
385 can only schedule up to the MW amount specified in their contract. Multiple reservations
386 are created for these special cases to allow BPA to model each POR-to-POD combination.
387 The amount set aside for these cases does not exceed the total PTP_F rights specified in
388 the contracts.

389 **ROR_F** is the firm capacity reserved for roll-over rights for contracts granting Transmission
390 Customers the right of first refusal to take or continue to take Transmission Service when the
391 Transmission Customer's Transmission Service contract expires or is eligible for renewal.

392 BPA assumes that all of its Transmission Service Agreements eligible to roll-over in the
393 future will be rolled over. If a Transmission Customer chooses not to exercise its roll-over
394 rights by the required deadline, BPA no longer holds out capacity for roll-over rights for
395 that Transmission Customer.

396 **OS_F** is the firm capacity reserved for any other service(s), contract(s), or agreement(s) not
397 specified above using Firm Transmission Service as specified in the ATCID.

398 BPA has no OS_F and thus sets OS_F at zero for all of its paths for all time periods. All of
399 BPA's firm Transmission obligations are captured in the NITS_F, PTP_F, GF_F and ROR_F
400 components of the ETC_F algorithm.

401 Although BPA uses the above algorithm to calculate ETC_F for all of its paths, BPA's ETC_F
402 calculation methodology differs between its 1:1 and flow-based paths. For 1:1 paths, BPA
403 calculates ETC_F by assuming that 1 MW of reserved firm capacity equals 1 MW of ETC_F across
404 that path. For the flow-based paths, BPA calculates ETC_F by summing the base ETC from
405 power-flow ETC studies with interim ETC_F calculated using PTDfS.

406 **Determining base ETC for Flow-Based Paths**

407 **Use of WECC Base Cases to Determine Base ETC**

408 BPA uses the WECC seasonal base cases and modifies them to calculate the base ETC
409 for its flow-based paths. BPA refers to these base cases as ETC Cases.

410 **Determining Base ETC for Heavy Load Base Cases**

411 BPA creates monthly heavy load ETC Cases to calculate base ETC values. BPA's ETC
412 cases are produced using a power flow model that computes how much power will
413 flow over each flow-based path for the assumed Load and generation levels for each
414 time period studied. Counterflows are inherently modeled in these base cases.

415 BPA uses the following assumptions to create heavy load ETC Cases for its base ETC
416 calculations:

417 **System topology:** Normal operating conditions are used. BPA uses the WECC Winter
418 seasonal case for its November through March ETC base cases, the WECC Spring
419 seasonal case for its April and May ETC base cases, and the WECC Summer seasonal
420 case for its June through October ETC base cases.

421 **Load:** BPA uses loads contained in the WECC seasonal base cases for the time periods
422 being studied, along with any updates to those loads BPA may have made after the
423 WECC base cases were received from WECC.

424 • **NITS_F, PTP_F and GF_F:** BPA assumes a 1-in-2 year monthly heavy load forecast in all
425 its monthly ETC cases

426 **Generation:** For the generators in BPA’s Balancing Authority or directly
427 interconnected to BPA, BPA uses the following generation assumptions:

428 **FCRPS:** For the FCRPS resources serving NITS_F, PTP_F, and GF_F Long-Term Reservations,
429 generation levels are set using a multiple-step process. For all time periods studied,
430 BPA uses the following process:

431 • The Columbia Generating Station is assumed to be on-line at full Load in the ETC
432 cases. Generation levels at the Libby, Hungry Horse, Dworshak, and Albeni Falls
433 projects are set based on the requirements set forth in the 2000 Biological
434 Opinion. The generation levels at the Willamette Valley projects⁴ are set at a
435 monthly fleet-aggregate lower 10th percentile of Heavy Load Hour block
436 generation from the planning period of record and adjusted as needed to
437 accurately reflect operations that BPA knows are in place. **Nameplate Adjusted**
438 **Method:** When creating heavy load ETC Cases, generation levels for all other
439 federal hydro projects⁵ are set by first determining the nameplate for each project
440 and then adjusting such nameplates by outages forecasted for the particular
441 plants. Next in the month of August, the Lower Snake plants (Lower Granite,
442 Lower Monumental, Little Goose, and Ice Harbor) are capped at the observed
443 project outflow over the past ten Augusts. Then multiple generation scenarios are
444 modelled by stressing one of three different “zones” of Federal hydro resources to
445 the nameplate adjusted generation levels described above and scales the
446 generation at the remaining Federal hydro projects to match the sum of the
447 demands for all contracts that call out non-specific Federal hydroelectric projects
448 as PORs after adjusting these demands for the portion served by Columbia
449 Generating Station, Libby, Hungry Horse, Dworshak, Albeni Falls, and the
450 Willamette Valley projects. The Federal PTP demands at each project are then
451 added to this result to obtain the final assumed generation level for each Federal
452 hydro project.

453 **Non-Federal Thermal Generators:** Non-federal thermal generators associated with
454 PTP_F, GF_F and NITS_F Transmission Service for BPA’s area and all adjacent TSP areas are
455 set at up to the contract Demand.

⁴ Willamette Valley projects include: Big Cliff, Cougar, Detroit, Dexter, Foster, Green Peter, Hills Creek, Lookout Point, and Lost Creek.

⁵ Federal hydro projects include: Grand Coulee, Chief Joseph, Lower Granite, Lower Monumental, Little Goose, Ice Harbor, McNary, John Day, The Dalles, Bonneville.

- 456 **Wind Generators:**
- 457
- 458
- 459 • **PTP_F:** Wind generators associated with PTP_F Long-Term Reservations are set at
460 the following depending on the scenarios being run:
 - 461 ○ Modeled on at 100 percent of the contract demand for the wind
462 generator; or
 - 463 ○ Modeled off
 - 464 • **NITS_F:** The flow-based path impacts of wind generators identified as
465 designated network resources in NITS_F contracts or in the NT Resources
466 Memorandum of Agreement in BPA’s area are determined on a flow-based
467 path-by-flow-based path basis and set at the greater of the following:
 - 468 ○ The wind generators modeled on at the designated amount of the wind
469 generators; or,
 - 470 ○ The wind generators modeled off and replaced by increasing the FCRPS
471 generation level by the designated amount of the wind generators using
472 the Nameplate Adjusted Method for all ETC cases described above.
- 473 Wind generators designated as network resources in NITS_F contracts for all
474 adjacent TSPs are modeled up to the designated amount.
- 475 • **GF_F:** BPA and all of BPA’s adjacent TSPs have no GF_F contracts for wind
476 generators.

475 **Behind the Meter Generators:** Non-federal resources that do not require
476 Transmission Service over the FCRTS and that are behind the meter are set up to
477 levels used in BPA’s process for power system planning studies.

478 **Mid-Columbia Hydro Projects:** Generation levels at the non-federal Mid-Columbia
479 hydro projects are set up to 90 percent of their historical output by season.

480 When creating heavy load ETC cases, if there is more generation than load plus
481 committed exports in the base case, BPA reduces all excess generation pro rata,
482 except for the stressed FCRPS zone. The generation reduction is done to bring
483 generation and load into balance in order to solve the power flow model.

484 When creating heavy load ETC cases, if there is more load and committed exports than
485 generation in the ETC base case, BPA reduces exports on the COI and Pacific DC
486 Intertie in the ETC base case. This is done to solve the power flow model.

487 **Sensitivity Studies for Heavy Load Base Cases**

488 In calculating its base ETC values, BPA runs ETC case scenarios for three different
489 sensitivities: the Canadian Entitlement Return (CER) obligation modeled on or off,
490 wind resources designated to serve PTP_F and NITS_F on or off, and stressing the three
491 different zones of the FCRPS.

492 For the FCRPS scenarios, the three “zones” that are stressed individually in the
493 scenarios are made up of the following projects: (i) Upper Columbia zone includes
494 Grand Coulee and Chief Joseph; (ii) Lower Snake zone includes Lower Monumental,
495 Lower Granite, Little Goose, and Ice Harbor; and (iii) Lower Columbia zone includes
496 McNary, John Day, The Dalles and Bonneville.

497 For the CER Scenarios, BPA models the FCRPS generators delivering or not delivering
498 energy to Canada in the amount specified in the Canadian Entitlement Agreement.

499 In the CER on scenarios, BPA models the exports to Canada at the Canadian
500 Entitlement Agreement contract level. The FCRPS generation is modeled using the
501 Nameplate Adjusted Method.

502 In the CER off scenarios, BPA models imports from Canada at the contract rights that
503 customers have across the Northern Intertie N>S. The FCRPS generation is also
504 modeled using the Nameplate Adjusted Method.

505 For the wind resource scenarios, see above for a description of the base ETC
506 assumptions for wind generators serving PTP_F and $NITS_F$.

507 Therefore, in its heavy load base ETC sensitivity analysis, BPA models the following 6
508 scenarios:

- 509 1. Wind modeled off/Upper Columbia stressed
- 510 2. Wind modeled off/Lower Snake stressed
- 511 3. Wind modeled off/Lower Columbia stressed
- 512 4. Wind modeled on/Upper Columbia stressed
- 513 5. Wind modeled on/Lower Snake stressed
- 514 6. Wind modeled on/Lower Columbia stressed

515 All scenarios are run with CER modeled on and off for all months.

516 BPA uses the highest base ETC value calculated from these scenarios in its firm ATC
517 calculations across the flow-based paths. BPA uses the lowest base ETC value from
518 these scenarios in its non-firm ATC calculations across the flow-based paths.

519 **Determining Base ETC and Sensitivities for Light Load Base Cases**

520 BPA uses the WECC Winter seasonal light load case as the starting point for its Winter
521 seasonal light load ETC base case. The ETC from this case is used as the base ETC for
522 the months of November through March.

523 BPA uses the WECC Summer seasonal light load case as the starting point for its
524 Summer light load ETC base case. The ETC from the Summer case is used as the base
525 ETC for the months of June through October.

526 If a WECC Spring seasonal light load case is available, BPA uses that case as the
527 starting point for its Spring seasonal light load ETC base case. The ETC from this case
528 is used as the base ETC for the months of April and May. If the WECC Spring seasonal
529 light load case is not available, the higher of the base ETCs from either the Winter or
530 Summer case are used as the base ETC for April and May.

531 BPA uses the following assumptions in light load ETC base cases:

- 532 a. System topology: Normal operating conditions are used.

- 533 b. Loads: Loads from the WECC light load cases are used. Beginning with the
534 Winter 2022 seasonal case and for Montana loads only, BPA compares the loads
535 in the WECC seasonal light load case with the seasonal light loads supplied by
536 Montana Power, and uses the lowest of the two values in order to properly
537 stress the light load case.
- 538 c. Generation: BPA uses generation assumptions from historical data. Canadian
539 Entitlement is modeled as delivering energy to Canada in the amount specified
540 in the Canadian Entitlement Agreement.

541 There are two sensitivity studies performed for the light load ETC base cases:

- 542 a. Federal generation east of the path is increased, and a corresponding amount
543 of federal generation west of the path is reduced
- 544 b. Federal generation east of the path is reduced, and a corresponding amount of
545 federal generation west of the path is increased

546 BPA uses the highest base ETC value calculated from these scenarios in its firm ATC
547 calculations across the flow-based paths where light load cases are utilized. BPA uses
548 the lowest base ETC value from these scenarios in its non-firm ATC calculations across
549 the flow-based paths where light load cases are utilized.

550 **Calculating Interim ETC_F for Flow-based Paths**

551 To calculate the impacts for all NITS_F and PTP_F reservations that were not modeled in the
552 base ETC cases, BPA uses PTDF analysis on the demand in each reservation. PTDF analysis
553 is the fraction of energy (expressed as a percentage or as a decimal) that will flow across
554 BPA's monitored flow-based paths as that energy is injected at a POR (or source) relative
555 to a slack bus, and withdrawn at a POD (or sink) relative to a slack bus, for each flow-
556 based path.

557 PTDF impacts are calculated as per BPA's Transmission Service Requests Evaluation
558 business practice. If a reservation's impact on a flow-based path is determined to be *de*
559 *minimis* per the Transmission Service Requests Evaluation business practice, then BPA
560 deems the impact of the reservation to be zero when calculating ETC_F used in the ATC_F
561 calculation.

562 The sum of these positive impacts is referred to as the interim ETC_F value, and is added to
563 the base ETC values to produce a final ETC_F value for each time period for each flow-
564 based path.

565 **Outages in PTDF Calculations**

566 BPA calculates PTDFs by adjusting the WECC base cases to include transmission
567 outages in BPA's outage system for BPA's area and any adjacent TSP areas. BPA has
568 no executed coordination Agreements with other TSPs. (MOD-001 R3.6)

569 When the Raver-Paul 500-kV line is out of service, the PTDFs that BPA calculates and
570 uses for the Raver-Paul path are based on the monitored lines for this path that are
571 outlined in Table 2. This allows BPA to properly manage the Raver-Paul path in this
572 outage situation.

573 **Outage Criteria in ETC Calculations**

574 BPA uses the outage planning timeline described in the “Outages” section. The
575 following criteria determine which outages are incorporated into BPA’s hourly, daily
576 and monthly ETC calculations: (MOD-001 R3.6)

577 **Hourly ETC Calculations**

578 For its hourly ETC calculations, BPA uses hourly PTDFs published at least once per
579 day. Transmission outages for Transmission Lines, sections of Transmission Lines,
580 transformers and taps are used to set branches as *open* in the appropriate base
581 case for the hour being calculated.

582 **Daily ETC Calculations**

583 For its daily ETC calculations, BPA uses the most recent PTDFs published for the
584 hour ending 11 of each day, since hour ending 11 tends to have the highest
585 coincidence of outages. Therefore all Transmission outages scheduled to occur
586 during the hour ending 11, regardless of the duration of the outage, impact daily
587 ETC calculations. (MOD-001 R3.6.1)

588 BPA includes Transmission outages in daily ETC calculations beyond the 10- to 16-
589 day planned outage study period if the outage is officially scheduled in BPA’s
590 outage system.

591 **Monthly ETC Calculations**

592 For its monthly ETC calculations, BPA uses the most recent daily PTDFs published
593 for the first Tuesday of that month. BPA includes Transmission outages in monthly
594 ETC calculations beyond the 10- to 16-day planned outage study period if the
595 outage is officially scheduled in BPA’s outage system. (MOD-001 R3.6.2)

596 **Source/POR and Sink/POD Identification and Mapping**

597 In the ETC components of its flow-based path ATC calculations, BPA accounts for
598 source and sink for Transmission Service through the following processes:

599 BPA maps the source/POR and sink/POD to the WECC base cases. In this mapping, BPA
600 has assigned network bus points that represent the primary interface for
601 Interconnection with specific generation projects, adjacent electrical Systems or
602 Load-serving entities and trading hubs. Some adjacent electrical Systems have
603 multiple Interconnection points deemed as PORs/sources or PODs/sinks. The mapping
604 of these points is published in the Transmission Service Contract Points list on BPA’s
605 OASIS homepage.

606 BPA calculates weighted PTDFs for Sources/PORs as follows:

- 607 1. The PTDF weighting for the FCRPS/BPA Power PTDF varies by time period and path
608 based on stress scenarios. The PTDF weighting is derived from generation
609 forecasts of the federal resources, for calculations for the next hour through
610 approximately two weeks. Beyond this time frame, BPA derives the weighting of
611 the PTDF by applying the generation dispatch determined in the ETC Cases.

- 612 2. BPA derives the PTDF weighting for the Mid-Columbia bus point by applying the
613 generation dispatch determined in the ETC Cases.
614 3. BPA has grouped the generators in its adjacent BAAs based on the primary
615 interface between each BAA and the generation projects within that BAA
616 (excluding some remote generators that are scheduled via NERC e-Tag). These
617 groupings are assigned weighted PTDFs that represent how the generators
618 participate in the group and are used to evaluate transactions within and between
619 adjacent BAAs that do not include BPAT. BPA derives the PTDF weightings for
620 these points from BAA-provided generation estimates or by applying the generation
621 dispatch determined in the ETC Cases if generation estimates are not available. In
622 the ETC Cases, these generators are modeled up to the long-term firm
623 Transmission rights associated with the generators.

624 BPA calculates weighted PTDFs for Sinks/PODs as follows:

- 625 1. BPA has weighted PTDFs for loads in its adjacent BAAs based on the primary
626 interface between each BAA and the load within that BAA. The weighting is based
627 on how the load is distributed in the BAA.
628 2. BPA calculates a weighted PTDF to account for unscheduled Network Integration
629 Transmission Service loads in BPA's BAA that are served from the FCRPS. The
630 weighting is based on the individual load forecasts for the time period being
631 calculated.
632 3. BPA calculates a weighted load for all of the BPA Power Services customers that
633 are served via Network Integration Transmission Service agreements. The
634 weighting is based on the individual load forecasts for the time period being
635 calculated.
636 4. BPA calculates a weighted load for PNGC Power, which is a Joint Operating Entity
637 made up of several cooperative utilities. The weighting is based on the individual
638 load forecasts for the time period being calculated.

639 BPA calculates one weighted PTDF that applies to the following Source/POR and
640 Sink/POD:

- 641 1. BPA calculates a weighed PTDF for the Western Energy Imbalance Market. This
642 weighting is based on the percentage of Automatic Generation Control response
643 (which could be zero) carried by each plant in the FCRPS.

644 **Calculating Firm Available Transfer Capability (ATC_F)**

645 When calculating ATC_F for its paths for all time periods, BPA uses the following algorithm
646 (MOD-029 R7):

$$647 \quad \text{ATC}_F = \text{TTC}_F - \text{ETC}_F - \text{CBM} - \text{TRM} + \text{Postbacks}_F + \text{Counterflows}_F$$

648 **Where:**

649 ATC_F is the firm Available Transfer Capability for the ATC Path for that period.

650 **TTC** is the Total Transfer Capability of the ATC Path for that period.

651 **ETC_F** is the sum of existing firm commitments for the ATC Path during that period.

652 For **ETC_F** calculations for all time periods, BPA divides **ETC_F** into the following variables
653 within its ATC software:

$$654 \quad \mathbf{ETC_F = LRES + SRES + LETC - SADJ/ETC Adjustments}$$

655 **Where:**

656 **LRES** is the sum of positive impacts of BPA's Long-Term Reservations.

657 **SRES** is the sum of positive impacts of BPA's Short-Term Reservations.

658 **LETC** is used to ensure that the amount of **NITS_F**, **GF_F**, **PTP_F** and **ROR_F** capacity BPA sets
659 aside in the **LRES** variable for contracts where BPA gives customers the right to schedule
660 the capacity reserved between multiple **PORs** and **PODs** does not exceed the total capacity
661 specified in those contracts.

662 **LETC** is also used to align the **ETC** calculated in the power flow base case with additional
663 **PTDF** calculations in order to balance to the standard **OATI** calculation. This adjustment is
664 derived by comparing two values: a) the impacts of the confirmed **PTP_F**, **GF_F**, **NITS_F** and
665 **ROR_F** Long-Term Reservations derived from the base **ETC** Cases and b) the impacts of the
666 same reservations calculated using **PTDF** Analysis for each flow-based path. The
667 adjustment for each flow-based path is equal to the difference of these two values.
668 Conditional firm reservations are not included in the **ETC** Cases and therefore are also not
669 included in this comparison.

670 **SADJ/ETC Adjustments** is the variable BPA uses to make adjustments to **ETC_F** not
671 captured in **LRES** or **SRES**.

672 BPA applies one such adjustment to allow for deferral competitions, as required in Section
673 17.7 of BPA's **OATT**. When a deferral reservation is confirmed, BPA applies an **SADJ/ETC**
674 Adjustment to hold out capacity for the time period deferred, starting at the latter of five
675 months out or the service commencement date of the original reservation, to allow for a
676 competition. At four months out, if no competition is identified, the **SADJ/ETC**
677 Adjustment is modified to release the capacity for the fourth month out.

678 BPA uses a **SADJ/ETC** Adjustment to account for a portion of the firm **TRM** that BPA
679 applies on the **NI S>N**.

680 BPA also uses **SADJ/ETC** Adjustments to ensure accurate accounting of **ETC_F**. These
681 adjustments may be performed to account for situations such as data modeling
682 corrections, and are noted in the descriptions of the adjustments.

683 The following diagram illustrates how the variables in BPA's ATC software correspond to
684 the variables in the **ETC_F** algorithm.

685

ETC_F =	NITS_F	+	GF_F	+	PTP_F	+	ROR_F
	↓		↓		↓		↓
	LRES		LRES		LRES		LRES
	+				+		
	SRES				SRES		
	+		+		+		+
	LETC		LETC		LETC		LETC
	-		-		-		-
	SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments

686 **CBM** is the Capacity Benefit Margin for the ATC Path during that period.

687 BPA does not maintain CBM and thus sets CBM at zero for all of its paths for all time
688 periods.

689 **TRM** is the Transmission Reliability Margin for the ATC Path during that period.

690 The description of how BPA implements TRM can be found in BPA's TRMID, which is posted
691 on BPAs website.

692 **Postbacks_F** are changes to firm Available Transfer Capability due to a change in the use of
693 Transmission Service for that period, as defined in Business Practices.

694 BPA automatically recalculates ETC_F to account for changes to Transmission Service
695 Requests (such as request types of Recall and Redirect and annulments). Since these
696 types of changes to Transmission Service Requests are captured in ETC_F, BPA sets
697 Postbacks_F at zero for all time periods when calculating ATC_F.

698 **Counterflows_F** are adjustments to firm Available Transfer Capability as determined by the
699 Transmission Service Provider and specified in their ATCID.

700 BPA does not include confirmed Transmission reservations, expected interchange or
701 internal flow counter to the direction of the path being calculated in its ATC_F calculations.
702 BPA's rationale is that it does not want to offer firm ATC due to counterflow that may not
703 be scheduled as this could lead to curtailments of Firm Transmission Service in the Real-
704 time horizon. (MOD-001 R3.2) Therefore BPA sets Counterflows_F at zero for all of its paths
705 for all time periods.

706 For flow-based paths, counterflows are automatically modeled in the base ETC cases. In
707 instances where the power flow study results in a negative base ETC value, BPA uses zero
708 as the base ETC for purposes of calculating ATC_F. This is done to ensure that BPA does not
709 make capacity available as a result of counterflows that may or may not materialize in
710 real-time.

711 **Calculating Non-Firm Transmission Service for BPA’s Paths**

712 BPA calculates ETC_{NF} and ATC_{NF} for each of its six non-firm Transmission products. The six
713 non-firm products are: Secondary Network ($NITS_{NF6}$), Monthly Non-Firm PTP (PTP_{NF5}), Weekly
714 Non-Firm PTP (PTP_{NF4}), Daily Non-Firm PTP (PTP_{NF3}), Hourly Non-Firm PTP (PTP_{NF2}) and
715 Secondary Non-Firm Hourly PTP (PTP_{NF1}).

716 **Calculating Non-Firm Existing Transmission Commitments (ETC_{NF})**

717 BPA calculates ETC_{NF} for all time periods and paths using the algorithm in MOD-029 R6:

$$718 \quad ETC_{NF} = NITS_{NF} + GF_{NF} + PTP_{NF} + OS_{NF}$$

719 ETC_{NF} is calculated for each of BPA’s six non-firm Transmission products as follows:

- 720 1. ETC_{NF6} : includes the $NITS_{NF6}$ transmission product
- 721 2. ETC_{NF5} : includes the $NITS_{NF6}$ and PTP_{NF5} transmission products
- 722 3. ETC_{NF4} : includes the $NITS_{NF6}$, PTP_{NF5} and PTP_{NF4} transmission products
- 723 4. ETC_{NF3} : includes the $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , and PTP_{NF3} transmission products
- 724 5. ETC_{NF2} : includes the $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} and PTP_{NF2} transmission products
- 725 6. ETC_{NF1} : includes the $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1} transmission products

726 **Where:**

727 $NITS_{NF}$ is the non-firm capacity set aside for Network Integration Transmission Service serving
728 Load (i.e., secondary service), to include losses, and Load growth not otherwise included in
729 Transmission Reliability Margin or Capacity Benefit Margin.

730 In BPA’s calculations, this is comprised of the $NITS_{NF6}$ Transmission product. BPA’s $NITS_{NF6}$
731 calculation does not include losses or Load growth, since losses and Load growth are
732 already set aside as firm capacity in $NITS_F$.

733 GF_{NF} is the non-firm capacity set aside for grandfathered Transmission Service and contracts
734 for energy and/or Transmission Service, where executed prior to the effective date of a
735 Transmission Service Provider’s Open Access Transmission Tariff or “safe harbor tariff”.

736 BPA does not have any grandfathered non-firm Transmission Service obligations and thus
737 sets GF_{NF} at zero for all of its paths for all time periods.

738 PTP_{NF} is non-firm capacity reserved for confirmed Point-to-Point Transmission Service.

739 Depending on the ETC_{NF} being calculated, PTP_{NF} will include the PTP_{NF5} , PTP_{NF4} , PTP_{NF3} ,
740 PTP_{NF2} and PTP_{NF1} Transmission products.

741 OS_{NF} is the non-firm capacity reserved for any other service(s), contract(s), or agreement(s)
742 not specified above using non-firm transmission service as specified in the ATCID.

743 BPA has no OS_{NF} and thus sets OS_{NF} at zero for all of its paths for all time periods.

744 ETC_{NF} for 1:1 paths is calculated by assuming that 1 MW of reserved and/or scheduled capacity
745 results in 1 MW of impact across the 1:1 path.

746 When calculating ETC_{NF} for flow-based paths, BPA sums the positive impacts of reservations
747 and/or schedules as determined by PTFD analysis, per BPA's Transmission Service Requests
748 Evaluation business practice. The treatment of *de minimis* impacts in ETC_{NF} is covered within
749 the Calculating Non-Firm Available Transfer Capability section below.

750 **Calculating Non-Firm Available Transfer Capability (ATC_{NF})**

751 BPA calculates ATC_{NF} for its paths for two horizons: Real-time and Beyond Real-time. The
752 Real-time horizon begins at 10 p.m. each day for the 24 hours in the next day. The Beyond
753 Real-time horizon includes hourly for the hours after those included in the Real-time period
754 as well as daily and monthly calculations.

755 BPA calculates ATC_{NF} for all time periods and paths using the algorithm found in MOD-029 R8:

$$756 \quad \mathbf{ATC}_{NF} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

757 ATC_{NF} is calculated for each of BPA's six non-firm Transmission products as follows:

$$758 \quad 1. \quad \mathbf{ATC}_{NF6} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF6} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

$$759 \quad 2. \quad \mathbf{ATC}_{NF5} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF5} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

$$760 \quad 3. \quad \mathbf{ATC}_{NF4} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF4} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

$$761 \quad 4. \quad \mathbf{ATC}_{NF3} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF3} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

$$762 \quad 5. \quad \mathbf{ATC}_{NF2} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF2} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

$$763 \quad 6. \quad \mathbf{ATC}_{NF1} = \mathbf{TTC} - \mathbf{ETC}_F - \mathbf{ETC}_{NF1} - \mathbf{CBM}_S - \mathbf{TRM}_U + \mathbf{Postbacks}_{NF} + \mathbf{Counterflows}_{NF}$$

764 Table 3 outlines the differences in how the ATC_{NF} algorithm components are calculated
765 between the Beyond Real-time and Real-time time horizons.

766

Table 3, ATC_{NF} Calculation for Beyond Real-Time and Real-Time Horizons

Algorithm Component	Beyond Real-time	Real-time
TTC	As described in TTC section in the ATCID	Same
ETC _F	Calculated using reservations and base ETC cases for flow-based paths <ul style="list-style-type: none"> • <i>De minimis</i> impacts are treated as zero in ETC_F 	Calculated using schedules <ul style="list-style-type: none"> • <i>De minimis</i> impacts are included in ETC_F
ETC _{NF}	Calculated using reservations <ul style="list-style-type: none"> • <i>De minimis</i> impacts are treated as zero in ETC_{NF} 	Calculated using reservations until scheduled, then calculated using schedules <ul style="list-style-type: none"> • <i>De minimis</i> impacts are included in ETC_{NF} for both reservations and schedules
CBM _S	N/A	N/A
TRM _U	As described in the TRMID	Same
Postback _{SNF}	Zero since ETC _{NF} is recalculated to capture changes to the Transmission Service Requests	Zero since ETC _{NF} is recalculated to capture changes to the Transmission Service Requests and/or schedules, with the exception of AC N>S
Counterflows _{NF}	Included with schedules	Same

768 **Where:**

769 ATC_{NF} is the non-firm Available Transfer Capability for the ATC Path for that period.

770 BPA calculates six ATC_{NF} values as described above.

771 TTC is the Total Transfer Capability of the ATC Path for that period.

772 ETC_F is the sum of existing firm commitments for the ATC Path during that period.

773 The section below outlines how BPA calculates ETC_F for all of its paths for the beyond
774 Real-time and the Real-time horizons.

775 ETC_F for the Beyond Real-Time Horizon

776 Reservations, and base ETC cases for flow-based paths, are used to calculate ETC_F for the
777 Beyond Real-time horizon. When calculating ETC_F for this horizon, *de minimis* impacts of
778 reservations across flow-based paths are deemed to be zero.

779 For ATC_{NF} calculations for the beyond Real-time horizon, BPA utilizes the following
780 variables within its ATC software to calculate ETC_F:

781
$$\text{ETC}_F = \text{LRES} + \text{SRES} - \text{SADJ/ETC Adjustments} + \text{NFETC}$$

782

783 **Where:**

784 **LRES** is the sum of positive impacts of BPA’s Long-Term Reservations.

785 **SRES** is the sum of positive impacts of BPA’s Short-Term Reservations.

786 **SADJ/ETC Adjustments** is the variable used to make adjustments to ETC_F not captured
787 in LRES or SRES.

788 BPA applies one such adjustment to allow for deferral competitions, as required in
789 Section 17.7 of BPA’s OATT. When a deferral reservation is confirmed, BPA applies a
790 SADJ/ETC Adjustment to hold out capacity for the time period deferred, starting at
791 the latter of five months out or the service commencement date of the original
792 reservation, to allow for a competition. At four months out, if no competition is
793 identified, the SADJ/ETC Adjustment is modified to add back capacity for the fourth
794 month out.

795 BPA uses SADJ/ETC Adjustments to ensure accurate accounting of ETC_F . These
796 adjustments may be performed to account for situations such as data modeling
797 corrections, and are noted in the descriptions of the adjustments.

798 **NFETC** is used to ensure that the amount of $NITS_F$, GF_F , PTP_F and ROR_F capacity BPA
799 sets aside in the LRES variable for contracts where BPA gives customers the right to
800 schedule the capacity reserved between multiple PORs and PODs does not exceed the
801 total capacity specified in those contracts.

802 **NFETC** is also used to align the ETC calculated in the power flow base case along with
803 additional PTDF calculations in order to balance to the standard OATI calculation.

804 This adjustment is derived by comparing two values: a) the impacts of the PTP_F , GF_F
805 and $NITS_F$ Long-Term Reservations derived from the base ETC Cases and b) the impacts
806 of the same reservations calculated using PTDF Analysis for each flow-based path. The
807 adjustment for each flow-based path is equal to the difference of these two values.
808 Conditional firm reservations are not included in the ETC Cases and therefore are also
809 not included in this comparison.

810 The following diagram illustrates how the variables in BPA’s ATC software correspond
811 to the variables in the ETC_F algorithm for the Beyond Real-time horizon.

$ETC_F =$	$NITS_F$	+	GF_F	+	PTP_F	+	ROR_F
	↓		↓		↓		↓
	LRES		LRES		LRES		LRES
	+				+		
	SRES				SRES		
	+		+		+		+
	NFETC		NFETC		NFETC		NFETC
	-		-		-		-
	SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments		SADJ/ETC Adjustments

812 **ETC_F for the Real-Time Horizon**

813 For ATC_{NF} calculations for the Real-time horizon, BPA divides ETC_F into the following
 814 variables within its ATC software:

815
$$ETC_F = SCH^+_7 + ASC^+_7 + RADJ/ETC \text{ Adjustment}$$

816 Schedules are used to calculate ETC_F for the Real-time horizon. When calculating ETC_F for
 817 this horizon, *de minimis* impacts of schedules across flow-based paths are included in
 818 ETC_F.

819 **Where:**

820 **SCH⁺₇** is the sum of the positive impacts of schedules that reference confirmed NITS_F,
 821 GF_F and PTP_F reservations for the ATC Path for that period. The energy profile of the
 822 schedule is used except for the schedule types of Dynamic, Capacity and Pseudo-tie.

823 **ASC⁺₇** is the sum of the positive impacts of dynamic schedules that reference
 824 confirmed NITS_F, GF_F and PTP_F reservations for the ATC Path for that period. The
 825 transmission profile of the schedule is used for the schedule types of Dynamic,
 826 Capacity and Pseudo-tie.

827 **RADJ/ETC Adjustment:** BPA uses RADJ/ETC adjustments to ensure accurate
 828 accounting of ETC_F. These adjustments may be performed to account for situations
 829 such as data modeling corrections.

830 The following diagram illustrates how the variables in BPA’s ATC software correspond
 831 to the variables in the ETC_F algorithm for the Real-time horizon. ROR_F is not included
 832 in ETC_F for the Real-time horizon because ROR_F is not relevant for the Real-time
 833 horizon.

ETC_F =	NITS_F	+	GF_F	+	PTP_F
	↓		↓		↓
	SCH⁺₇		SCH⁺₇		SCH⁺₇
	+		+		+
	ASC⁺₇		ASC⁺₇		ASC⁺₇
	+		+		+
	RADJ/ETC Adjustment		RADJ/ETC Adjustment		RADJ/ETC Adjustment

834 **ETC_{NF}** is the sum of existing non-firm commitments for the ATC Path during that period.

835 The section below outlines how BPA calculates ETC_{NF} for all of its paths for the beyond
 836 Real-time and the Real-time horizons.

837 **ETC_{NF} for the Beyond Real-Time Horizon**

838 For ATC_{NF} calculations for the beyond Real-time horizon, ETC_{NF} is reflected as the
 839 following variable within BPA’s ATC software:


840 $ETC_{NF} = RRES_{6,5,4,3,2,1}$

841 Reservations are used to calculate ETC_{NF} for the Beyond Real-time horizon. When
 842 calculating ETC_{NF} for this horizon, *de minimis* impacts of reservations across flow-based
 843 paths are deemed to be zero.

844 **Where:**

845 $RRES_{6,5,4,3,2,1}$ is the sum of the positive impacts of all confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} ,
 846 PTP_{NF3} , PTP_{NF2} and PTP_{NF1} reservations.

847 The following diagram illustrates how the variables in BPA’s ATC software correspond
 848 to the variables in the ETC_{NF} algorithm for the Beyond Real-time horizon.



849 **ETC_{NF} for the Real-Time Horizon**

850 For ATC_{NF} calculations in the Real-time horizon, ETC_{NF} is reflected as the following
 851 variables within BPA’s ATC software:

852 $ETC_{NF} = SCH^+_{6,5,4,3,2,1} + ASC^+_{6,5,4,3,2,1}$

853 To calculate ETC_{NF} for the Real-time horizon, reservations are used until schedules are
 854 received, and then schedules are used. When calculating ETC_{NF} for this horizon, *de*
 855 *minimis* impacts across flow-based paths are included in ETC_{NF} , regardless of whether the
 856 reservation or schedule is being used in the calculation.

857 **Where:**

858 $SCH^+_{6,5,4,3,2,1}$ is the sum of the positive impacts of schedules referenced to confirmed
 859 $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1} reservations, plus the sum of the
 860 positive impacts of confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1}
 861 reservations that have not yet been scheduled. Once these reservations are
 862 scheduled, the schedule is used for ETC_{NF} , thereby adding back the difference
 863 between the reservation and schedule amounts to ATC_{NF} . The energy profile of the
 864 schedule is used except for the schedule types of Dynamic, Capacity and Pseudo-tie.

865 $ASC^+_{6,5,4,3,2,1}$ is the sum of positive impacts of dynamic schedules referenced to
 866 confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1} reservations, plus the sum of
 867 the positive impacts of confirmed $NITS_{NF6}$, PTP_{NF5} , PTP_{NF4} , PTP_{NF3} , PTP_{NF2} and PTP_{NF1}
 868 reservations that have not yet been scheduled. Once these reservations are
 869 scheduled, the schedule is used for ETC_{NF} , thereby adding back the difference
 870 between the reservation and schedule amounts to ATC_{NF} . The transmission profile of
 871 the schedule is used for the schedule types of Dynamic, Capacity and Pseudo-tie.

872 The following diagram illustrates how the variables in BPA’s ATC software correspond
 873 to the variables in the ETC_{NF} algorithm for the Real-time horizon.

874

ETC_{NF} =	NITS_{NF}	+	PTP_{NF}
	↓		↓
	SCH₆⁺		SCH_{5,4,3,2,1}⁺
	+		+
	ASC₆⁺		ASC_{5,4,3,2,1}⁺

875 **CBM_s** is the Capacity Benefit Margin for the ATC Path that has been scheduled during that
 876 period.

877 BPA does not maintain CBM and thus sets CBM_s at zero for all of its paths for all time
 878 periods.

879 **TRM_U** is the Transmission Reliability Margin for the ATC Path that has not been released for
 880 sale (unreleased) as non-firm capacity by the Transmission Service Provider during that
 881 period.

882 The description of how BPA implements TRM can be found in BPA’s TRMID, which is posted
 883 on BPAs website.

884 **Postbacks_{NF}** are changes to non-firm Available Transfer Capability due to a change in the use
 885 of Transmission Service for that period, as defined in Business Practices.

886 The section below outlines how BPA calculates Postbacks_{NF} for all of its paths for the
 887 beyond Real-time and the Real-time horizons.

888 **Postbacks_{NF} for the Beyond Real-time horizon**

889 BPA automatically recalculates ETC_{NF} to account for changes to Transmission Service
 890 Requests (such as request types of Recall and annulments) for the Beyond Real-time
 891 horizon. Since these types of changes to Transmission Service Requests are captured in
 892 ETC_{NF}, BPA sets Postbacks_{NF} at zero for this horizon.

893 **Postbacks_{NF} for the Real-time Horizon**

894 BPA automatically recalculates ETC_{NF} to account for changes to Transmission Service
 895 Requests (such as request types of Recall and annulments) and/or schedules for the Real-
 896 time Horizon. Since these types of changes to Transmission Service Requests and/or
 897 schedules are captured in ETC_{NF}, BPA sets Postbacks_{NF} at zero for this horizon for all paths
 898 with the exception of AC N>S.

899 For ATC_{NF} calculations for the AC N>S path in the Real-time horizon, BPA uses a
900 Postbacks_{NF}, expressed as RADJ/ETC. For its hourly AC N>S non-firm calculations, BPA
901 posts back any unused share of non-firm capacity that is available to BPA by capacity
902 ownership and other Agreements for the AC N>S, if needed to prevent Curtailments.

903 **Counterflows_{NF}** are adjustments to non-firm Available Transfer Capability as determined by
904 the Transmission Service Provider and specified in its ATCID.

905 Since a schedule provides assurance that the transaction will flow, all counterflows
906 resulting from firm and non-firm Transmission schedules, excluding tag types dynamic,
907 pseudo and capacity, are added back to ATC_{NF} in the Counterflows_{NF} component. (MOD-001
908 R3.2)

909 In BPA's ATC_{NF} calculations, Counterflows_{NF} is expressed as $SCH_{7,6,5,4,3,2,1}$, which is the sum
910 of schedules flowing in the direction counter to the direction of the path.

911 Counterflows are modeled in the ETC Cases used to determine ETC_F for BPA's flow-based
912 paths. In instances where the power flow study results in a negative base ETC value, BPA
913 uses zero as the base ETC for purposes of calculating ATC_{NF} . This is done to ensure that
914 BPA does not make capacity available as a result of counterflows that may or may not
915 materialize in real-time

916 In some cases, the amount of Counterflows_{NF} exceeds the sum of the ETC_F and ETC_{NF} ,
917 which, when added to TTC, results in ATC_{NF} greater than TTC.

918 Note: The variable RADJ/ETC is also used to respond to a BPA dispatcher order to change ATC
919 values by a specified amount and thereby reduce schedules in-hour when the flow exceeds
920 the TTC.

921 **Adjustments to Flow-based Path ATC Values**

922 There may be instances where BPA needs to perform testing in the production environment of
923 the systems that manage BPA's ATC calculations. In these instances, BPA may adjust its ATC
924 values across the flow-based paths to ensure that Hourly requests are not declined due to
925 lack of ATC across the flow-based paths. BPA will issue a notice to customers with the details
926 prior to performing this testing.

927 **VIII. Data Sources and Recipients**

928 BPA receives data for use in its ATC calculations, and provides data for use in calculating 1:1
929 and flow-based path capabilities through the WECC base case process. BPA also directly
930 receives and provides data, such as outage information and specific Transmission
931 commitments, from and to the following Transmission Service Providers and Transmission
932 Operators: (MOD-001 R3.3, R3.4)

- 933 • Avista Corporation
- 934 • BC Hydro
- 935 • California Independent System Operator
- 936 • City of Tacoma, Department of Public Utilities, Light Division

- 937 • Eugene Water and Electric Board
- 938 • Fortis BC
- 939 • Idaho Power Company
- 940 • Los Angeles Department of Water and Power
- 941 • NV Energy
- 942 • NorthWestern Energy
- 943 • Pacific Gas & Electric
- 944 • PacifiCorp
- 945 • Pend Oreille County Public Utility District No. 1
- 946 • Portland General Electric
- 947 • Public Utility District No. 1 of Chelan County
- 948 • Public Utility District No. 1 of Clark County
- 949 • Public Utility District No. 1 of Douglas County
- 950 • Public Utility District No. 2 of Grant County, Washington
- 951 • Public Utility District No. 1 of Snohomish County
- 952 • Puget Sound Energy, Inc.
- 953 • Sacramento Municipal Utility District
- 954 • Seattle City Light
- 955 • Southern California Edison
- 956 • Transmission Agency of Northern California
- 957 • Western Area Power Administration - Sierra Nevada Region
- 958 • California Independent System Operator

959 **IX. Responding to Data Requests**

960 Upon official request from any Transmission Service Provider, Planning Coordinator,
 961 Reliability Coordinator, or Transmission Operator for any data from the list below, solely for
 962 use in the requestor's ATC or AFC calculations, BPA will begin to make the data available
 963 within 30 calendar days of receiving the request.

- 964 • Expected generation and Transmission outages, additions, and retirements
- 965 • Load forecasts
- 966 • Unit commitments and order of dispatch, to include all designated resources (BPA does
 967 not have resources that are committed or have the legal obligation to run)
- 968 • Firm NITS and non-firm NITS (i.e. Secondary Service)
- 969 • Firm and non-firm Transmission reservations
- 970 • Grandfathered obligations
- 971 • Firm roll-over rights
- 972 • Any firm and non-firm adjustments applied by BPA to reflect parallel path impacts
- 973 • Power flow models and underlying assumptions
- 974 • Contingencies, provided in one or more of the following formats:

- 975 ○ A list of Elements
- 976 ○ A list of flow-based paths
- 977 ○ A set of selection criteria that can be applied to the WECC base cases used by
- 978 BPA
- 979 ● Facility Ratings
- 980 ● Any other service that impact ETCs
- 981 ● Values of CBM and TRM for all paths
- 982 ● Values of TTC and ATC for all paths
- 983 ● Source and sink identification and mapping to the WECC base cases

984 BPA will make this data available on the schedule specified by the requestor (but no more
985 frequently than once per hour, unless mutually agreed to by the requestor and Bonneville).

986 For a Transmission Service Provider, Planning Coordinator, Reliability Coordinator, or
987 Transmission Operator to officially request data to use in ATC or AFC calculations, the
988 requestor must fill out the **Data Request Form** (MOD-001 R9) found on BPA's ATC
989 Methodology website. The completed request form must be sent to
990 nercatstandards@bpa.gov with **Data request Form** (MOD-001 R9) in the subject line. (MOD-
991 001 R9)

992 X. ATCID Revisions

993 BPA will notify the entities contained in ATCID TP Distribution List when implementing a new
994 or revised ATCID and make its current ATCID available. (MOD-001 R4, R5)