

The Daily Overgeneration Management Protocol Retrospective

An indepth report for 7/2/2012

	OMD	Total BPA BA Thermal Gen	OSM		Total BPA BA Wind Gen	UNUSED INTERTIE CAPACITY			MT EXPORT
	(Non VER)		(VER)	(Non VER)		(NOB)	(COB)	(NI)	(minus = import)
HE01	0	1062	554	0	1588	249	371	2000	129
HE02	0	1058	1002	0	732	216	487	2000	120
HE03	0	1060	1237	0	432	288	526	2000	144
HE04	0	1062	1173	0	352	291	539	2000	165
HE05	0	1083	606	0	517	291	547	2000	162
HE06	0	1126	34	0	787	289	458	2000	247
HE07	0	1232	0	0	1142	443	594	2000	402
HE08	0	1389	0	0	1425	499	412	2000	489
HE09	0	1465	0	0	1476	489	425	2000	523
HE10	0	1549	0	0	1257	217	424	2000	542
HE11	0	1699	0	0	1327	220	352	2000	534
HE12	0	1780	0	0	1078	204	260	2000	437
HE13	0	1847	0	0	1115	196	288	2000	420
HE14	0	1959	0	0	1168	116	241	2000	472
HE15	0	1952	0	0	1511	64	376	2000	401
HE16	0	1949	0	0	1760	64	401	2000	375
HE17	0	1923	0	0	2264	120	381	2000	368
HE18	0	1919	0	0	2645	120	342	2000	399
HE19	0	1823	0	0	2979	67	424	2000	404
HE20	0	1751	0	0	3093	124	333	2000	362
HE21	0	1723	0	0	3327	207	306	2000	274
HE22	0	1472	0	0	3324	251	417	2000	139
HE23	0	1069	0	0	3282	265	564	2000	96
HE24	0	1057	5	0	3184	279	847	2000	188
Day Total (MWh)	0		4611	0					
CUMM (MWh)*	1037		34772	0					

* Cumulative totals since OMD actions on April 24th, 2012

Comments:

The unused NOB, COB and NI capacities are equal to the export limit minus the export schedule. If there is an import on the path, this simply equals the export limit.

These unused COB and unused NOB amounts reflects the net unused non-firm capacity made available by BPAT, and the net unused capacity (could be either firm or non-firm) capacity of the other COB and NOB path owners. The maximum limit used is the WECC path rating, which may include capacity that may not be available for scheduling due to operational limits. All table values are in MWh.

Oregon High 12-hour average percent TDG

	TDG% (TW)
GCL	118.5
CHJ	121.4
LWG	118.0
LGS	116.8
LMN	117.8
IHR	116.3
MCN	122.7
JDA	119.8
TDA	119.8
BON	123.1

TDG%
% =< 120
120< % <125
125< % <127
127 =< %