

Wheatridge Wind

This project is proposed in response to generation interconnection requests submitted by NextEra. In total, NextEra has submitted ten generator interconnection requests for 2,768 MW of capacity. This project will enable the first phase of approximately 500 MW of capacity to address two of those requests - G0362 and G0365. The proposed interconnection will be from NextEra's 230kV collector substation to BPA's Morrow Flat Substation. NextEra has acquired 300MW of firm transmission service from BPA (currently being deferred).

The plan of service includes two 230 kV power circuit breakers, a reactor, numerous disconnect switches, associated relaying and communications equipment as well as control center updates.