

From: [Rick R. Rozanski](#)
To: [Tenney Denison, Lauren E \(BPA\) - TSPQ-TPP-2](#)
Subject: Derbs rate design
Date: Friday, September 02, 2016 1:56:47 PM

McMinnville supports maintaining a deadband which provide relief for small facilities that that generate in less than whole MW increments. A two MW deadband may suffice instead of three.

it seems appropriate for facilities greater than 3 MW to have revenue quality meters capable of 5 minute increments.

The cons for Alt#3 and Alt4 are compelling reasons to avoid these alternatives.

*Rick Rozanski – Resource Manager
McMinnville Water & Light
855 Marsh Lane
McMinnville, Oregon 97128*

(P) 503 472-6158 | (F) 503 472-5211 | (E) rrr@mc-power.com