

memorandum

DATE: January 4, 2013

REPLY TO
ATTN OF: KEP-4

SUBJECT: Supplement Analysis for the Transmission System Vegetation Management Program FEIS (DOE/EIS-0285/SA-493)

TO: Jacob Grinolds
Natural Resource Specialist – TFBV-SNOHOMISH

Proposed Action: Vegetation management along the Snohomish-Murray #1 Transmission Line Corridor

Pollution Prevention and Abatement Project No.: 2532

Location: Snohomish County, Washington: Bonneville Power Administration (BPA) Snohomish District

Proposed by: Bonneville Power Administration (BPA)

Description of the Proposal: BPA proposes to clear unwanted vegetation along and adjacent to the transmission line corridor, and access roads of the 230-kilovolt (kV) Snohomish-Murray #1 transmission line corridor from Snohomish Substation to Murray Substation. Other lines that are present within the corridor are the 230-kV Snohomish-Bothell #1, 230-kV Snohomish-Bothell #2, and 230-kV North Mountain-Snohomish #1. The ROW corridor in the proposed project area measures from 95 to 950 feet in width and crosses approximately 17 miles of terrain through rural residential, suburban, light industrial, agricultural, City of Seattle, Snohomish County, and other private lands.

In order to comply with Western Electricity Coordinating Council (WECC) standards, BPA proposes to manage vegetation with the goal of removing tall growing vegetation that is currently or will soon become a hazard to the transmission line (a hazard is defined as one or more branches, tops, and/or whole trees that could fall or grow into the minimum safety zone of the transmission line(s) causing an electrical arc, relay and/or outage). The overall goal of BPA is to establish low-growing plant communities along the ROW to control the development of potentially threatening vegetation.

A combination of selective and nonselective vegetation control methods would be used to perform the work. All methods including selective cutting, mowing, and herbicide treatments are consistent with the methods approved in BPA's Transmission System Vegetation Management Program EIS. Debris would be disposed of using on-site chip, lop and scatter, or mulching techniques. All on-site debris would be scattered along the ROW.

Analysis: A Vegetation Control Prescription & Checklist was developed for this corridor that incorporates the requirements identified in BPA's Transmission System Vegetation Management Program FEIS (DOE/EIS-0285, May 2000) and Record of Decision (August 23, 2000). The following summarizes natural resources occurring in the project area along with applicable mitigation measures outlined in the Vegetation Control Prescription & Checklist.

Water Resources: Water bodies (streams, rivers, lakes, wetlands) occurring in the project area are noted in the Vegetation Control Prescription. As conservation and avoidance measures, only spot and localized treatment with Garlon 3A (Triclopyr TEA) would be used within a 100 foot buffer up to the water's edge of any stream containing threatened or endangered species. Trees in riparian zones would be selectively cut to include only those that will grow into the minimum approach distances of the conductor at

maximum sag, other trees would be left in place or topped to preserved shade. Shrubs that are less than 10-feet-high would not be cut where ground to conductor clearance allows. No ground disturbing vegetation management methods would be implemented thus eliminating the risk for soil erosion and sedimentation near the streams. For location information, see the Vegetation Control Prescription.

Threatened and Endangered Species: Pursuant to its obligations under the Endangered Species Act (ESA), BPA has made a determination of whether its proposed project would have any effects on any listed species. A species list was obtained for federally listed, proposed and candidate species potentially occurring within the project boundaries from the United States Fish and Wildlife Service (USFWS). Based on the ESA review conducted, BPA made a determination that the project would have “No Effect” for all ESA listed species under USFWS’ jurisdiction. BPA also conducted a review of species under the jurisdiction of the National Oceanic and Atmospheric Administration, National Marine Fisheries Service (NOAA Fisheries). A determination of “No Effect” was made for all ESA listed species under NOAA Fisheries’ jurisdiction, with the implementation of the conservation measures in Water Resources section above.

Essential Fish Habitat: A review of the NOAA Fisheries database identified Essential Fish Habitat (EFH) streams occurring in the project area. Measures identified for water resources would be followed for EFH. A determination of “No Effect” was made for EFH waters that occur in the project area.

Cultural Resources: No cultural resources are known for the project area. If a site is discovered during the course of vegetation control, work would be stopped in the vicinity and the BPA Environmental Specialist, and the BPA Archeologist would be contacted.

Re-Vegetation: Native grasses and low-growing shrubs are present on the ROW and are expected to naturally seed into the areas that would have lightly disturbed soil.

Monitoring: The entire project would be inspected during the work period, spring 2013 to fall 2013. A follow-up treatment would occur 6-12 months after the initial treatment. Additional monitoring for follow-up treatment would be conducted as necessary. A diary of inspection results would be used to document formal inspections and will be filed with the contracting officer.

Findings: This Supplement Analysis finds that (1) the proposed actions are substantially consistent with the Transmission System Vegetation Management Program FEIS (DOE/EIS-0285) and ROD, and; (2) there are no new circumstances or information relevant to environmental concerns and bearing on the proposed actions or their impacts. Therefore, no further NEPA documentation is required.

/s/ Oden W. Jahn

Oden W. Jahn
Environmental Scientist

CONCUR: /s/ Katherine S. Pierce
Katherine S. Pierce
NEPA Compliance Officer

DATE: January 4, 2013

References:
Vegetation Management Prescription and Checklist
Effects Determination