

United States Government

Department of Energy  
Bonneville Power Administration

# memorandum

DATE: November 1, 2013

REPLY TO  
ATTN OF: KEPR-4

SUBJECT: Supplement Analysis for the Transmission System Vegetation Management Program FEIS  
(DOE/EIS-0285/SA-536)

to: Christina Leid  
Natural Resource Specialist – TFBV-PASCO

**Proposed Action:** Vegetation management along the Lower Monumental-McNary No.1 transmission line corridor

**Pollution Prevention and Abatement Project No.:** 2765

**Location:** Umatilla County, Oregon, and Walla Walla County, Washington, in the Bonneville Power Administration's (BPA) Pasco TLM District

**Proposed by:** BPA

**Description of the Proposal:** BPA proposes to clear unwanted vegetation along and adjacent to the transmission line corridor, and access roads on the 500-kilovolt (kV) Lower Monumental-McNary No. 1 transmission line corridor. The right-of-way (ROW) corridor in the proposed project area is 165 feet in width, crosses approximately 64 miles of terrain, and has approximately 115 acres where vegetation is managed. The majority of terrain (53 miles) does not support vegetation that would pose a risk of growing into the line, and would therefore be skipped. Land uses include agriculture and grazing and rural residential, on federal, state, and private land.

In order to comply with Western Electricity Coordinating Council (WECC) standards, BPA proposes to manage vegetation with the goal of removing tall growing vegetation that is currently or will soon become a hazard to the transmission line (a hazard is defined as one or more branches, tops, and/or whole trees that could fall or grow into the minimum safety zone of the transmission line(s) causing an electrical arc, relay and/or outage). The overall goal of BPA is to establish low-growing plant communities along the ROW to control the development of potentially threatening vegetation.

A combination of selective and nonselective vegetation control methods would be used to perform the work. All methods including selective cutting, mowing, and herbicide treatments are consistent with the methods approved in BPA's Transmission System Vegetation Management Program EIS. Debris would be disposed of using on-site chip, lop and scatter, or mulching techniques. All on-site debris would be scattered along the ROW.

The project would specifically include removal of Russian olive, willows, other incompatible hardwoods. Tree diameters of species to be removed would be less than five inches. No side limbing or removal of vegetation on access roads would be needed.

**Analysis:** A Vegetation Control Prescription & Checklist was developed for this corridor that incorporates the requirements identified in BPA's Transmission System Vegetation Management Program FEIS (DOE/EIS-0285, May 2000) and Record of Decision (August 23, 2000). The following summarizes natural resources occurring in the project area along with applicable mitigation measures outlined in the Vegetation Control Prescription & Checklist.

**Water Resources:** Water bodies (streams, rivers, lakes, wetlands) occurring in the project area are noted in the Vegetation Control Prescription. As conservation and avoidance measures, only spot and localized treatment with Garlon 3A (Triclopyr TEA) would be used within a 100 foot buffer up to the water's edge of any stream containing threatened or endangered species. Trees in riparian zones would be selectively cut to include only those that will grow into the minimum approach distances of the conductor at maximum sag, other trees would be left in place or topped to preserve shade. Shrubs that are less than 10-feet-high would not be cut where ground to conductor clearance allows. No ground disturbing vegetation management methods would be implemented thus eliminating the risk for soil erosion and sedimentation near the streams. For location information, see the Vegetation Control Prescription.

**Threatened and Endangered Species:** Pursuant to its obligations under the Endangered Species Act (ESA), BPA has made a determination of whether its proposed project would have any effects on any listed species. A species list was obtained for federally listed, proposed and candidate species potentially occurring within the project boundaries from the United States Fish and Wildlife Service (USFWS). Based on the ESA review conducted, BPA made a determination that the project would have "No Effect" for all ESA listed species under USFWS' jurisdiction. BPA also conducted a review of species under the jurisdiction of the National Oceanic and Atmospheric Administration, National Marine Fisheries Service (NOAA Fisheries). A determination of "No Effect" was made for all ESA listed species under NOAA Fisheries' jurisdiction, with the implementation of the conservation measures in Water Resources section above.

**Essential Fish Habitat:** A review of the NOAA Fisheries database identified Essential Fish Habitat (EFH) streams occurring in the project area. Measures identified for water resources would be followed for EFH. A determination of "No Effect" was made for EFH waters that occur in the project area.

**Cultural Resources:** No cultural resources are known for the project area. If a site is discovered during the course of vegetation control, work would be stopped in the vicinity and the BPA Environmental Specialist, and the BPA Archeologist would be contacted.

**Findings:** This Supplement Analysis finds that (1) the proposed actions are substantially consistent with the Transmission System Vegetation Management Program FEIS (DOE/EIS-0285) and ROD, and; (2) there are no new circumstances or information relevant to environmental concerns and bearing on the proposed actions or their impacts. This Supplement

Analysis also finds the proposed actions will not affect threatened or endangered species. Therefore, no further NEPA documentation is required.

/s/ Aaron Shurtliff

Aaron Shurtliff

Environmental Engineer

CONCUR: /s/ Stacy Mason

Stacy Mason

NEPA Compliance Officer

DATE: November 1, 2013

References:

Vegetation Management Prescription and Checklist  
Effects Determination