

Table 3.4-1

Comparison of Annual Emissions per Megawatt (MW) of Electricity Produced

Pollutant	Wanapa Energy Center Emissions (lb/MW-hr)¹	Boardman Coal Facility Emissions (lb//MW-hr)²	Percent Improvement
Sulfur Oxides	0.00784	11.59	99.9%
Nitrogen Dioxide	0.0415	4.83	99.1%
Particulate Matter	0.0693	0.402	82.8%
Carbon Monoxide	0.0191	0.292	93.5%
Volatile Organic Compounds	0.0174	0.0350	50.3%

¹ Based on a plant-wide electric generation capacity of 1,300 MW.

² Based on a plant-wide electric generation capacity of 600 MW.