



Department of Energy

Bonneville Power Administration
P.O. Box 491
Vancouver, Washington 98666-0491

TRANSMISSION SERVICES

June 18, 2008

In reply refer to: TEP-CSB-2

To: Parties interested in the Willow Creek Wind Interconnection Project

Bonneville Power Administration (BPA) has prepared the enclosed Record of Decision (ROD) for the Willow Creek Wind Interconnection Project (Wind Project), consistent with and tiered to BPA's Business Plan Environmental Impact Statement (DOE/EIS-0183, June 1995), and the Business Plan ROD (BP ROD, August 15, 1995).

Decision

BPA has decided to offer contract terms for interconnection of up to 72 megawatts of power to be generated by the proposed Wind Project into the Federal Columbia River Transmission System (FCRTS). Willow Creek Energy LLC proposes to construct and operate the Wind Project in Gilliam and Morrow counties, Oregon, and has requested interconnection into the FCRTS. BPA will construct a tap to allow the Wind Project to interconnect to BPA's existing Tower Road-Alkali No. 1 115-kilovolt transmission line. BPA will install new equipment at its existing Boardman Substation. BPA has considered both the economic and environmental consequences of the integration and will take measures to ensure the continued safe, reliable operation of the FCRTS.

Additional Information

If you would like additional copies of this ROD, it is available on BPA's Web site: www.efw.bpa.gov/environmental_services/Document_Library/Willow_Creek/. You may also call our toll-free document request line at (800) 622-4520 and leave a message with the name of the project and your complete mailing address.

If you need more information or have any questions, please call me toll free at (800) 622-4519, or e-mail me at ejaramillo@bpa.gov. Thank you for your interest in this project.

Sincerely,

/s/ Emmanuel Jaramillo
Emmanuel Jaramillo
Project Manager

Enclosure:
ROD