



Department of Energy

Bonneville Power Administration
P.O. Box 3621
Portland, Oregon 97208-3621

FREEDOM OF INFORMATION ACT PROGRAM

October 8, 2019

In reply refer to: FOIA #BPA-2019-01363-F

Talonya Adams
1700 West Law, PLLC
Phoenix, Arizona 85004
Email: ta@1700westlaw.com

Dear Ms. Adams:

Thank you for your interest in the Bonneville Power Administration (BPA). The agency received your request for records made under the Freedom of Information Act, 5 U.S.C. § 552, (FOIA) on September 16, 2019. Your request has been assigned a Department of Energy (DOE) tracking number of BPA-2019-01363-F. Please use that number in any correspondence with the agency concerning your request. This communication is the agency's formal acknowledgment and final response to your request.

Request

"[Please provide agency records showing...] utility outages at 180 NE Herman Creek Lane, Cascade Locks, Oregon 97014, between 1/1/2015 to 12/31/2016."

Acknowledgement

BPA has reviewed your request and has determined that it fulfills all of the criteria of a proper request under the FOIA and DOE regulations at Title 10, Code of Federal Regulations, Part 1004.

Response

BPA's Substation Ops Ross office located 1 page of records responsive to your request. BPA is herein releasing 1 page in full, with no redactions.

Fees

There are no fees associated with your request.

Certification

Pursuant to 10 C.F.R. § 1004.7(b)(2), I am the individual responsible for the records search and

release determination described above. Your FOIA request BPA-2019-00629-F is now closed with all available agency records provided.

Appeal

The adequacy of the search may be appealed within 90 calendar days from your receipt of this letter pursuant to 10 C.F.R. § 1004.8. Appeals should be addressed to:

Director, Office of Hearings and Appeals
HG-1, L'Enfant Plaza
U.S. Department of Energy
1000 Independence Avenue, S.W.
Washington, D.C. 20585-1615

The written appeal, including the envelope, must clearly indicate that a FOIA appeal is being made. You may also submit your appeal by e-mail to OHA.filings@hq.doe.gov, including the phrase "Freedom of Information Appeal" in the subject line. (The Office of Hearings and Appeals prefers to receive appeals by email.) The appeal must contain all the elements required by 10 C.F.R. § 1004.8, including a copy of the determination letter. Thereafter, judicial review will be available to you in the Federal District Court either (1) in the district where you reside, (2) where you have your principal place of business, (3) where DOE's records are situated, or (4) in the District of Columbia.

You may contact BPA's FOIA Public Liaison, Jason Taylor, at the address on this letter header for any further assistance and to discuss any aspect of your request. Additionally, you may contact the Office of Government Information Services (OGIS) at the National Archives and Records Administration to inquire about the FOIA mediation services they offer. The contact information for OGIS is as follows:

Office of Government Information Services
National Archives and Records Administration
8601 Adelphi Road-OGIS
College Park, Maryland 20740-6001
E-mail: ogis@nara.gov
Phone: 202-741-5770
Toll-free: 1-877-684-6448
Fax: 202-741-5769

Questions about this communication may be directed to Thanh Knudson, Flux Resources, LLC, at etknudson@bpa.gov or 503.230.5221

Sincerely,



Candice D. Palen
Freedom of Information/Privacy Act Officer

Enclosed: Responsive agency record

Customer , Planned, Automatic from 1/1/2015 00:00 to 12/31/2016 23:59, Cascade Locks OR Ordered by CustomerName, out_datetime															
Count	Outage ID	Tred ID	Customer Name	Line/POD Name	Type	Gen Flag	kV	Ops Spc HQ	O&M District	OutDatetime	InDatetime	Dur Mins	Outage Type	Cause	Responsible System
2	192990	121	Cascade Locks OR	Cascade Locks: Cascade Locks OR 115kV Feeder 1	P		115.0	ROS	LGV	5/21/2015 14:33	10/30/2015 8:30	232917	Plan	Maintenance	Customer
3	195305	121	Cascade Locks OR	Cascade Locks: Cascade Locks OR 115kV Feeder 1	P		115.0	ROS	LGV	10/30/2015 9:00	1/15/2016 9:21	110961	Plan	Maintenance	Customer
5	195625	118	Cascade Locks OR	Cascade Locks: Cascade Locks OR 13.8kV Feeder 1	P		13.8	ROS	LGV	11/17/2015 16:16	11/17/2015 17:26	70	Auto	Wind	BPA
7	195951	118	Cascade Locks OR	Cascade Locks: Cascade Locks OR 13.8kV Feeder 1	P		13.8	ROS	LGV	12/9/2015 4:33	12/9/2015 5:50	77	Auto	Weather	BPA
9	196152	118	Cascade Locks OR	Cascade Locks: Cascade Locks OR 13.8kV Feeder 1	P		13.8	ROS	LGV	12/21/2015 14:26	12/22/2015 7:41	1035	Auto	Wind	Customer
10	196695	118	Cascade Locks OR	Cascade Locks: Cascade Locks OR 13.8kV Feeder 1	P		13.8	ROS	LGV	2/28/2016 8:04	7/1/2016 9:59	178615	Plan	Switching	BPA
12	197988	121	Cascade Locks OR	Cascade Locks: Cascade Locks OR 115kV Feeder 1	P		115.0	ROS	LGV	6/17/2016 4:54	6/17/2016 5:03	9	Auto	Unknown	BPA
13	198978	118	Cascade Locks OR	Cascade Locks: Cascade Locks OR 13.8kV Feeder 1	P		13.8	ROS	LGV	8/25/2016 8:42	8/25/2016 13:16	274	Plan	Maintenance	BPA
15	200247	118	Cascade Locks OR	Cascade Locks: Cascade Locks OR 13.8kV Feeder 1	P		13.8	ROS	LGV	12/8/2016 23:27	12/8/2016 23:30	3	Auto	Wind	BPA
16	200246	121	Cascade Locks OR	Cascade Locks: Cascade Locks OR 115kV Feeder 1	P		115.0	ROS	LGV	12/8/2016 23:27	12/8/2016 23:30	3	Auto	Wind	BPA