

Seattle City Light
Generator Interconnection Reform Proposal Comments

Seattle City Lights

Eric Espenhorst

Date: October 5, 2012

Subject: GI Reform Proposal Comment

Regarding the SGIA, Seattle City Light requests that small, unattended plants should be able to purchase curtailment service as follows:

If BPA curtails transmission due to flowgate constraints, and Sink BA approves e-Tag Reliability Limit adjustment, BPA should adjust its AGC accordingly (backing down generation) and absorb the output as gen imbalance.

Eric Espenhorst
Seattle City Light
Power Management Division