



Transmission Services

E-Tags for Schedules between Nevada Power and California

Updated: 04/10/14

Transactions using BPAT transmission between the Nevada Power Balancing Area (NEVP) and the California Independent System Operator Balancing Area (CISO) or Balancing Authority of Northern California (BANC) require the use of two BPAT e-Tag segments of transmission:

1. Between Hilltop345 and Malin230.
2. BPAT facilities either across Malin500 or between Malin500 and across CaptainJack.

Table of Contents

Submitting eTags	1
Examples	1
Flow Diagram	3

Submitting eTags

1. To create the proper interchange, e-Tags must reference both BPAT transmission segments.
 BPAT standard and custom tag path validation will not fail an e-tag that incorrectly references only one segment of BPAT transmission, since the missing segment is not available to be validated. Failure to reference both transmission segments will result in identification of the problem (incorrect interchange totals for BPAT/CISO and BPAT/PACW) before or during checkout and may result in the e-Tag being curtailed to zero and the schedule removed.
2. For transactions between NEVP and the CISO or BANC, BPAT does not charge for the use of facilities across Malin500 or between Malin500 and across CaptainJack. To exempt this segment of the transaction from incurring transmission charges and loss obligations when referencing a POR/POD combination of Malin500/Malin500 or Malin500/CaptainJack on an e-tag, reference "SERVICE-NOR" in the OASIS field of the e-tag. The use of SERVICE-NOR is limited to certain paths and/or owners.

Examples

From NEVP to CISO AC

CA	PSE	TP	POR	POD	SE
NEVP			Source: AnySource		
	APSE	NEVP	NEVP_POR	HILLTOP345	NEVP
	APSE	BPAT	HILLTOP345	Malin230	BPAT*

CA	PSE	TP	POR	POD	SE
	APSE	PPW	Malin230	MALIN500	PACW
	APSE	BPAT	MALIN500	MALIN500	BPAT**
	APSE	CISO	MALIN500	CISO_POD	CISO
CISO			Sink: AnySink		

* Reference valid Transmission Services contract or OASIS Reference in the OASIS field.

** Reference SERVICE-NOR in the e-tag OASIS field.

From NEVP to CISO (BANC) 3A

CA	PSE	TP	POR	POD	SE
NEVP			Source: AnySource		
	APSE	NEVP	NEVP_POR	HILLTOP345	NEVP
	APSE	BPAT	HILLTOP345	Malin230	BPAT*
	APSE	PPW	Malin230	MALIN500	PACW
	APSE	BPAT	MALIN500	CaptainJack	BPAT **
	APSE	CISO	CaptainJack	TRY500	BANC
BANC			Sink: AnySink		

From CISO AC to NEVP

CA	PSE	TP	POR	POD	SE
CISO			Source: AnySource		
	APSE	CISO	CISO_POR	MALIN500	CISO
	APSE	BPAT	MALIN500	MALIN500	BPAT**
	APSE	PPW	MALIN500	Malin230	PACW
	APSE	BPAT	Malin230	Hilltop345	BPAT*
	APSE	NEVP	HILLTOP345	NEVP_POD	NEVP
NEVP			Sink: AnySink		

From CISO (BANC) 3A to NEVP

CA	PSE	TP	POR	POD	SE
BANC			Source: AnySource		
	APSE	CISO	TRY500	CaptainJack	BANC
	APSE	BPAT	CaptainJack	Malin500	BPAT**

CA	PSE	TP	POR	POD	SE
	APSE	PPW	Malin500	Malin230	PACW
	APSE	BPAT	Malin230	HILLTOP345	BPAT*
	APSE	NEVP	HILLTOP345	NEVP_POD	NEVP
NEVP			Sink: AnySink		

Flow Diagram

